



Institut luxembourgeois de la normalisation  
de l'accréditation, de la sécurité et qualité  
des produits et services

## ILNAS-EN 16750:2017

### **Fixed firefighting systems - Oxygen reduction systems - Design, installation, planning and maintenance**

Ortsfeste Löschanlagen -  
Sauerstoffreduktionsanlagen -  
Auslegung, Einbau, Planung und  
Instandhaltung

Installations fixes de lutte contre  
l'incendie - Systèmes d'appauvrissement  
en oxygène - Conception, installation,  
planification et maintenance

09/2017



## National Foreword

This European Standard EN 16750:2017 was adopted as Luxembourgish Standard ILNAS-EN 16750:2017.

Every interested party, which is member of an organization based in Luxembourg, can participate for FREE in the development of Luxembourgish (ILNAS), European (CEN, CENELEC) and International (ISO, IEC) standards:

- Participate in the design of standards
- Foresee future developments
- Participate in technical committee meetings

<https://portail-qualite.public.lu/fr/normes-normalisation/participer-normalisation.html>

### **THIS PUBLICATION IS COPYRIGHT PROTECTED**

Nothing from this publication may be reproduced or utilized in any form or by any mean - electronic, mechanical, photocopying or any other data carries without prior permission!

EUROPEAN STANDARD ILNAS-EN 16750:2017 **EN 16750**  
NORME EUROPÉENNE  
EUROPÄISCHE NORM September 2017

---

ICS 13.220.20

English Version

**Fixed firefighting systems - Oxygen reduction systems -  
Design, installation, planning and maintenance**

Installations fixes de lutte contre l'incendie - Systèmes  
d'appauvrissement en oxygène - Conception,  
installation, planification et maintenance

Ortsfeste Löschanlagen - Sauerstoffreduktionsanlagen -  
Konstruktion, Einbau, Planung und Instandhaltung

This European Standard was approved by CEN on 9 July 2017.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION  
COMITÉ EUROPÉEN DE NORMALISATION  
EUROPÄISCHES KOMITEE FÜR NORMUNG

**CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels**

---

# Contents

Page

European foreword.....	4
Introduction .....	5
1 Scope .....	6
2 Normative references .....	6
3 Terms and definitions .....	7
4 System requirements.....	9
4.1 General.....	9
4.2 Personnel safety .....	9
4.3 Effectiveness and application .....	9
4.4 Alarm organization and emergency plan .....	10
5 Design .....	10
5.1 Qualification of the designer .....	10
5.2 Fire protection concept.....	10
5.3 Structural specifications for the protected area.....	10
5.4 Oxygen concentration.....	11
5.5 Oxygen reduction to prevent fire .....	11
5.6 Safety margins.....	12
5.7 Oxygen reduced air quantity.....	16
5.7.1 Continuous oxygen reduction.....	16
5.7.2 Emergency plan .....	16
5.7.3 Oxygen reduced air.....	16
5.7.4 Gaseous supply.....	17
5.7.5 Fault signals .....	17
5.8 Technical areas .....	17
5.8.1 Technical area for control panel .....	17
5.8.2 Technical area for reduced oxygen air generation .....	18
6 Distribution pipework .....	18
6.1 Pipework.....	18
6.2 Pipe supports.....	19
6.3 Components in the pipework.....	19
7 Monitoring the oxygen concentration .....	19
8 Alarms and notifications .....	21
9 Control equipment.....	21
9.1 Function.....	21
9.2 Requirements.....	22
9.3 Electrical power supply .....	22
9.4 Electrical installations.....	22
9.5 Data recording.....	22
10 System operation .....	23
10.1 Instruction and training of personnel .....	23
10.2 Inspections .....	23
10.3 Operations log .....	23
10.4 Further obligations.....	23

<b>11</b>	<b>Maintenance .....</b>	<b>23</b>
<b>12</b>	<b>Documentation .....</b>	<b>24</b>
<b>13</b>	<b>Installation .....</b>	<b>25</b>
<b>13.1</b>	<b>Qualification of the installer .....</b>	<b>25</b>
<b>13.2</b>	<b>General specifications, installation .....</b>	<b>25</b>
<b>Annex A (normative) Ignition thresholds for oxygen reduction using nitrogen in fire prevention .....</b>		
		<b>26</b>
<b>A.1</b>	<b>Ignition thresholds .....</b>	<b>26</b>
<b>A.2</b>	<b>Tests to ascertain ignition thresholds of unfamiliar materials .....</b>	<b>27</b>
<b>A.2.1</b>	<b>Cup burner tests .....</b>	<b>27</b>
<b>A.2.2</b>	<b>Ignition threshold tests .....</b>	<b>28</b>
<b>A.2.2.1</b>	<b>General .....</b>	<b>28</b>
<b>A.2.2.2</b>	<b>Test criteria .....</b>	<b>29</b>
<b>A.2.2.3</b>	<b>Test documentation .....</b>	<b>29</b>
<b>Annex B (informative) Information for health and safety – Working in oxygen-reduction atmospheres for reasons of fire prevention .....</b>		
		<b>31</b>
<b>B.1</b>	<b>General .....</b>	<b>31</b>
<b>B.2</b>	<b>Principles of occupational health .....</b>	<b>31</b>
<b>B.3</b>	<b>Risk classes .....</b>	<b>31</b>
<b>B.4</b>	<b>Basic requirements, planning and installation .....</b>	<b>32</b>
<b>B.5</b>	<b>Protective measures for all areas with oxygen-reduced atmospheres .....</b>	<b>33</b>
<b>B.5.1</b>	<b>Structural and technical measures .....</b>	<b>33</b>
<b>B.5.2</b>	<b>Organizational measures .....</b>	<b>34</b>
<b>B.6</b>	<b>Risk classes and safety measures .....</b>	<b>34</b>
<b>Annex C (informative) Existing national regulations for access and working in areas with lower oxygen concentration .....</b>		
		<b>36</b>
<b>Bibliography .....</b>		<b>37</b>

## European foreword

This document (EN 16750:2017) has been prepared by Technical Committee CEN/TC 191 “Fixed firefighting systems”, the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by March 2018, and conflicting national standards shall be withdrawn at the latest by March 2018.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

## Introduction

Oxygen reduction systems are designed to prevent fires from starting or spreading, by means of the introduction of oxygen reduced air. Oxygen reduction systems are not designed to extinguish fires. The design and installation shall be based on detailed knowledge of the protected area, its occupancy and the materials in question. It is important to suit the fire protection measures to the hazard as a whole.

It is important to emphasize that across the European Union there are several regulatory and legislative limitations for access and working in areas with lower oxygen concentration, so it is important to take these limitations into account. Use of this European Standard can vary based on the national legislation in each country of the European Union.

## 1 Scope

This European standard specifies oxygen reduction systems that are used as fire prevention systems by creating an atmosphere in an area which is having a lower permanent oxygen concentration as in ambient conditions. The level of oxygen reduction is defined by the individual risks of these areas (see Annex A). Oxygen reduction is achieved by technical systems which are providing a flux of air containing a reduced concentration of oxygen.

This European standard specifies minimum requirements and defines the specifications governing the design, installation and maintenance of fixed oxygen reduction systems with oxygen reduced air in buildings and industrial production plants. The standard also applies to the extension and modification of existing systems.

This European standard applies to oxygen reduction systems using nitrogen which are designed for continual oxygen reduction in enclosed spaces.

NOTE Nitrogen is today the most suitable gas to be used for oxygen reduction. For other gases this European standard can be used as basis.

This European standard does not apply to oxygen reduction systems that use water mist or combustion gases.

The European standard does not apply to:

- explosion suppression systems;
- explosion prevention systems;
- fire extinguishing systems using gaseous extinguishing agents;
- inertization of portable containers;
- systems in which oxygen levels are reduced for reasons other than fire prevention (e.g. steel processing in the presence of inert gas to avoid the formation of oxide film);
- inerting required during repair work on systems or equipment (e.g. welding) in order to eliminate the risk of fire or explosion.

In addition to the conditions for the actual oxygen reduction system and its individual components this European standard also covers certain structural specifications for the protected area.

The space protected by an oxygen reduction system is a controlled and continuously monitored indoor climate for extended occupation. This standard does not cover unventilated confined spaces that may contain hazardous gases.

## 2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 54 (all parts), *Fire detection and fire alarm systems*

EN 12094-1, *Fixed firefighting systems - Components for gas extinguishing systems - Part 1: Requirements and test methods for electrical automatic control and delay devices*