

Explosive atmospheres - Part 0: Equipment - General requirements

Explosionsgefährdete Bereiche - Teil 0: Betriebsmittel - Allgemeine Anforderungen

Atmosphères explosives - Partie 0: Matériel - Exigences générales

07/2018

National Foreword

This European Standard EN IEC 60079-0:2018 was adopted as Luxembourgish Standard ILNAS-EN IEC 60079-0:2018.

Every interested party, which is member of an organization based in Luxembourg, can participate for FREE in the development of Luxembourgish (ILNAS), European (CEN, CENELEC) and International (ISO, IEC) standards:

- Participate in the design of standards
- Foresee future developments
- Participate in technical committee meetings

<https://portail-qualite.public.lu/fr/normes-normalisation/participer-normalisation.html>

THIS PUBLICATION IS COPYRIGHT PROTECTED

Nothing from this publication may be reproduced or utilized in any form or by any mean - electronic, mechanical, photocopying or any other data carries without prior permission!

English Version

Explosive atmospheres - Part 0: Equipment - General requirements (IEC 60079-0:2017)

Atmosphères explosives - Partie 0: Matériel - Exigences
générales
(IEC 60079-0:2017)

Explosionsgefährdete Bereiche - Teil 0: Betriebsmittel -
Allgemeine Anforderungen
(IEC 60079-0:2017)

This European Standard was approved by CENELEC on 2017-12-04. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

European foreword

The text of document (31/1345/FDIS), future edition 7 of IEC 60079-0, prepared by IEC/TC 31 "Equipment for explosive atmospheres" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 60079-0:2018.

The following dates are fixed:

- latest date by which the document has to be (dop) 2019-01-06
implemented at national level by
publication of an identical national
standard or by endorsement
- latest date by which the national (dow) 2021-07-06
standards conflicting with the
document have to be withdrawn

This document supersedes EN 60079-0:2012.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a mandate given to CENELEC by the European Commission and the European Free Trade Association, and supports essential requirements of EU Directive(s).

For the relationship with EU Directive(s) see informative Annex ZZ, which is an integral part of this document.

Endorsement notice

The text of the International Standard IEC 60079-0:2017 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC/TS 60034-25	NOTE	Harmonized as CLC/TS 60034-25.
IEC 60034-29	NOTE	Harmonized as EN 60034-29.
IEC 60079-2	NOTE	Harmonized as EN 60079-2.
IEC 60079-5	NOTE	Harmonized as EN 60079-5.
IEC 60079-6	NOTE	Harmonized as EN 60079-6.
IEC 60079-7	NOTE	Harmonized as EN 60079-7.
IEC 60079-10-1	NOTE	Harmonized as EN 60079-10-1.
IEC 60079-10-2	NOTE	Harmonized as EN 60079-10-2.
IEC 60079-11	NOTE	Harmonized as EN 60079-11.
IEC 60079-13	NOTE	Harmonized as EN 60079-13.
IEC 60079-14	NOTE	Harmonized as EN 60079-14.
IEC 60079-15	NOTE	Harmonized as EN 60079-15.
IEC 60079-17	NOTE	Harmonized as EN 60079-17.
IEC 60079-18	NOTE	Harmonized as EN 60079-18.
IEC 60079-19	NOTE	Harmonized as EN 60079-19.
IEC 60079-25	NOTE	Harmonized as EN 60079-25.
IEC 60079-28	NOTE	Harmonized as EN 60079-28.
IEC 60079-29-1	NOTE	Harmonized as EN 60079-29-1.

IEC 60079-29-4	NOTE	Harmonized as EN 60079-29-4.
IEC/IEEE 60079-30-1	NOTE	Harmonized as EN 60079-30-1.
IEC 60079-31	NOTE	Harmonized as EN 60079-31.
IEC/TS 60079-32-1	NOTE	Harmonized as CLC/TR 60079-32-1.
IEC/TS 60079-39	NOTE	Harmonized as CLC/TS 60079-39 ¹⁾ .
IEC 60254 (series)	NOTE	Harmonized in EN 60254 series.
IEC 60623	NOTE	Harmonized as EN 60623.
IEC 60896-11	NOTE	Harmonized as EN 60896-11.
IEC 60896-21	NOTE	Harmonized as EN 60896-21.
IEC 60952 (series)	NOTE	Harmonized in EN 60952 series.
IEC 61056-1	NOTE	Harmonized in EN 61056-1.
IEC 61427 (series)	NOTE	Harmonized in EN 61427 series.
IEC 61951-1	NOTE	Harmonized as EN 61951-1.
IEC 61951-2	NOTE	Harmonized as EN 61951-2.
IEC 61960 (series)	NOTE	Harmonized in EN 61960 series.
ISO/IEC 80079-20-2	NOTE	Harmonized as EN ISO/IEC 80079-20-2.
ISO/IEC 80079-34	NOTE	Harmonized as EN ISO/IEC 80079-34.
ISO/IEC 80079-36	NOTE	Harmonized as EN ISO/IEC 80079-36.
ISO/IEC 17000	NOTE	Harmonized as EN ISO/IEC 17000.

¹⁾ Under preparation. Stage at the time of publication: CLC/FprTS 60079-39:2017.

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 Where an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60034-1	-	Rotating electrical machines - Part 1: Rating and performance	EN 60034-1 ²⁾	-
IEC 60034-5	-	Rotating electrical machines - Part 5: Degrees of protection provided by the integral design of rotating electrical machines (IP code) - Classification	EN 60034-5	2001
IEC 60079-1	-	Explosive atmospheres - Part 1: Equipment protection by flameproof enclosures "d"	EN 60079-1	2014
IEC 60079-20-1	-	Explosive atmospheres - Part 20-1: Material characteristics for gas and vapour classification - Test methods and data	EN 60079-20-1	2010
IEC 60079-26	-	Explosive atmospheres - Part 26: Equipment with equipment protection level (EPL) Ga	EN 60079-26	2015
IEC 60079-35-1	-	Explosive atmospheres - Part 35-1: Caplights for use in mines susceptible to firedamp - General requirements - Construction and testing in relation to the risk of explosion	EN 60079-35-1	2011
IEC 60086-1	-	Primary batteries - Part 1: General	+AC EN 60086-1	2011
IEC 60192	-	Low pressure sodium vapour lamps - Performance specifications	EN 60192	2015
IEC 60216-1	-	Electrical insulating materials - Thermal endurance properties - Part 1: Ageing procedures and evaluation of test results	EN 60216-1	2001
IEC 60216-2	-	Electrical insulating materials - Thermal endurance properties - Part 2: Determination of thermal endurance properties of electrical insulating materials - Choice of test criteria	EN 60216-2	2013
IEC 60243-1	-	Electric strength of insulating materials - Test methods - Part 1: Tests at power frequencies	EN 60243-1	2005
IEC 60423	-	Conduit systems for cable management - Outside diameters of conduits for electrical installations and threads for conduits and fittings	EN 60423	2013
IEC 60529	-	Degrees of protection provided by enclosures (IP Code)	EN 60529	2007
			+EN 60529:1991/corrigendum May 1993	1991
				1993

²⁾ Under preparation. Stage at the time of publication: FprEN 60034-1:2017.

IEC 60662 (mod)	-	High pressure sodium vapour lamps - Performance specifications	EN 60662	2012
IEC 60664-1	-	Insulation coordination for equipment within low-voltage systems - Part 1: Principles, requirements and tests	+prAA EN 60664-1	2017 2007
IEC 60947-1	-	Low-voltage switchgear and controlgear - Part 1: General rules	EN 60947-1	2007
IEC 62626-1	-	Low-voltage switchgear and controlgear enclosed equipment - Part 1: Enclosed switch outside the scope of IEC 60947-3 for various applications, to provide isolation of electrical equipment during repair and maintenance work	EN 62626-1	2014
ISO 48	-	Rubber, vulcanized or thermoplastic - Determination of hardness (hardness between 10 IRHD and 100 IRHD)	-	-
ISO 178	-	Plastics - Determination of flexural properties	EN ISO 178	2010
ISO 179	series	Plastics - Determination of Charpy impact properties	EN ISO 179	series
ISO 262	-	ISO general purpose metric screw threads- Selected sizes for screws, bolts and nuts	-	-
ISO 273	-	Fasteners - Clearance holes for bolts and screws	EN 20273	1991
ISO 527-2	-	Plastics - Determination of tensile properties - Part 2: Test conditions for moulding and extrusion plastics	EN ISO 527-2	2012
ISO 965-1	-	ISO general purpose metric screw threads - Tolerances – Part 1: Principles and basic data	-	-
ISO 965-3	-	ISO general purpose metric screw threads- Tolerances – Part 3: Deviations for constructional screw threads	-	-
ISO 3601-1	-	Fluid power systems - O-rings – Part 1: Inside diameters, cross-sections, tolerances and designation codes	-	-
ISO 3601-2	-	Fluid power systems - O-rings - Part 2: Housing dimensions for general applications	-	-
ISO 4014	-	Hexagon head bolts - Product grades A and B	EN ISO 4014	2011
ISO 4017	-	Fasteners - Hexagon head screws - Product grades A and B	EN ISO 4017	2014
ISO 4026	-	Hexagon socket set screws with flat point	EN ISO 4026	2003
ISO 4027	-	Hexagon socket set screws with cone point	EN ISO 4027	2003
ISO 4028	-	Hexagon socket set screws with dog point	EN ISO 4028	2003
ISO 4029	-	Hexagon socket set screws with cup point	EN ISO 4029	2003
ISO 4032	-	Hexagon regular nuts (style 1) - Product grades A and B	EN ISO 4032	2012
ISO 4762	-	Hexagon socket head cap screws	EN ISO 4762	2004
ISO 4892-2	-	Plastics - Methods of exposure to laboratory light sources - Part 2: Xenon-arc lamps	EN ISO 4892-2	2013
ISO 7380	-	Hexagon socket button head screws	EN ISO 7380	2011
ISO 14583	-	Hexalobular socket pan head screws	EN ISO 14583	2011
ANSI/UL 746B	-	Polymeric Materials - Long-Term Property Evaluations	-	-
ANSI/UL 746C	-	Standard for Polymeric Materials - Use in Electrical Equipment Evaluations	-	-
ASTM D 5964	-	Standard Practice for Rubber IRM 901, IRM 902, and IRM 903 Replacement Oils for ASTM No. 1, ASTM No. 2, ASTM No. 3 Oils, and IRM 905 formerly ASTM No. 5 Oil	-	-

Annex ZY (informative)

Additional Information relating to the European ATEX Directive 2014/34/EU

ZY.1 Equipment Groups and Categories

In all cases Equipment Protection Levels (EPL) as defined by EN IEC 60079-0 are related to the corresponding Equipment Groups and Equipment Categories according to table ZY.1. The same applies if a standard makes reference to the intended use of equipment in Zones according to the definitions in EN 60079-10-1 and EN 60079-10-2.

Table ZY.1

EN IEC 60079-0		Directive 2014/34/EU		EN 60079-10-X
EPL	Group	Equipment Group	Equipment Category	Zones
Ma	I	I	M1	Not Applicable
Mb			M2	
Ga	II	II	1G	0
Gb			2G	1
Gc			3G	2
Da	III		1D	20
Db			2D	21
Dc			3D	22

ZY.2 Instructions

The manufacturer or his authorized representative in the Community is to draw up the instructions for use in the required Community languages.

In clause 30.1 under: “instructions for safety addressing the following areas – installation and erection;”

“Information other than the general requirements given in IEC 60079-14”

Is replaced by

“Information other than the general requirements given in EN 60079-14 and EN 50628”


NOTE EN 50628 - Erection of electrical installations in underground mines

ZY.3 Marking

ZY.3.1

The marking according to this standard is to be supplemented by the marking according to Directive 2014/34/EU. Examples are given below.

European marking examples

Directive part	Standard part	Equipment example
 I M2	Ex db I Mb	Mining equipment,

Type of Protection flameproof enclosure “d”



II 2G

Ex eb IIB T4 Gb

Gas explosion protected equipment

Type of Protection increased safety “e”



II 1D

Ex ma IIIC 120°C Da

Dust explosion protected equipment,

Type of Protection encapsulation “m”

NOTE 1 Attention is drawn to the requirement in 29.3 f):

“The Ex marking for explosive gas atmospheres and explosive dust atmospheres shall be separate and not combined;”



II 1 G

Ex ia IIB T4 Ga



II 1 D

Ex ia IIIC T120°C Da

Alternatively, the directive part of the marking may be combined and the standard part of the marking kept separate, as follows:



II 1 GD

Ex ia IIB T4 Ga

Ex ia IIIC T120°C Da

NOTE 2 For Ex Equipment intended to be put on the market in the EEA, CE marking is applicable. For Ex Components intended to be put on the market in the EEA, CE marking is not applicable.

ZY.3.2

Contrary to 29.3 a) the marking is to always include the manufacturer's name (not trademark) and address. The address is to be sufficient to identify the physical location of the manufacturer. An address used for postal purposes, without identifying the physical location, is not sufficient.

ZY.4 Fans

Clause 17.2.5 “Room ventilating fans” is to be supplemented by the requirements given in EN 14986 “Design of fans working in potentially explosive atmospheres”

ZY.5 Significant changes between this European Standard and EN 60079-0:2012+A11:2013

This European Standard supersedes EN 60079-0:2012+A11:2013.

Table ZY.2 – Significant changes with respect to EN 60079-0:2012+A11:

Explanation of the significance of the changes	Clause	Type		
		Minor and editorial changes	Extension	Major technical changes
Throughout document, “electrical equipment” replaced by “equipment” where appropriate.	Multiple	X		
Scope List of “Type of “Protection” and “Product” standards combined into one list.	1	X		
Definitions used in multiple sub-parts added. Definitions harmonized across sub-parts and added to 60079-0 where appropriate. Battery definitions updated	3	X		

Explanation of the significance of the changes	Clause	Type		
		Minor and editorial changes	Extension	Major technical changes
Clarification of the way that information on process temperature influences can be expressed.	5.1.2	X		
Clarification regarding the determination of service temperatures when dust layers are present	5.2	X		
Clarification on the need to provide service temperature information for Ex Components in the Schedule of Limitations	5.2	X		
Relocation of EPL Da dust layer requirements from IEC 60079-18 & IEC 60079-31	5.3.2.3.1	A1		
Clarified that for EPL Db, a maximum specified dust layer of greater than 200 mm is not permitted as thicker layers have no additional effect on maximum surface temperature.	b)	X		
Added for EPL Db, a dust layer in a specified orientation, marked as T_L	c)		X	
Clarified that for EPL Dc, no dust layer tests are required.	5.3.2.3.3	X		
Clarified that the “temperature” is the temperature of the air surrounding the component	5.3.3	X		
Subdivided section dealing with higher permitted surface temperatures for “smooth” surfaces. Corrected area from 1 000 mm ² to 10 000 mm ² .	5.3.4	X		
Clarified that the “Ex” requirements of IEC 60079 supplement those of the relevant industrial standards.	6.1	X		
Added requirement that where an adhesive is used to secure a gasket, it shall be used within its COT and shall comply with the requirements for cements.	6.5			C1
Requirements relocated to IEC 60079-28	former 6.6.2	A2		
Ultrasonic requirements updated based on latest research work	6.6.3		X	
Added reference to IEC 60079-28	6.6.4	A2		
Material identification parameters have been revised to reflect reasonably obtainable information	7.1.2.2	X		
“RTI-mechanical” has been clarified to include “RTI-mechanical strength” and “RTI-mechanical impact”	7.1.2.2	X		
Material identification parameters have been revised to reflect reasonably obtainable information	7.1.2.3	X		
Relocated information on “cements” from Clause 12.	7.1.2.4	X		
“RTI-mechanical” has been clarified to include “RTI-mechanical strength” and “RTI-mechanical	7.2.2	X		

Explanation of the significance of the changes	Clause	Type		
		Minor and editorial changes	Extension	Major technical changes
impact". Requirements for cements aligned with the requirements for elastomers.				
Relocation of 10 K margin for EPL Gc or Dc from IEC 60079-15, IEC 60079-18 & IEC 60079-31	7.2.2	A3		
Added clarification with respect to gaskets and seals where only the outer edge is potentially exposed to light.	7.3	X		
Clarification added that one or more of the described techniques may be used	7.4.2	X		
Added additional relaxation for the case where a surface is in contact with an earthed surface on only two of four sides.	7.4.2 b)		X	
Added reference to IEC 60243-1 and IEC 60243-2 for test method to require a 4 kV DC test.	7.4.2.c)			C2
Additional guidance added with respect to the possible Specific Conditions of Use	7.4.2 e)	X		
New option added for portable, mains-powered equipment with earth-connected guard	7.4.2 f)		X	
Added option for determination of maximum transferred charge.	7.4.2 g) Table 10		X	
Added missing limits (same as 7.4.2)	7.4.3 a)	X		
Clarified that it is a dc test that is conducted	7.4.3 b)	X		
Clarified that this requirement is not applied to personal or portable equipment	7.5	X		
Clarified Group I limits	8.2	X		
Clarified Group II, EPL Ga limits	8.3	X		
Added limitation for external surfaces of >65% copper	8.5			C3
Added clarification as to what is considered a tool	9.1	X		
Clarified that the tolerance class of the set screw is not critical, only that it not protrude from the threaded hole after tightening.	9.4	X		
Information on cements transferred to Clause 7	12	X		
Required that Ex Component Certificates require a Schedule of Limitations in all cases	13.5		X	
Revised to clarified that all connection facilities may not be a "Compartment".	14	X		
Sub-clause split to separate the requirements for protective earthing and equipotential bonding into separate sections	15.3 15.4	X		
Section split to separate secureness of electrical connections from the internal earth continuity plate.	15.6 15.7	X		
Non-threaded Group I cable glands are no longer required to be Ex Components.	16.3		X	
Non-threaded Group I blanking elements are no	16.4		X	

Explanation of the significance of the changes	Clause	Type		
		Minor and editorial changes	Extension	Major technical changes
longer required to be Ex Components.				
Scope of Clause 17 clarified to define applicability	17	X		
Additional guidance notes added to address bearings	17.3	X		
Clarified applicability to disconnectors, interlocks, and maintenance switches.	18.2	X		
Fuse requirements deleted as they are addressed in the individual sub-parts	19	X		
Added requirements for EPL Gc and Dc	20.1			C4
The test circuit requirements for a flameproof connection have been removed as they are more completely specified in IEC 60079-1.	20.2	X		
The impact test requirements for luminaires are relocated to Table 15	21.1 Table 15	X		
Clarified interlock switch operation for flameproof luminaires	21.2	X		
Clarified that some Types of Protection permit connection of cells in parallel	23.2	X		
New cell types and data added based on latest available data	Table 13		X	
New cell types and data added based on latest available data	Table 14			C5
Clarification of what documentation is to be prepared regarding the explosion safety aspects of the equipment	24	X		
Clarification that the type tests are to take into consideration the installation instructions	26.2	X		
Clarification that the "glass" requirements also apply to "ceramic" parts	26.4.1.1	X		
Added a permission to interchange the order of tests at the "lower test temperature" and the "upper test temperature".	26.4.1.2.2 26.4.1.2.3	X		
Clarified the construction of the impact test fixture	26.4.2	X		
Clarified the impact tests for glass parts	26.4.2	X		
Added clarification to deal with the new IPX9 ratings	26.4.5.1		X	
Clarified the test voltage for maximum surface temperature	26.5.1.3	X		
Relocation of EPL Da dust layer requirements from IEC 60079-18 & IEC 60079-31	26.5.1.3	A1		
Relocation of EPL Db specified dust layer requirements from IEC 60079-31	26.5.1.3	A4		
Added for EPL Db, a dust layer in a specified orientation, marked as T_L	26.5.1.3		B1	

Explanation of the significance of the changes	Clause	Type		
		Minor and editorial changes	Extension	Major technical changes
Clarified that for EPL Dc, the testing is conducted without a dust layer.	26.5.1.3	X		
Relocation of thermal endurance to heat 10K relaxation for Gc equipment from IEC 60079-15, IEC 60079-18, & IEC 60079-31	Table 17	X		
Clarification of a consistent way to address elastomeric materials exposed to ultraviolet light	26.10	X		
Replacement of "oil No. 2" with the revised designation of "oil IRM 902".	26.11	X		
Option added for testing at lower voltages when low resistance materials are encountered	26.13		X	
Transferred charge test added based on IEC TS 60079-32-2	26.17		X	
The reference to a specific instruction document instead of an "X" condition relocated to e) instead of a note giving a permission	29.3 e)	X		
Updated to reflect the additional levels of protection already shown in the sub-parts: "da", "dc", "eb", "ec", "oc", "op is", "op pr", "op sh", "pxb", "pyb", "pzc", "qb", "sa", "sb", and "sc".	29.4 b)	X		
Text added to address marking of "Ex associated equipment"	29.4		X	
Updated to reflect the additional levels of protection already shown in the sub-parts: "ic", "op is", "op pr", "op sh", "pxb", "pyb", "pzc", "sa", "sb", and "sc".	29.5 b)	X		
Clarified marking of EPL Da, EPL Db with no dust layer, EPL Db with a specified dust layer, and EPL Dc.	29.5 d)	X		
Introduced marking for EPL Db with a dust layer in a specified orientation	29.5 d)		X	
Text added to address marking of "Ex associated equipment"	29.5		X	
Text added to address marking of equipment intended to be installed in a boundary wall.	29.9		X	
The marking of Ex Component enclosure was aligned with the marking requirements of IEC 60079-1 and IEC 60079-7	29.10	X		
The alternate marking of EPL has been deleted.	former 29.13			C6
Marking for electric machines operated with a converter clarified	29.15	X		
Instruction material guidance clarified	30.1	X		
Additional instruction material for electric machines added	30.3			C7
Additional instruction material for cable glands added	30.5 A.5			C8

Explanation of the significance of the changes	Clause	Type		
		Minor and editorial changes	Extension	Major technical changes
Allow ISO 10807 hose assemblies to be used with cable glands.	A.1		X	
Clarify testing with stainless steel mandrels	A.3	X		
Reduction of the time / slippage permitted	A.3.1.1		X	
Clarify impact testing of cable glands	A.3.3 Figure A.3	X		
Clarified the order of tests	A.3.4	X		
Clarified remarks	Annex B	X		
Aligned Figure with text	Figure C.1	X		
Clarified operation of electric machines from converters	Annex D (informative)	X		
Clarified temperature testing of electric machines	Annex E (informative)	X		
Flowchart for Cable Gland testing	Annex G (informative)	X		
Guidance of electric machine shaft voltages	Annex H (informative)	X		

NOTE The technical changes referred to include the significance of technical changes in the revised IEC Standard, but they do not form an exhaustive list of all modifications from the previous version. More guidance may be found by referring to the Redline Version of the standard.

Explanations:

A) Definitions

Minor and editorial changes

clarification
decrease of technical requirements
minor technical change
editorial corrections

These are changes which modify requirements in an editorial or a minor technical way. They include changes of the wording to clarify technical requirements without any technical change, or a reduction in level of existing requirement.

Extension

addition of technical options

These are changes which add new or modify existing technical requirements, in a way that new options are given, but without increasing requirements for equipment that was fully compliant with the previous standard. Therefore, these will not have to be considered for products in conformity with the preceding edition.

Major technical changes

addition of technical requirements
increase of technical requirements

These are changes to technical requirements (addition, increase of the level or removal) made in a way that a product in conformity with the preceding edition will not always be able to fulfil the requirements given in the later edition. These changes have to be considered for

products in conformity with the preceding edition. For these changes additional information is provided in clause B) below.

NOTE These changes represent current technological knowledge. However, these changes should not normally have an influence on equipment already placed on the market.

B) Information about the background of changes

- A1 The dust layer requirements for EPL Da are unchanged from what previously existed in IEC 60079-18, Ed 4 and IEC 60079-31, Ed 2, but have been relocated to IEC 60079-0 to allow consistent application in all Types of Protection.
- A2 IEC 60079-28 now includes all requirements for optical radiation for all EPLs.
- A3 The COT requirements for EPL Gc or Dc are unchanged from what previously existed in IEC 60079-15, Ed 4, IEC 60079-18, Ed 4, and IEC 60079-31, Ed 2, but have been relocated to IEC 60079-0 to allow consistent application in all Types of Protection.
- A4 The dust layer requirements for EPL Db with a specified dust layer depth are unchanged from what previously existed in IEC 60079-31, Ed 2, but have been relocated to IEC 60079-0 to allow consistent application in all Types of Protection.
- B1 Dust layer requirements for EPL Db with a dust layer in a specified orientation have been added.
- C1 It is recognized that the new requirements were, in many cases, already applied. The change is to ensure that they are uniformly and consistently applied.
- C2 Require that the test be conducted at 4 kV DC.
- C3 The limitation applies to external surfaces of other than cable glands, blanking elements, thread adapters and bushings.
- C4 The added requirements for tool securing and marking are consistent with the approach in IEC 60079-15
- C5 Voltage values were changed following additional research due to the complicated assessment and sometimes unspecified construction of Li/Ion-cells. It was found that some voltage values previously stated were too low.
- C6 The now required EPL marking may be other than that permitted by the Level of Protection to account for limiting restrictions of material or plastic material surface area.
- C7 Additional instruction material for electric machines required to facilitate selection, installation, and maintenance.
- C8 Additional instruction material for cable glands required to facilitate selection and installation.

Annex ZZ (informative)

Relationship between this European Standard and the Essential Requirements of 2014/34/EU [2014 OJ L96] aimed to be covered

This European Standard has been prepared under a Commission's standardisation request M/BC/CEN/92/46 to provide one voluntary means of conforming to Essential Requirements of 2014/34/EU of the European Parliament and of the Council of 26 February 2014 on the harmonisation of the laws of the Member States relating to equipment and protective systems intended for use in potentially explosive atmospheres (recast).

Once this standard is cited in the Official Journal of the European Union under that Directive, compliance with the normative clauses of this standard given in Table ZZ.1 confers, within the limits of the scope of this standard, a presumption of conformity with the corresponding Essential Requirements of that Directive, and associated EFTA regulations.

Table ZZ.1 – Correspondence between this European Standard and Annex II of Directive 2014/34/EU [2014 OJ L96]

Essential Requirements of 2014/34/EU	Clause(s) / sub-clause(s) of this EN	Remarks / Notes
1.0.1.	Entire standard	Second indent only
1.0.2.	Entire standard including Annex ZY	By reference to appropriate EPLs
1.0.3.	3.84 and related references throughout document	In particular, use of "X" marking and related Specific Conditions of Use for Ex Equipment or Schedule of Limitations for Ex Components
1.0.4.	5 / 6.1	
1.0.5.	28.3 / 29 / Annex ZY	
1.0.6.	30	
1.1.1.	7 / 8	
1.1.2.	8.5	
1.1.3.	6.3 / 7 / 8	
1.2.1.	Entire standard	
1.2.2.	Entire standard	
1.2.3.	Not covered	
1.2.4.	5.3.2.3	
1.2.5.	Not covered	
1.2.6.	6.3	
1.2.7.	6.1	
1.2.8.	Not covered	
1.2.9.	Not covered	See EN 60079-1

Essential Requirements of 2014/34/EU	Clause(s) / sub-clause(s) of this EN	Remarks / Notes
1.3.1.	(in part) 5 / 6.6	
1.3.2.	7.4	
1.3.3.	6.4	
1.3.4.	Not covered	See EN ISO 80079-36
1.3.5.	Not covered	
1.4.1.	6.1	
1.4.2.	6.1	
1.5.	Not covered	
1.6.1.	Not covered	
1.6.2.	Not covered	
1.6.3.	Not covered	
1.6.4.	15 / Annex A	
1.6.5.	Not covered	
2.0.1.	Throughout document	Multiple requirements for Group I, EPL Ma
2.0.2.	Throughout document	Multiple requirements for Group I, EPL Mb
2.1.1.	Throughout document	Multiple requirements for Group II, EPL Ga
2.1.2.	Throughout document	Multiple requirements for Group III, EPL Da
2.2.1.	Throughout document	Multiple requirements for Group II, EPL Gb
2.2.2.	Throughout document	Multiple requirements for Group III, EPL Db
2.3.1.	Throughout document	Multiple requirements for Group II, EPL Gc
2.3.2.	Throughout document	Multiple requirements for Group III, EPL Dc
3.	Not covered	

NOTE To confer a presumption of conformity with the relevant essential requirements of Directive 2014/34/EU, this standard has to be applied together with at least one of the supplemental standards giving the requirements for a specific Type of Protection. See Clause 1.

WARNING 1: Presumption of conformity stays valid only as long as a reference to this European standard is maintained in the list published in the Official Journal of the European Union. Users of this standard should consult frequently the latest list published in the Official Journal of the European Union.

WARNING 2: Other Union legislation may be applicable to the product(s) falling within the scope of this standard.



INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Explosive atmospheres –
Part 0: Equipment – General requirements**

**Atmosphères explosives –
Partie 0: Matériel – Exigences générales**

CONTENTS

FOREWORD	8
1 Scope	15
2 Normative references	16
3 Terms and definitions	18
4 Equipment grouping	36
4.1 General	36
4.2 Group I	36
4.3 Group II	36
4.4 Group III	36
4.5 Equipment for a particular explosive gas atmosphere	37
5 Temperatures	37
5.1 Environmental influences	37
5.1.1 Ambient temperature	37
5.1.2 External source of heating or cooling	37
5.2 Service temperature	37
5.3 Maximum surface temperature	38
5.3.1 Determination of maximum surface temperature	38
5.3.2 Limitation of maximum surface temperature	38
5.3.3 Small component temperature for Group I or Group II electrical equipment	39
5.3.4 Component temperature of smooth surfaces for Group I or Group II electrical equipment	40
6 Requirements for all equipment	41
6.1 General	41
6.2 Mechanical strength of equipment	41
6.3 Opening times	41
6.4 Circulating currents in enclosures (e.g. of large electric machines)	42
6.5 Gasket retention	42
6.6 Electromagnetic and ultrasonic energy radiating equipment	42
6.6.1 General	42
6.6.2 Radio frequency sources	42
6.6.3 Ultrasonic sources	43
6.6.4 Lasers, luminaires, and other non-divergent continuous wave optical sources	44
7 Non-metallic enclosures and non-metallic parts of enclosures	44
7.1 General	44
7.1.1 Applicability	44
7.1.2 Specification of materials	44
7.2 Thermal endurance	45
7.2.1 Tests for thermal endurance	45
7.2.2 Material selection	46
7.2.3 Alternative qualification of elastomeric sealing O-rings	46
7.3 Resistance to ultraviolet light	46
7.4 Electrostatic charges on external non-metallic materials	47
7.4.1 Applicability	47
7.4.2 Avoidance of a build-up of electrostatic charge for Group I or Group II	47

7.4.3	Avoidance of a build-up of electrostatic charge for Group III	49
7.5	Attached external conductive parts	50
8	Metallic enclosures and metallic parts of enclosures	51
8.1	Material composition	51
8.2	Group I	51
8.3	Group II	51
8.4	Group III	52
8.5	Copper Alloys	52
9	Fasteners	52
9.1	General	52
9.2	Special fasteners	53
9.3	Holes for special fasteners	53
9.3.1	Thread engagement	53
9.3.2	Tolerance and clearance	53
9.4	Hexagon socket set screws	54
10	Interlocking devices	54
11	Bushings	54
12	(Reserved for future use)	54
13	Ex Components	54
13.1	General	54
13.2	Mounting	55
13.3	Internal mounting	55
13.4	External mounting	55
13.5	Ex Component certificate	55
14	Connection facilities	55
14.1	General	55
14.2	Type of protection	56
14.3	Creepage and clearance	56
15	Connection facilities for earthing or bonding conductors	56
15.1	Equipment requiring earthing or bonding	56
15.1.1	Internal earthing	56
15.1.2	External bonding	56
15.2	Equipment not requiring earthing	56
15.3	Size of protective earthing conductor connection	56
15.4	Size of equipotential bonding conductor connection	57
15.5	Protection against corrosion	57
15.6	Secureness of electrical connections	57
15.7	Internal earth continuity plate	57
16	Entries into enclosures	57
16.1	General	57
16.2	Identification of entries	57
16.3	Cable glands	58
16.4	Blanking elements	58
16.5	Thread adapters	58
16.6	Temperature at branching point and entry point	59
16.7	Electrostatic charges of cable sheaths	59
17	Supplementary requirements for electric machines	60
17.1	General	60

17.2	Ventilation.....	60
17.2.1	Ventilation openings	60
17.2.2	Materials for external fans	60
17.2.3	Cooling fans of rotating electric machines.....	60
17.2.4	Auxiliary motor cooling fans.....	61
17.2.5	Room ventilating fans	61
17.3	Bearings	62
18	Supplementary requirements for switchgear	62
18.1	Flammable dielectric	62
18.2	Disconnectors	62
18.3	Group I – Provisions for locking	63
18.4	Doors and covers.....	63
19	Reserved for future use	63
20	Supplementary requirements for external plugs, socket outlets and connectors for field wiring connection	63
20.1	General.....	63
20.2	Explosive gas atmospheres	64
20.3	Explosive dust atmospheres	64
20.4	Energized plugs	64
21	Supplementary requirements for luminaires	64
21.1	General.....	64
21.2	Covers for luminaires of EPL Mb, EPL Gb, or EPL Db	64
21.3	Covers for luminaires of EPL Gc or EPL Dc	65
21.4	Sodium lamps	65
22	Supplementary requirements for caplights and handlights	65
22.1	Group I caplights	65
22.2	Group II and Group III caplights and handlights	65
23	Equipment incorporating cells and batteries.....	66
23.1	General.....	66
23.2	Interconnection of cells to form batteries	66
23.3	Cell types.....	66
23.4	Cells in a battery.....	69
23.5	Ratings of batteries.....	69
23.6	Interchangeability	69
23.7	Charging of primary batteries	69
23.8	Leakage.....	69
23.9	Connections.....	69
23.10	Orientation.....	69
23.11	Replacement of cells or batteries	69
23.12	Replaceable battery pack.....	70
24	Documentation	70
25	Compliance of prototype or sample with documents.....	70
26	Type tests	70
26.1	General.....	70
26.2	Test configuration	70
26.3	Tests in explosive test mixtures	70
26.4	Tests of enclosures.....	71
26.4.1	Order of tests	71

26.4.2	Resistance to impact	73
26.4.3	Drop test	74
26.4.4	Acceptance criteria	75
26.4.5	Degree of protection (IP) by enclosures	75
26.5	Thermal tests	76
26.5.1	Temperature measurement	76
26.5.2	Thermal shock test	78
26.5.3	Small component ignition test (Group I and Group II)	78
26.6	Torque test for bushings	79
26.6.1	Test procedure	79
26.6.2	Acceptance criteria	80
26.7	Non-metallic enclosures or non-metallic parts of enclosures	80
26.7.1	General	80
26.7.2	Test temperatures	80
26.8	Thermal endurance to heat	80
26.9	Thermal endurance to cold	81
26.10	Resistance to UV light	81
26.10.1	General	81
26.10.2	Light exposure	82
26.10.3	Acceptance criteria	82
26.11	Resistance to chemical agents for Group I equipment	82
26.12	Earth continuity	83
26.13	Surface resistance test of parts of enclosures of non-metallic materials	84
26.14	Measurement of capacitance	85
26.14.1	General	85
26.14.2	Test procedure	85
26.15	Verification of ratings of ventilating fans	86
26.16	Alternative qualification of elastomeric sealing O-rings	86
26.17	Transferred charge test	86
26.17.1	Test equipment	86
26.17.2	Test sample	87
26.17.3	Test procedure	87
27	Routine tests	88
28	Manufacturer's responsibility	88
28.1	Conformity with the documentation	88
28.2	Certificate	89
28.3	Responsibility for marking	89
29	Marking	89
29.1	Applicability	89
29.2	Location	89
29.3	General	89
29.4	Ex marking for explosive gas atmospheres	90
29.5	Ex marking for explosive dust atmospheres	92
29.6	Combined types (or levels) of protection	95
29.7	Multiple types of protection	95
29.8	Ga equipment using two independent Gb types (or levels) of protection	95
29.9	Boundary wall	95
29.10	Ex Components	95
29.11	Small Ex Equipment and small Ex Components	96

29.12	Extremely small Ex Equipment and extremely small Ex Components	96
29.13	Warning markings	96
29.14	Cells and batteries	97
29.15	Electric machines operated with a converter	97
29.16	Examples of marking.....	98
30	Instructions.....	101
30.1	General.....	101
30.2	Cells and batteries	102
30.3	Electric machines.....	103
30.4	Ventilating fans	103
30.5	Cable glands.....	104
Annex A	(normative) Supplementary requirements for cable glands	105
A.1	General.....	105
A.2	Constructional requirements	105
A.2.1	Cable sealing.....	105
A.2.2	Filling compounds.....	106
A.2.3	Clamping	106
A.2.4	Lead-in of cable	106
A.2.5	Release by a tool.....	107
A.2.6	Fixing	107
A.2.7	Degree of protection	107
A.3	Type tests	107
A.3.1	Tests of clamping of non-armoured and braided cables	107
A.3.2	Tests of clamping of armoured cables.....	110
A.3.3	Type test for resistance to impact	111
A.3.4	Test for degree of protection (IP) of cable glands	112
A.4	Marking.....	113
A.4.1	Marking of cable glands.....	113
A.4.2	Identification of cable-sealing rings.....	113
A.5	Instructions	113
Annex B	(normative) Requirements for Ex Components	115
Annex C	(informative) Example of rig for resistance to impact test	118
Annex D	(informative) Electric machines connected to converters.....	119
Annex E	(informative) Temperature evaluation of electric machines.....	120
Annex F	(informative) Guidance flowchart for tests of non-metallic enclosures or non-metallic parts of enclosures (26.4)	123
Annex G	(informative) Guidance flowchart for tests of cable glands	124
Annex H	(informative) Shaft voltages resulting in motor bearing or shaft brush sparking Discharge energy calculation	125
H.1	General.....	125
H.2	Assessment of the risk of ignition using ignition energy calculation	125
H.3	Shaft voltage determination for a rotating machine.....	126
H.4	Capacitance “C” calculation for a rotating machine	126
H.5	Energy “E” calculation for a rotating machine	129
H.6	Assessment using reference curves	129
Bibliography	131

Figure 1	– Typical battery examples.....	20
----------	---------------------------------	----

Figure 2 – Typical battery compartment	21
Figure 3 – Typical replaceable battery pack	22
Figure 4 – Tolerances and clearance for threaded fasteners	53
Figure 5 – Contact surface under head of fastener with a reduced shank	54
Figure 6 – Cable gland	59
Figure 7 – Conduit entry	59
Figure 8 – Assembly of test sample for earth-continuity test	84
Figure 9 – Test piece with painted electrodes	85
Figure 10 – Compression set of an O-ring	86
Figure A.1 – Illustration of the terms used for cable glands	106
Figure A.2 – Rounded edge of the point of entry of the flexible cable	107
Figure A.3 – Example of rig for resistance to impact test	112
Figure C.1 – Example of rig for resistance to impact test	118
Figure F.1 – Non-metallic enclosures or non-metallic parts of enclosures	123
Figure H.1 – Capacitance stored in bearing clearance of sleeve bearing Between journal and outer bearing housing	128
Figure H.2 – Air-gap between stator and rotor	128
Figure H.3 – Typical surfaces that form capacitors from the motor shaft to ground	129
Figure H.4 – Capacitive ignition curves	130
Table 1 – Ambient temperatures in service and additional marking	37
Table 2 – Classification of maximum surface temperatures for Group II electrical equipment	38
Table 3 – Assessment of temperature classification according to component size	40
Table 4 – Assessment of temperature classification Component surface area $\geq 20 \text{ mm}^2$	40
Table 5 – Threshold power	43
Table 6 – Threshold energy	43
Table 7 – Limitation of surface areas	48
Table 8 – Maximum diameter or width	49
Table 9 – Limitation of thickness of non-metallic layer	49
Table 10 – Maximum acceptable transferred charge	49
Table 11 – Maximum capacitance of unearthed conductive parts	51
Table 12 – Minimum cross-sectional area of PE conductors	57
Table 13 – Primary cells	66
Table 14 – Secondary cells	68
Table 15 – Tests for resistance to impact	74
Table 16 – Torque to be applied to the stem of bushing used for connection facilities	79
Table 17 – Thermal endurance test	80
Table 18 – Text of warning markings	97
Table 19 – Example of type-test converter parameters	103
Table B.1 – Applicability of clauses to Ex Components	115
Table H.1 – Maximum permitted energy	126