



Institut luxembourgeois de la normalisation
de l'accréditation, de la sécurité et qualité
des produits et services

ILNAS-EN 12845:2004+A2:2009

Fixed firefighting systems - Automatic sprinkler systems - Design, installation and maintenance

Installations fixes de lutte contre
l'incendie - Systèmes d'extinction
automatique du type sprinkleur -
Conception, installation et maintenance

Ortsfeste Brandbekämpfungsanlagen -
Automatische Sprinkleranlagen -
Planung, Installation und Instandhaltung

04/2009



National Foreword

This European Standard EN 12845:2004+A2:2009 was adopted as Luxembourgish Standard ILNAS-EN 12845:2004+A2:2009.

Every interested party, which is member of an organization based in Luxembourg, can participate for FREE in the development of Luxembourgish (ILNAS), European (CEN, CENELEC) and International (ISO, IEC) standards:

- Participate in the design of standards
- Foresee future developments
- Participate in technical committee meetings

<https://portail-qualite.public.lu/fr/normes-normalisation/participer-normalisation.html>

THIS PUBLICATION IS COPYRIGHT PROTECTED

Nothing from this publication may be reproduced or utilized in any form or by any mean - electronic, mechanical, photocopying or any other data carries without prior permission!

ILNAS-EN 12845:2004+A2:2009

EUROPEAN STANDARD **EN 12845:2004+A2**

NORME EUROPÉENNE

EUROPÄISCHE NORM

April 2009

ICS 13.220.20

Supersedes EN 12845:2004

English Version

**Fixed firefighting systems - Automatic sprinkler systems -
Design, installation and maintenance**

Installations fixes de lutte contre l'incendie - Systèmes
d'extinction automatique du type sprinkleur - Conception,
installation et maintenance

Ortsfeste Brandbekämpfungsanlagen - Automatische
Sprinkleranlagen - Planung, Installation und Instandhaltung

This European Standard was approved by CEN on 16 April 2004 and includes Amendment 1 approved by CEN on 22 February 2009 and Amendment 2 approved by CEN on 22 February 2009.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents

	page
Foreword	9
Introduction	10
1 Scope	12
2 Normative references	12
3 Terms and definitions.....	13
4 Contract planning and documentation	20
4.1 General.....	20
4.2 Initial considerations	21
4.3 Preliminary or estimating stage	21
4.4 Design stage.....	21
4.4.1 General.....	21
4.4.2 Summary schedule	22
4.4.3 Installation layout drawings.....	22
4.4.4 Water supply.....	25
5 Extent of sprinkler protection.....	27
5.1 Buildings and areas to be protected.....	27
5.1.1 Permitted exceptions within a building	27
5.1.2 Necessary exceptions	28
5.2 Storage in the open air	28
5.3 Fire resistant separation	28
5.4 Protection of concealed spaces	28
5.5 Height difference between the highest and lowest sprinklers.....	28
6 Classification of occupancies and fire hazards.....	29
6.1 General.....	29
6.2 Hazard classes	29
6.2.1 Light Hazard - LH	29
6.2.2 Ordinary Hazard - OH	29
6.2.3 High Hazard - HH.....	30
6.3 Storage.....	31
6.3.1 General.....	31
6.3.2 Storage Configuration	32
7 Hydraulic design criteria	34
7.1 LH, OH and HHP	34
7.2 High Hazard Storage - HHS.....	35
7.2.1 General.....	35
7.2.2 Ceiling or roof protection only	35
7.2.3 Intermediate level in-rack sprinklers	36
7.3 Pressure and flow requirements for pre-calculated systems	38
7.3.1 LH and OH systems	38
7.3.2 HHP and HHS systems without in-rack sprinklers	39
8 Water supplies.....	42
8.1 General.....	42
8.1.1 Duration	42

8.1.2	Continuity	42
8.1.3	Frost protection	42
8.2	Maximum water pressure	42
8.3	Connections for other services	43
8.4	Housing of equipment for water supplies	44
8.5	Test facility devices	44
8.5.1	At control valve sets	44
8.5.2	At water supplies	45
8.6	Water Supply test	45
8.6.1	General	45
8.6.2	Storage tank and pressure tank supplies	45
8.6.3	Town main, booster pump, elevated private reservoir and gravity tank supplies	45
9	Type of water supply	45
9.1	General	45
9.2	Town mains	46
9.2.1	General	46
9.2.2	Boosted mains	46
9.3	Storage tanks	46
9.3.1	General	46
9.3.2	Water volume	46
9.3.3	Refill rates for full capacity tanks	48
9.3.4	Reduced capacity tanks	48
9.3.5	Effective capacity of tanks and dimensions of suction chambers	49
9.3.6	Strainers	51
9.4	Inexhaustible sources - Settling and suction chambers	51
9.5	Pressure tanks	54
9.5.1	General	54
9.5.2	Housing	54
9.5.3	Minimum capacity (water)	54
9.5.4	Air pressure and contents	54
9.5.5	Charging with air and water	55
9.5.6	Control and safety equipment	55
9.6	Choice of water supply	56
9.6.1	Single water supplies	56
9.6.2	Ⓐ Superior single water supplies Ⓐ	56
9.6.3	Duplicate water supplies	57
9.6.4	Combined water supplies	57
9.7	Isolation of water supply	57
10	Pumps	58
10.1	General	58
10.2	Multiple pump arrangements	58
10.3	Compartments for pumpsets	58
10.3.1	General	58
10.3.2	Sprinkler protection	59
10.3.3	Temperature	59
10.3.4	Ventilation	59
10.4	Maximum temperature of water supply	59
10.5	Valves and accessories	59
10.6	Suction conditions	60
10.6.1	General	60
10.6.2	Suction pipe	60
10.7	Performance characteristics	64
10.7.1	Pre-calculated systems - LH and OH	64
10.7.2	Pre-calculated systems - HHP and HHS with no in-rack sprinklers	65
10.7.3	Calculated systems	65
10.7.4	Pressure and water capacity of boosted town mains	65

EN 12845:2004+A2:2009 (E)

10.7.5	Pressure switches	66
10.8	Electrically driven pumpsets	66
10.8.1	General.....	66
10.8.2	Electricity supply	66
10.8.3	Main switchboard.....	66
10.8.4	Installation between the main switchboard and the pump controller.....	67
10.8.5	Pump controller.....	67
10.8.6	Monitoring of pump operation.....	67
10.9	Diesel engine driven pumpsets	68
10.9.1	General.....	68
10.9.2	Engines	68
10.9.3	Cooling system	68
10.9.4	Air filtration.....	68
10.9.5	Exhaust system.....	68
10.9.6	Fuel, fuel tank and fuel feed pipes	69
10.9.7	Starting mechanism.....	69
10.9.8	Electric starter motor batteries.....	70
10.9.9	Battery chargers.....	71
10.9.10	Siting of batteries and chargers.....	71
10.9.11	Starter alarm indication	71
10.9.12	Tools and spare parts	71
10.9.13	Engine tests and exercising	72
11	Installation type and size	72
11.1	Wet pipe installations	72
11.1.1	General.....	72
11.1.2	Protection against freezing.....	72
11.1.3	Size of installations	73
11.2	Dry pipe installations.....	73
11.2.1	General.....	73
11.2.2	Size of installations	74
11.3	Alternate installations	74
11.3.1	General.....	74
11.3.2	Size of installations	74
11.4	Pre-action installations	74
11.4.1	General.....	74
11.4.2	Automatic detection system.....	75
11.4.3	Size of installations	75
11.5	Subsidiary dry pipe or alternate extension	75
11.5.1	General.....	75
11.5.2	Size of subsidiary extensions.....	76
11.6	Subsidiary water spray extension.....	76
12	Spacing and location of sprinklers	76
12.1	General.....	76
12.2	Maximum area of coverage per sprinkler.....	77
12.3	Minimum distance between sprinklers.....	78
12.4	Location of sprinklers in relation to building construction.....	78
12.5	Intermediate sprinklers in HH occupancies	85
12.5.1	General.....	85
12.5.2	Maximum vertical distance between sprinklers at intermediate levels.....	85
12.5.3	Horizontal position of sprinklers at intermediate levels.....	85
12.5.4	Numbers of rows of sprinklers at each level	87
12.5.5	HHS intermediate sprinklers in non-shelved racks.....	88
12.5.6	HHS intermediate sprinklers below solid or slatted shelves in racks (ST5 and ST6).....	88
13	Pipe sizing and layout	90
13.1	General.....	90
13.1.1	Pipe sizing	90

13.2 Calculation of pressure losses in pipework	90
13.2.1 Pipe friction loss	90
13.2.2 Static pressure difference	91
13.2.3 Velocity	91
13.2.4 Pressure loss through fittings and valves	91
13.2.5 Accuracy of calculations	93
13.3 Pre-calculated systems	93
13.3.1 General	93
13.3.2 Location of Design Points	93
13.3.3 Light Hazard - LH	94
13.3.4 Ordinary Hazard - OH	96
13.3.5 High hazard - HHP and HHS (except intermediate level sprinklers)	98
13.4.1 Design density	107
13.4.2 Locations of the area of operation	108
13.4.3 Shape of the area of operation	108
13.4.4 Minimum sprinkler discharge pressure	112
13.4.5 Minimum pipe diameters	112
14 Sprinkler design characteristics and uses	113
14.1 General	113
14.2 Sprinkler types and application	113
14.2.1 General	113
14.2.2 Ceiling, flush, recessed and concealed pattern	114
14.2.3 Sidewall pattern	114
14.2.4 Flat spray pattern	115
14.3 Flow from sprinklers	115
14.4 Sprinkler temperature ratings	115
14.5 Sprinkler thermal sensitivity	115
14.5.1 General	115
14.5.2 Interaction with other measures	116
14.6 Sprinkler guards	116
14.7 Sprinkler water shields	116
14.8 Sprinkler rosettes	117
14.9 Corrosion protection of sprinklers	117
15 Valves	117
15.1 Control valve set	117
15.2 Stop valves	117
15.3 Ring main valves	117
15.4 Drain valves	117
15.5 Test valves	118
15.5.1 Alarm and pump start test valves	118
15.5.2 Remote test valves	119
15.6 Flushing connections	119
15.7 Pressure gauges	119
15.7.1 General	119
15.7.2 Water supply connections	119
15.7.3 Control valve set	120
15.7.4 Removal	120
16 Alarms and alarm devices	120
16.1 Water flow alarms	120
16.1.1 General	120
16.1.2 Water motor and gong	120
16.1.3 Piping to water motor	120
16.2 Electrical water flow and pressure switches	121
16.2.1 General	121
16.2.2 Water flow alarm switches	121
16.2.3 Dry and pre-action systems	121

EN 12845:2004+A2:2009 (E)

16.3	Fire brigade and remote central station alarm connection	121
17	Pipework	121
17.1	General	121
17.1.1	Underground piping	121
17.1.2	Above ground piping	122
17.1.3	Welding of steel pipe	122
17.1.4	Flexible pipes and joints	122
17.1.5	Concealment	122
17.1.6	Protection against fire and mechanical damage	123
17.1.7	Painting	123
17.1.8	Drainage	123
17.1.9	Copper pipe	123
17.2	Pipe supports	124
17.2.1	General	124
17.2.2	Spacing and location	124
17.2.3	Design	125
17.3	Pipework in concealed spaces	125
17.3.1	False ceilings above OH occupancies	125
17.3.2	All other cases	126
18	Signs, notices, and information	126
18.1	Block plan	126
18.1.1	General	126
18.2	Signs and notices	126
18.2.1	Location plate	126
18.2.2	Signs for stop valves	126
18.2.3	Control valve set	127
18.2.4	Water supply connections to other services	127
18.2.5	Suction and booster pumps	127
18.2.6	Electric switches and control panels	128
18.2.7	Testing and operating devices	128
19	 Commissioning 	129
19.1	Commissioning tests	129
19.1.1	Pipework	129
19.1.2	Equipment	129
19.1.3	Water supplies	129
19.2	Completion certificate and documents	129
20	Maintenance	130
20.1	General	130
20.1.1	Programmed work	130
20.1.2	Precautions while carrying out work	130
20.1.3	Replacement sprinklers	130
20.2	User's programme of inspection and checking	130
20.2.1	General	130
20.2.2	Weekly routine	131
20.2.3	Monthly routine	132
20.3	Service and maintenance schedule	132
20.3.1	General	132
20.3.2	Quarterly routine	132
20.3.3	Half-yearly routine	133
20.3.4	Yearly routine	134
20.3.5	Yearly routine	134
20.3.6	10 yearly routine	134
Annex A	(normative)  Classification of typical hazards	136
Annex B	(normative) Methodology for categorizing stored goods	140

B.1	General	140
B.2	Material factor (M)	140
B.2.1	General	140
B.2.2	Material Factor 1	140
B.2.3	Material factor 2	141
B.2.4	Material factor 3	142
B.2.5	Material factor 4	142
B.3	Storage configuration	142
B.3.1	Effect of storage configuration	142
B.3.2	Exposed plastic container with non-combustible content	143
B.3.3	Exposed plastic surface - unexpanded	143
B.3.4	Exposed plastic surface - expanded	143
B.3.5	Open structure	143
B.3.6	Solid block materials	144
B.3.7	Granular or Powdered materials	144
B.3.8	No special configuration	144
Annex C	(normative) Alphabetical listing of stored products and categories	145
Annex D	(normative) Zoning of sprinkler installations	151
D.1	General	151
D.2	Zoning of installations	151
D.3	Requirements for zoned installations	151
D.3.1	Extent of zones	151
D.3.2	Zone subsidiary stop valves	151
D.3.3	Flushing Valves	152
D.3.4	Monitoring	152
D.3.5	Zone test and drainage facilities	152
D.3.6	Installation control valve set	152
D.3.7	Installation monitoring and alarms	152
D.4	Block plan	153
Annex E	(normative) Special requirements for high rise systems	155
E.1	General	155
E.2	Design criteria	155
E.2.1	Hazard group	155
E.2.2	Subdivision of high rise sprinkler systems	155
E.2.3	Standing water pressures at non-return and alarm valves	155
E.2.4	Calculation of distribution pipework for pre-calculated systems	155
E.2.5	Water pressures	156
E.3	Water supplies	156
E.3.1	Types of water supplies	156
E.3.2	Pressure and flow requirements for pre-calculated installations	156
E.3.3	Water supply characteristics for pre-calculated installations	156
E.3.4	Pump performance for pre-calculated installations	156
Annex F	(normative) Special requirements for life safety systems	159
F.1	Subdivision into zones	159
F.2	A_2 Wet pipe installations A_2	159
F.3	Sprinkler type and sensitivity	159
F.4	Control Valve valve set	159
F.5	Water supplies	159
F.6	Theatres	159
F.7	Additional precautions for maintenance	160
Annex G	(normative) Protection of A_2 deleted text A_2 special hazards	161
G.1	General	161
G.2	Aerosols	161
G.3	Clothes in multiple garment hanging storage	162