

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Power cables with extruded insulation and their accessories for rated voltages from 1 kV ($U_m = 1,2$ kV) up to 30 kV ($U_m = 36$ kV) –
Part 1: Cables for rated voltages of 1 kV ($U_m = 1,2$ kV) and 3 kV ($U_m = 3,6$ kV)**

**Câbles d'énergie à isolant extrudé et leurs accessoires pour des tensions assignées de 1 kV ($U_m = 1,2$ kV) à 30 kV ($U_m = 36$ kV) –
Partie 1: Câbles de tensions assignées de 1 kV ($U_m = 1,2$ kV) et 3 kV ($U_m = 3,6$ kV)**



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2004 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland
Email: inmail@iec.ch
Web: www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: www.iec.ch/searchpub

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: www.iec.ch/online_news/justpub

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

- Electropedia: www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

- Customer Service Centre: www.iec.ch/webstore/custserv

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: csc@iec.ch

Tel.: +41 22 919 02 11

Fax: +41 22 919 03 00

A propos de la CEI

La Commission Electrotechnique Internationale (CEI) est la première organisation mondiale qui élabore et publie des normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

- Catalogue des publications de la CEI: www.iec.ch/searchpub/cur_fut-f.htm

Le Catalogue en-ligne de la CEI vous permet d'effectuer des recherches en utilisant différents critères (numéro de référence, texte, comité d'études,...). Il donne aussi des informations sur les projets et les publications retirées ou remplacées.

- Just Published CEI: www.iec.ch/online_news/justpub

Restez informé sur les nouvelles publications de la CEI. Just Published détaille deux fois par mois les nouvelles publications parues. Disponible en-ligne et aussi par email.

- Electropedia: www.electropedia.org

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International en ligne.

- Service Clients: www.iec.ch/webstore/custserv/custserv_entry-f.htm

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions, visitez le FAQ du Service clients ou contactez-nous:

Email: csc@iec.ch

Tél.: +41 22 919 02 11

Fax: +41 22 919 03 00

INTERNATIONAL STANDARD

NORME INTERNATIONALE

Power cables with extruded insulation and their accessories for rated voltages from 1 kV ($U_m = 1,2$ kV) up to 30 kV ($U_m = 36$ kV) –

Part 1: Cables for rated voltages of 1 kV ($U_m = 1,2$ kV) and 3 kV ($U_m = 3,6$ kV)

Câbles d'énergie à isolant extrudé et leurs accessoires pour des tensions assignées de 1 kV ($U_m = 1,2$ kV) à 30 kV ($U_m = 36$ kV) –

Partie 1: Câbles de tensions assignées de 1 kV ($U_m = 1,2$ kV) et 3 kV ($U_m = 3,6$ kV)

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

CONTENTS

FOREWORD.....	6
1 Scope.....	8
2 Normative references.....	8
3 Terms and definitions	10
3.1 Definitions of dimensional values (thicknesses, cross-sections, etc.).....	10
3.2 Definitions concerning the tests	10
4 Voltage designations and materials	11
4.1 Rated voltages	11
4.2 Insulating compounds	12
4.3 Sheathing compounds	13
5 Conductors	13
6 Insulation.....	13
6.1 Material	13
6.2 Insulation thickness	13
7 Assembly of multicore cables, inner coverings and fillers.....	15
7.1 Inner coverings and fillers.....	15
7.2 Cables with rated voltage 0,6/1 (1,2) kV	16
7.3 Cables with rated voltage 1,8/3 (3,6) kV.....	17
8 Metallic layers for single-core and multicore cables.....	17
9 Metallic screen	18
9.1 Construction.....	18
9.2 Requirements	18
10 Concentric conductor.....	18
10.1 Construction.....	18
10.2 Requirements	18
10.3 Application.....	18
11 Lead sheath.....	18
12 Metallic armour.....	19
12.1 Types of metallic armour.....	19
12.2 Materials	19
12.3 Application of armour.....	20
12.4 Dimensions of the armour wires and armour tapes	21
12.5 Correlation between cable diameters and armour dimensions	21
12.6 Round or flat wire armour	22
12.7 Double tape armour	22
13 Oversheath.....	22
13.1 General	22
13.2 Material	22
13.3 Thickness.....	23
14 Test conditions	23
14.1 Ambient temperature	23
14.2 Frequency and waveform of power frequency test voltages	23
14.3 Waveform of impulse test voltages	23

15	Routine tests	23
15.1	General	23
15.2	Electrical resistance of conductors	24
15.3	Voltage test	24
16	Sample tests	25
16.1	General	25
16.2	Frequency of sample tests	25
16.3	Repetition of tests	26
16.4	Conductor examination	26
16.5	Measurement of thickness of insulation and of non-metallic sheaths (including extruded separation sheaths, but excluding inner extruded coverings)	26
16.6	Measurement of thickness of lead sheath	27
16.7	Measurement of armour wires and tapes	27
16.8	Measurement of external diameter	28
16.9	Hot set test for EPR, HEPR and XLPE insulations and elastomeric sheaths	28
17	Type tests, electrical	28
17.1	Insulation resistance measurement at ambient temperature	29
17.2	Insulation resistance measurement at maximum conductor temperature	29
17.3	Voltage test for 4 h	30
17.4	Impulse test for cables of rated voltage 1,8/3 (3,6) kV	30
18	Type tests, non-electrical	30
18.1	Measurement of thickness of insulation	31
18.2	Measurement of thickness of non-metallic sheaths (including extruded separation sheaths, but excluding inner coverings)	31
18.3	Tests for determining the mechanical properties of insulation before and after ageing	31
18.4	Tests for determining the mechanical properties of non-metallic sheaths before and after ageing	32
18.5	Additional ageing test on pieces of completed cables	32
18.6	Loss of mass test on PVC sheaths of type ST ₂	33
18.7	Pressure test at high temperature on insulations and non-metallic sheaths	33
18.8	Test on PVC insulation and sheaths and halogen free sheaths at low temperatures	33
18.9	Test for resistance of PVC insulation and sheaths to cracking (heat shock test)	33
18.10	Ozone resistance test for EPR and HEPR insulations	34
18.11	Hot set test for EPR, HEPR and XLPE insulations and elastomeric sheaths	34
18.12	Oil immersion test for elastomeric sheaths	34
18.13	Water absorption test on insulation	34
18.14	Fire tests	34
18.15	Measurement of carbon black content of black PE oversheaths	35
18.16	Shrinkage test for XLPE insulation	36
18.17	Special bending test	36
18.18	Determination of hardness of HEPR insulation	36
18.19	Determination of the elastic modulus of HEPR insulation	36

18.20 Shrinkage test for PE oversheaths	37
18.21 Additional mechanical tests on halogen free oversheaths	37
18.22 Water absorption test for halogen free oversheaths	37
19 Electrical tests after installation	37
Annex A (normative) Fictitious calculation method for determination of dimensions of protective coverings	48
A.1 General	48
A.2 Method	48
Annex B (normative) Rounding of numbers	54
B.1 Rounding of numbers for the purpose of the fictitious calculation method	54
B.2 Rounding of numbers for other purposes	54
Annex C (normative) Determination of hardness of HEPR insulations	56
C.1 Test piece	56
C.2 Test procedure	56
Figure C.1 – Test on surfaces of large radius of curvature	57
Figure C.2 – Test on surfaces of small radius of curvature	58
Table 1 – Recommended rated voltages U_0	11
Table 2 – Insulating compounds	12
Table 3 – Maximum conductor temperatures for different types of insulating compound	12
Table 4 – Maximum conductor temperatures for different types of sheathing compound	13
Table 5 – Nominal thickness of PVC/A insulation	14
Table 6 – Nominal thickness of cross-linked polyethylene (XLPE) insulation	14
Table 7 – Nominal thickness of ethylene propylene rubber (EPR) and hard ethylene propylene rubber (HEPR) insulation	15
Table 8 – Thickness of extruded inner covering	16
Table 9 – Nominal diameter of round armour wires	21
Table 10 – Nominal thickness of armour tapes	21
Table 11 – Routine test voltages	25
Table 12 – Number of samples for sample tests	26
Table 13 – Electrical type test requirements for insulating compounds	38
Table 14 – Non-electrical type tests (see Tables 15 to 23)	39
Table 15 – Test requirements for mechanical characteristics of insulating compounds (before and after ageing)	40
Table 16 – Test requirements for particular characteristics for PVC insulating compound	41
Table 17 – Test requirements for particular characteristics of various thermosetting insulating compounds	42
Table 18 – Test requirements for mechanical characteristics of sheathing compounds (before and after ageing)	43

Table 19 – Test requirements for particular characteristics for PVC sheathing compounds	44
Table 20 – Test requirements for particular characteristics of thermoplastic PE sheathing compounds	45
Table 21 – Test requirements for particular characteristics of halogen free sheathing compound	46
Table 22 – Test requirements for particular characteristics of elastomeric sheathing compound	47
Table 23 – Test methods and requirements for halogen free compounds	47
Table A.1 – Fictitious diameter of conductor	49
Table A.2 – Assembly coefficient k for laid-up cores	50
Table A.3 – Increase of diameter for concentric conductors and metallic screens	51
Table A.4 – Increase of diameter for additional bedding	53

INTERNATIONAL ELECTROTECHNICAL COMMISSION

POWER CABLES WITH EXTRUDED INSULATION AND THEIR ACCESSORIES FOR RATED VOLTAGES FROM 1 kV ($U_m = 1,2$ kV) UP TO 30 kV ($U_m = 36$ kV) –

Part 1: Cables for rated voltages of 1 kV ($U_m = 1,2$ kV) and 3 kV ($U_m = 3,6$ kV)

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60502-1 has been prepared by IEC technical committee 20: Electric cables.

This second edition cancels and replaces the first edition, published in 1997, its amendment 1 (1998) and constitutes a technical revision.

The main changes with respect to the first edition relate to insulation and oversheath thickness requirements, and inclusion of constructions and requirements for halogen free cables with reduced flame propagation and low levels of smoke emission.

The text of this standard is based on the following documents:

FDIS	Report on voting
20/683/FDIS	20/691/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

IEC 60502 consists of the following parts, under the general title *Power cables with extruded insulation and their accessories for rated voltages from 1 kV ($U_m = 1,2$ kV) up to 30 kV ($U_m = 36$ kV)*:

- Part 1: Cables for rated voltages of 1 kV ($U_m = 1,2$ kV) and 3 kV ($U_m = 3,6$ kV);
- Part 2: Cables for rated voltages from 6 kV ($U_m = 7,2$ kV) up to 30 kV ($U_m = 36$ kV);
- Part 3: Reserved;
- Part 4: Test requirements on accessories for cables with rated voltages from 6 kV ($U_m = 7,2$ kV) up to 30 kV ($U_m = 36$ kV).

The committee has decided that the contents of this publication will remain unchanged until 2009. At this date, the publication will be

- reconfirmed;
- withdrawn;
- replaced by a revised edition, or
- amended.