

June 2022

ICS 13.220.50; 91.060.50

English Version

Extended application of test results on durability of self-closing for fire resistance and/or smoke control doorsets and openable windows - Part 2: Durability of self-closing of steel rolling shutters

Application étendue des résultats d'essais de durabilité de la fermeture automatique des blocs-portes et fenêtres ouvrantes résistants au feu et/ou étanches à la fumée - Partie 2 : Durabilité de la fermeture automatique des rideaux à enroulement en acier

Erweiterter Anwendungsbereich von Prüfergebnissen zur Dauerhaftigkeit der Selbstschließung für Feuerschutz- und/oder Rauchschutztüren und zu öffnende Fenster - Teil 2: Dauerhaftigkeit der Selbstschließung von Rolltoren aus Stahl

This draft European Standard is submitted to CEN members for formal vote. It has been drawn up by the Technical Committee CEN/TC 127.

If this draft becomes a European Standard, CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

This draft European Standard was established by CEN in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.

Recipients of this draft are invited to submit, with their comments, notification of any relevant patent rights of which they are aware and to provide supporting documentation.

Warning : This document is not a European Standard. It is distributed for review and comments. It is subject to change without notice and shall not be referred to as a European Standard.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents	Page
European foreword.....	3
Introduction	4
1 Scope	5
2 Normative references.....	5
3 Terms and definitions	6
4 Determination of the field of extended application	6
4.1 General.....	6
4.2 Procedure for evaluation	6
4.3 Procedure for maximum field of extended application	7
4.4 Interpretation of test results	7
5 Extended application report.....	8
6 Classification report.....	8
Annex A (normative) Construction parameter variations	9
Annex B (normative) Metal rolling shutter assemblies stress calculation method	41
B.1 Calculation principles.....	41
B.2 Calculation of limiting stress and simulation of the maximum curtain weight.....	41
B.2.1 Calculation of the limiting stress for the varied parameter	41
B.2.2 Simulation of the maximum required curtain weight.....	41
B.3 Barrel calculations.....	41
B.4 Barrel support bracket calculations	43
B.5 Shaft / axle calculations.....	43
B.6 Endplate calculations.....	44
Annex C (informative) Figures related to Annex A and Annex B	48

European foreword

This document (FprEN 17020-2:2022) has been prepared by Technical Committee CEN/TC 127 “Fire safety in buildings”, the secretariat of which is held by BSI.

This document is currently submitted to the Formal Vote.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association.

A list of all parts in the EN 17020 series can be found on the CEN website.

Introduction

The EN 15269 series of standards covering extended application of test results for fire resistance and/or smoke control for doorsets, rolling shutter assemblies and openable windows, including their items of building hardware, does not yet include their durability of self-closing following an extended application process. This document is one of the EN 17020 series of standards intended to be used for the purpose of producing an extended application report based on the evaluation of one or more durability self-closing tests. These European Standards may also be used to identify the best selection of test specimens required to cover a wide range of product variations.

1 Scope

This document covers metal (e.g. steel, stainless steel, aluminium) rolling shutter assemblies also covered by EN 15269-10 and EN 15269-20.

This document prescribes the methodology for extending the application of test results obtained from durability of self-closing test(s), see EN 12605:2000.

Subject to the completion of the appropriate durability of self-closing test or tests, the extended application could cover all or some of the following non-exhaustive list:

- shutter curtain;
- wall or ceiling fixed elements (frame or suspension system);
- items of building hardware;
- decorative finishes;
- intumescent or non-intumescent (e.g. smoke, draught) seals;
- alternative supporting construction(s).

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 1363-1, *Fire resistance tests - Part 1: General requirements*

EN 1363-2, *Fire resistance tests - Part 2: Alternative and additional procedures*

EN 1634-1, *Fire resistance and smoke control tests for door and shutter assemblies, openable windows and elements of building hardware - Part 1: Fire resistance test for door and shutter assemblies and openable windows*

EN 1634-3, *Fire resistance and smoke control tests for door and shutter assemblies, openable windows and elements of building hardware - Part 3: Smoke control test for door and shutter assemblies*

EN 12433-1, *Industrial, commercial and garage doors and gates - Terminology - Part 1: Types of doors*

EN 12433-2, *Industrial, commercial and garage doors and gates - Terminology - Part 2: Parts of doors*

EN 12605:2000, *Industrial, commercial and garage doors and gates - Mechanical aspects - Test methods*

EN 13501-2, *Fire classification of construction products and building elements - Part 2: Classification using data from fire resistance tests, excluding ventilation services*

EN 15269-1, *Extended application of test results for fire resistance and/or smoke control for door, shutter and openable window assemblies, including their elements of building hardware - Part 1: General requirements*

EN 15269-10, *Extended application of test results for fire resistance and/or smoke control for door, shutter and openable window assemblies including their elements of building hardware - Part 10: Fire resistance of steel rolling shutter assemblies*

EN 15269-20, *Extended application of test results for fire resistance and/or smoke control for door, shutter and openable window assemblies, including their elements of building hardware - Part 20: Smoke control for doors, shutters, operable fabric curtains and openable windows*

EN 16034, *Pedestrian doorsets, industrial, commercial, garage doors and openable windows - Product standard, performance characteristics - Fire resisting and/or smoke control characteristics*

EN ISO 13943, *Fire safety - Vocabulary (ISO 13943:2017)*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in EN 1363-1, EN 1363-2, EN 1634-1, EN 1634-3, EN 15269-1, EN 15269-10, EN 15269-20, EN 12433-1, EN 12433-2 and EN ISO 13943 and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp/ui>
- IEC Electropedia: available at <https://www.electropedia.org/>

3.1 full scale test

test of a full size rolling shutter assembly

Note 1 to entry: This test is in accordance with EN 12605:2000.

4 Determination of the field of extended application

4.1 General

4.1.1 Before there can be any consideration for extended application, the metal rolling shutter assembly shall have been tested in accordance with EN 12605:2000 to achieve a test result which could generate a classification for the durability of self-closing in accordance with EN 13501-2 for the required number of test cycles.

4.1.2 A review of the construction parameters can indicate that one or more characteristics may be improved by a particular parameter variation. All evaluations shall be made on the basis of retaining the classifications for the durability of self-closing obtainable from testing to EN 12605:2000, including those with a lower number of opening and closing cycles. However, this shall never lead to an increased classification for any specific parameter beyond that achieved during any one test unless specifically identified in the relevant Construction Parameter Variation tables.

4.1.3 If, when following the extended application procedure, any part of the classified product cannot be achieved by extended application rules, that part shall be omitted from the subsequent extended application report and classification report.

4.2 Procedure for evaluation

4.2.1 Identify the variations from the original test specimen(s) which are required to be covered by an extended application report. Ensure that the variation(s) do(es) not prevent the rolling shutter from self-closing.

4.2.2 Locate the variations in the appropriate parameter variation by reference to columns (1) and (2) of Table A.1.

4.2.3 Establish from the contents of column (3) of Table A.1 whether any extended application is available without the need for further testing.

4.2.4 Where this is deemed to be possible this can be recorded in the extended application report together with any appropriate restrictions and the stated rules from column (3) in Table A.1.

4.2.5 Where the variations required can only be achieved from additional testing according to column (4) of Table A.1, the additional test can be made on a similar test specimen type to the original test against which the extended application is sought. Alternatively, column (4) identifies an option for alternative testing and relevant test parameters.

4.3 Procedure for maximum field of extended application

4.3.1 It is possible to provide a limited field of extended application from the results of a single test. However, where a manufacturer intends to produce a range of rolling shutter assemblies incorporating manual and power operated drives, insulated and uninsulated version, with alternative elements of construction etc. it is recommended that careful consideration is given to the complete range of designs and options in order to minimize the testing required before testing commences.

4.3.2 Establish all the parameter variations which are required to be part of the product range.

4.3.3 Determine which are the most important specification requirements and incorporate as many as possible into the test specimen(s) for the first tests in the series.

4.3.4 Conduct the first durability of self-closing test or a series of tests and then establish which of the original desired parameter variations have not been covered by this test(s).

4.3.5 Identify these parameter variations in Table A.1 and establish if any extended application is possible without further testing.

4.3.6 Record this for the extended application report together with any restrictions and rules given in column (3) in Table A.1.

4.3.7 Evaluate which, if any, of the desired parameter variations have not been covered by the initial field of extended application derived from 4.3.6 above.

4.3.8 Select the required outstanding parameter variations from column (1) and column (2) of Table A.1 and observe from column (4) of Table A.1 which are the most appropriate weakest test specimen options for further testing.

4.3.9 If the complete selection of required parameter variations has not been covered by the tests completed in accordance with 4.3.8 above, then an appropriate test or tests may be repeated with the additional product variations incorporated.

4.4 Interpretation of test results

4.4.1 In order to maximize the field of extended application, it is important that the test reports shall record details of any failures which occurred throughout the test duration.

4.4.2 Where a series of tests have been conducted, the field of extended application shall be based on the lowest performance achieved from the complete series of tests unless premature failure has been attributed to one or more specific construction parameter variation(s).