



Institut luxembourgeois de la normalisation
de l'accréditation, de la sécurité et qualité
des produits et services

ILNAS-EN 14470-1:2023

**Fire safety storage cabinets - Part 1:
Safety storage cabinets for flammable
liquids**

Feuerwiderstandsfähige Lagerschränke -
Teil 1: Sicherheitsschränke für brennbare
Flüssigkeiten

Armoires de stockage de sécurité
incendie - Partie 1 : Armoires de stockage
de sécurité pour liquides inflammables

07/2023



National Foreword

This European Standard EN 14470-1:2023 was adopted as Luxembourgish Standard ILNAS-EN 14470-1:2023.

Every interested party, which is member of an organization based in Luxembourg, can participate for FREE in the development of Luxembourgish (ILNAS), European (CEN, CENELEC) and International (ISO, IEC) standards:

- Participate in the design of standards
- Foresee future developments
- Participate in technical committee meetings

<https://portail-qualite.public.lu/fr/normes-normalisation/participer-normalisation.html>

THIS PUBLICATION IS COPYRIGHT PROTECTED

Nothing from this publication may be reproduced or utilized in any form or by any mean - electronic, mechanical, photocopying or any other data carries without prior permission!

ILNAS-EN 14470-1:2023

EUROPEAN STANDARD **EN 14470-1**

NORME EUROPÉENNE

EUROPÄISCHE NORM

July 2023

ICS 13.220.40; 71.040.10

Supersedes EN 14470-1:2004

English Version

**Fire safety storage cabinets - Part 1: Safety storage
cabinets for flammable liquids**

Armoires de stockage de sécurité incendie - Partie 1 :
Armoires de stockage de sécurité pour liquides
inflammables

Feuerwiderstandsfähige Lagerschränke - Teil 1:
Sicherheitsschränke für brennbare Flüssigkeiten

This European Standard was approved by CEN on 14 May 2023.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents

Page

European foreword	4
Introduction	5
1 Scope.....	6
2 Normative references.....	6
3 Terms and definitions	7
4 Classification.....	8
5 Construction	8
5.1 Fire protection	8
5.2 Access opening.....	8
5.3 Construction materials and surface areas	9
5.4 Weight load	9
5.5 Ventilation.....	9
5.6 Storage level	10
5.7 Spill containment sump	10
5.8 Penetrations for pipes, hoses and electrical cables	10
5.9 Storage levels and doors	10
6 Fire resistance.....	10
7 Information to be supplied.....	11
8 Marking and labelling	12
8.1 Openings for the inlet and outlet air	12
8.2 Equipotential bonding	12
8.3 Labelling of the front	12
Annex A (normative) Type test to determine protection level, hence classification	13
A.1 Principle	13
A.2 Testing apparatus and means	13
A.3 Test models.....	13
A.3.1 Quantity and description of test models	13
A.3.2 Preliminary examination of the test model	13
A.4 Preparation of fire test.....	14
A.4.1 Installation of test model	14
A.4.2 Temperature measuring point placement in the test model.....	14
A.4.3 Temperature measuring device placement in the furnace	17
A.5 Test report.....	18
A.6 Technical documentation by the manufacturer	19
Annex B (normative) Construction alterations.....	20
B.1 General information	20

B.2	Construction modifications that shall be assessed	20
B.2.1	Subsequent change of outer dimensions	20
B.2.2	Subsequent change of access openings.....	20
B.2.3	Subsequent variation and extension of interior equipment.....	20
B.2.4	Changes in components and materials	21
B.2.5	Additional penetrations	21
B.2.6	Additional superimposed load	24
B.3	Test report – Construction alterations	24
	Annex C (normative) Mechanical and aerotechnical tests.....	25
C.1	General information	25
C.2	Mechanical tests.....	25
C.3	Aerotechnical tests.....	25
C.4	Test report – Mechanical and aerotechnical tests	26
	Bibliography	27

European foreword

This document (EN 14470-1:2023) has been prepared by Technical Committee CEN/TC 332 “Laboratory equipment”, the secretariat of which is held by DIN.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by January 2024, and conflicting national standards shall be withdrawn at the latest by January 2024.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 14470-1:2004.

The main changes compared to the previous edition are listed below:

- a) Extension of the scope from an internal volume of not more than 1 m³ to not more than 2 m³;
- b) Clause 3 “Terms and definitions” extended and clarified;
- c) Deletion of the classification “Type 15”;
- d) Clarifications in Clause 5 “Construction” by e.g. including the description for materials and surfaces, weight loads and the addition of openings for pipes, hoses and electrical cables;
- e) Extension of Clause 7 “Information to be supplied”;
- f) Extension of Clause 8 “Marking and labelling”;
- g) Revision of the figures for temperature sensors in Annex A;
- h) Annex B extended and clarified by including a small fire test;
- i) Adding new Annex C “Mechanical and aerotechnical testing”.

Any feedback and questions on this document should be directed to the users’ national standards body. A complete listing of these bodies can be found on the CEN website.

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.

Introduction

This document describes the design and testing criteria for fire safety storage cabinets (also referred to as “cabinets” in this document) to be used in rooms to store flammable liquids in closed containers at normal room temperatures.

Primarily, this document covers the three major safety requirements for storage of flammable liquids, which are:

- a) minimizing the fire risk associated with the storage of flammable substances and protection of the fire safety storage cabinet's content in the event of fire for a known (tested) minimum length of time (fire rating);
- b) minimizing the amount of vapour released into the working environment;
- c) retention of accidental spillage within the fire safety storage cabinet.

Testing of the fire safety storage cabinet (see a) above) under fire conditions is a normative part of this document and the procedures and interpretation of the tests are described in detail.

The fire test (see a) above) provides three categories of fire protection ratings. In practice the degree of fire protection/rating allows the user to select, depending on individual circumstances, a fire safety storage cabinet which will allow sufficient time for personnel to leave, and fire fighters to enter the room before it is likely to that the flammables stored turn a possible minor/extinguishable fire into an uncontrollable one. The methods of achieving b) and c) above are sufficiently flexible to allow for local/national needs.

Caution should be exercised when determining the appropriate cabinet fire rating when flammables having auto-ignition temperatures below 200 °C and/or having high vapour pressures at room temperature are involved. When such flammable materials are being stored, expert advice should be sought. Reference is made to national regulations concerning flammable liquids.

1 Scope

This document is a product specification, giving performance requirements for fire safety storage cabinets to be used for the storage of flammable liquids. It is applicable to cabinets with a total internal volume of not greater than 2 m³, which can be free standing, restrained to a wall or mounted on plinth or castors.

This document does not apply to brick enclosures or walk-in storage rooms.

This document does not apply to any support frame or mechanism other than the base which is integral to the fire safety storage cabinet.

Requirements are given in respect of the construction of the fire safety storage cabinet and its capacity to resist fire conditions on the outside. A classification of fire safety storage cabinets is given, according to the level of fire resistance offered, and a type test is included, see Annex A.

The tests described in this document are type tests.

This document does not discriminate between different flammable liquids, which can have considerably different physical properties.

Attention is drawn to national regulations, which can apply with regard to the storage of flammable liquids.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 1363-1:2020, *Fire resistance tests - Part 1: General requirements*

EN 13165, *Thermal insulation products for buildings - Factory made rigid polyurethane foam (PU) products - Specification*

EN 13501-1:2018, *Fire classification of construction products and building elements - Part 1: Classification using data from reaction to fire tests*

EN 16121, *Non-domestic storage furniture - Requirements for safety, strength, durability and stability*

EN 16122, *Domestic and non-domestic storage furniture - Test methods for the determination of strength, durability and stability*

EN ISO 5167-1, *Measurement of fluid flow by means of pressure differential devices inserted in circular cross-section conduits running full - Part 1: General principles and requirements (ISO 5167-1)*

EN ISO 7010, *Graphical symbols - Safety colours and safety signs - Registered safety signs (ISO 7010)*