
**Information technology — Data
centres — Impact of the ISO 52000
series on energy performance of
buildings**

*Technologies de l'information — Centres de données — Impact de la
série ISO 52000 sur la performance énergétique des bâtiments*



COPYRIGHT PROTECTED DOCUMENT

© ISO/IEC 2022

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

Contents

Page

Foreword	iv
Introduction	v
1 Scope	1
2 Normative references	1
3 Terms, definitions and abbreviated terms	1
3.1 Terms and definitions.....	1
3.2 Abbreviated terms.....	4
3.3 Symbols (variables).....	4
3.4 Symbols (indices).....	5
4 Background, motivation and exclusions	6
4.1 Background and motivation.....	6
4.2 Exclusions.....	7
5 Data centre assessment boundary	7
5.1 Data centre boundary in the ISO/IEC 30134 series.....	7
5.2 Assessment boundary of the system in the ISO 52000 series.....	8
6 General principles of the overarching EPB framework and procedures	9
6.1 Output of the method.....	9
6.2 General description of the procedures.....	10
6.3 General description of the routing.....	10
6.4 Types of assessment.....	11
6.4.1 General.....	11
6.4.2 Calculated energy performance.....	11
6.4.3 Measured overall energy performance and comparison with calculations.....	12
7 Assessment of primary or weighted energy performance	13
7.1 Weighted overall energy balance.....	13
7.2 Primary energy factors.....	13
7.3 Weighting factors for exported energy.....	15
8 General approach for data centre energy flows	15
8.1 Data centre energy flows considered in the ISO/IEC 30134 series.....	15
8.2 General energy flows considered in the ISO 52000 series.....	15
8.2.1 General.....	15
8.2.2 Electricity and other carriers with exportation.....	16
8.2.3 Energy carriers without exportation.....	20
8.2.4 Exported heat on-site produced and not included in thermal use of the system.....	20
8.3 Data centre energy flows in an EPB approach.....	21
9 Impacts of the EPB approach on data centre KPIs	22
9.1 Impacts on conversion factors (case of metered energy consumption).....	22
9.2 Impact on power usage effectiveness (PUE — ISO/IEC 30134-2).....	25
9.3 Impact on the renewable energy factor (REF — ISO/IEC 30134-3).....	25
9.4 Impact on the energy reuse factor (ERF — ISO/IEC 30134-6).....	26
9.5 Impact on the excess electrical energy factor (XEEF — ISO/IEC TR 23050).....	26
9.6 Impact on IT equipment energy efficiency for servers (ITEE _{SV} — ISO/IEC 30134-4).....	26
Annex A (informative) Examples of primary energy assessment of a data centre as used for PUE assessment	27
Annex B (informative) Examples of primary energy assessment of data centre as used for REF assessment	35
Annex C (informative) Examples of primary energy assessment of data centre as used for ERF assessment	42

Foreword

ISO (the International Organization for Standardization) and IEC (the International Electrotechnical Commission) form the specialized system for worldwide standardization. National bodies that are members of ISO or IEC participate in the development of International Standards through technical committees established by the respective organization to deal with particular fields of technical activity. ISO and IEC technical committees collaborate in fields of mutual interest. Other international organizations, governmental and non-governmental, in liaison with ISO and IEC, also take part in the work.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of document should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives or www.iec.ch/members_experts/refdocs).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO and IEC shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents) or the IEC list of patent declarations received (see <https://patents.iec.ch>).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see www.iso.org/iso/foreword.html. In the IEC, see www.iec.ch/understanding-standards.

This document was prepared by Joint Technical Committee ISO/IEC JTC 1, *Information technology*, Subcommittee SC 39, *Sustainability, IT and data centres*.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html and www.iec.ch/national-committees.

Introduction

It is recognized that no “free” energy exists, even if certain processes or technical solutions are implemented in data centres, whose names can potentially suggest that energy is free (e.g. renewable energy, “free” cooling with air or water, geo-cooling, etc.).

In particular:

- even if the cost of certain renewable energy sources is low compared to non-renewable sources, there are still costs associated with the use or implementation of renewable energies such as transport and/or storage;
- some energy-efficient solutions implemented in data centres can also have other capital and operational energy costs;
- the remaining energy going out of a subsystem of a data centre, if not evaluated inside or outside the data centre boundary, is lost; every effort in order to minimize these losses results in improved energy efficiency of the data centre.

Regulatory frameworks exist (for example, in the European Union) which request primary energy assessment and that the energy consumption of computer rooms included in commercial or residential buildings can be assessed within primary energy as part of the overall energy consumption for these types of buildings.

The common objective of the key performance indicators (KPI) specified in the ISO/IEC 30134 series is the efficient or effective use or utilization of energy and other resources.

The ISO 52000 series defines methods and tools to assess the energy performance of buildings (EPB), routing and energy balance, together with greenhouse gas emissions.

These methods and tools are to be used (when mandatory) for mixed use buildings that include a data centre or server room in their premises. They can also be used in the case of stand-alone data centres.

Information technology — Data centres — Impact of the ISO 52000 series on energy performance of buildings

1 Scope

This document proposes elements for the expression of energy production, storage, reuse and consumption in reference to primary energy in data centres, taking into account both the elements needed for energy assessment and the concepts developed in the framework of the ISO 52000 series for energy performance of buildings (EPB).

This document:

- provides the main definitions and concepts from the ISO 52000 series needed to make a primary energy assessment for data centres;
- provides approaches for discriminating true sources of energy used by a given data centre;
- compares, where relevant, the terms used in both the ISO/IEC 30134 series and ISO 52000 series and provides explanations on the use of factors for converting final or delivered energy to primary energy which take a different approach in each series (and how to move from one to the other);
- illustrates the impact of using the EPB approach on data-centre-energy-related key performance indicators (KPIs), both in general and by the provision of examples;
- provides known sources of weighting or conversion factors to be used when there are no recognized or agreed local factors applicable to the studied data centre energy performance assessment.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO/IEC 30134 (all parts), *Information technology — Data centres key performance indicators*

ISO/IEC 22237 (all parts), *Information technology — Data centre facilities and infrastructures*

3 Terms, definitions and abbreviated terms

3.1 Terms and definitions

For the purposes of this document, the terms and definitions given in the ISO/IEC 30134 series and the ISO/IEC 22237 series and the following apply.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <https://www.electropedia.org/>

3.1.1

assessment boundary

boundary where the delivered and exported energy are measured or calculated

[SOURCE: ISO 52000-1:2017, 3.4.2]