



Institut luxembourgeois de la normalisation
de l'accréditation, de la sécurité et qualité
des produits et services

ILNAS-EN 817:2008



National Foreword

This European Standard EN 817:2008 was adopted as Luxembourgish Standard ILNAS-EN 817:2008.

Every interested party, which is member of an organization based in Luxembourg, can participate for FREE in the development of Luxembourgish (ILNAS), European (CEN, CENELEC) and International (ISO, IEC) standards:

- Participate in the design of standards
- Foresee future developments
- Participate in technical committee meetings

<https://portail-qualite.public.lu/fr/normes-normalisation/participer-normalisation.html>

THIS PUBLICATION IS COPYRIGHT PROTECTED

Nothing from this publication may be reproduced or utilized in any form or by any mean - electronic, mechanical, photocopying or any other data carries without prior permission!

EUROPEAN STANDARD ILNAS-EN 817:2008 **EN 817**
NORME EUROPÉENNE
EUROPÄISCHE NORM

June 2008

ICS 91.140.70

Supersedes EN 817:1997

English Version

**Sanitary tapware - Mechanical mixing valves (PN 10) - General
technical specifications**

Robinetterie sanitaire - Mitigeurs mécaniques (PN 10) -
Spécifications techniques générales

Sanitärarmaturen - Mechanisch einstellbare Mischer (PN
10) - Allgemeine technische Spezifikation

This European Standard was approved by CEN on 29 May 2008.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: rue de Stassart, 36 B-1050 Brussels

Contents

	page
Foreword.....	6
Introduction	7
1 Scope	8
2 Normative references	10
3 Terms, definitions and designation	10
3.1 Terms and definitions	10
3.2 Designation	11
4 Marking and identification	11
4.1 Marking	11
4.2 Identification.....	12
5 Materials	12
5.1 Chemical and hygiene requirements	12
5.2 Exposed surface conditions	12
6 Dimensional characteristics	12
6.1 General remarks.....	12
6.2 Inlet dimensions.....	12
6.3 Outlet dimensions.....	17
6.4 Mounting dimensions.....	19
6.5 Special cases	20
6.6 Flexible hoses for shower outlets.....	20
6.7 Shower outlets	20
7 Sequence of testing.....	21
8 Leaktightness characteristics	21
8.1 General.....	21
8.2 Test methods.....	21
8.3 Leaktightness of the obturator and of the mixing valve upstream of the obturators with the obturator in the closed position.....	22
8.4 Leaktightness of the mixing valve downstream of the obturator with the obturator open	22
8.5 Leaktightness of manually operated diverter	22
8.6 Leaktightness and operation of diverter with automatic return	23
8.7 Leaktightness of the obturator: cross flow between hot water and cold water.....	24
9 Pressure resistance characteristics – mechanical performance under pressure	26
9.1 General.....	26
9.2 Principle.....	26
9.3 Apparatus	26
9.4 Mechanical behaviour upstream of the obturator – obturator in the closed position.....	26
9.5 Mechanical behaviour downstream of the obturator – obturator in the open position	26
10 Hydraulic characteristics	27
10.1 General.....	27
10.2 Initial settings.....	27
10.3 Principle.....	28
10.4 Apparatus	28
10.5 Procedure	28
10.6 Determination of flow rate	29
10.7 Determination of sensitivity.....	30
11 Mechanical strength characteristics - torsion test for operating mechanism	33

11.1	General.....	33
11.2	Test method	33
12	Mechanical endurance characteristics.....	34
12.1	Mechanical endurance of the control device.....	34
12.2	Mechanical endurance of diverters	38
12.3	Mechanical endurance of swivel spouts.....	40
13	Backflow protection	41
14	Acoustic characteristics	41
14.1	General.....	41
14.2	Procedure	41
14.3	Requirements.....	41
	Annex A (informative) Apparatus	43
	Annex B (informative) Pressure take-off tee.....	47
	Bibliography	50

Figures

Figure 1	Supply system with a pressure range of (0,05 to 1,0) MPa [(0,5 to 10) bar].....	9
Figure 2	Flexible hoses and plain tube	14
Figure 3	Multi-hole mechanical mixing valve	15
Figure 4	Supply connections for mechanical mixing valve and remote outlets	16
Figure 5	Remote outlet	18
Figure 6	Single hole mechanical mixing valve.....	18
Figure 7	Two hole mechanical mixing valve	18
Figure 8	Single hole mechanical mixing valve.....	19
Figure 9	Two hole mechanical mixing valve	20
Figure 10	Sensitivity curve.....	31
Figure 11	Radius for the determination of sensitivity	32
Figure 12	Rectangular movement	34
Figure 13	Triangular movement.....	35
Figure 14	Test bench adjustment torque for conventionnal mixing valve.....	37
Figure 15	Test bench adjustment torque for joystick mixing valve.....	37
Figure 16	Test bench adjustment torque for sequential mixing valve	37
Figure A 1	Supply circuits	43
Figure A 2	Test circuit.....	45
Figure A 3	Mounting of the mixing valve	46
Figure B 1	Pressure take-off tee	47
Figure B 2	Schematic examples of pressure take-off tees	48

Tables

Table 1 Conditions of use/Classifications	8
Table 2 Designation	11
Table 3 Inlet dimensions (mechanical mixing valve).....	13
Table 4 Outlet dimensions (Remote outlets, mechanical mixing valve)	17
Table 5 Mounting dimensions (Outlets, single- and multi-hole mechanical mixing valve).....	19
Table 6 Test Sequence	21
Table 7 Summary of leaktightness tests	25
Table 8 Summary of pressure resistance characteristic tests.....	27
Table 9 Initial Settings	27
Table 10 Flow rates according to application.....	29
Table 11 Performance levels	30
Table 12 Summary of test conditions for cartridges	35
Table 13 Summary of test conditions for diverters.....	39
Table 14 Flow rate classes (EN ISO 3822-4 Annex A).....	41
Table 15 Acoustic group	42
Table A 1 Connecting dimension	45
Table B 1 Dimensions of the pressure take-off tee	47

Foreword

This document (EN 817:2008) has been prepared by Technical Committee CEN/TC 164 "Water supply", the secretariat of which is held by AFNOR.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by December 2008, and conflicting national standards shall be withdrawn at the latest by December 2008.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 817:1997.

This European Standard acknowledges the field of application for mechanical mixing valves used in water supply systems with a pressure range of (0,05 to 1,0) MPa (0,5 bar to 10 bar).

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.