

**IEC 62271-110**  
(Third edition – 2012)

High-voltage switchgear and controlgear –

Part 110: Inductive load switching

**CEI 62271-110**  
(Troisième édition – 2012)

Appareillage à haute tension –

Partie 110: Manœuvre de charges inductives

## CORRIGENDUM 1

### 6.114.3 Test circuits

*Replace the existing fourth paragraph of this subclause by the following new paragraph:*

For three-pole in one enclosure type circuit-breakers, single pole testing is permissible provided that the correct transient recovery voltages to earth (enclosure) are achieved.

### 6.114.3 Circuits d'essais

*Remplacer le quatrième alinéa existant de ce paragraphe par le nouvel alinéa suivant:*

Pour les disjoncteurs tripolaires à enveloppe unique, un essai en monophasé est admis, à condition que des tensions transitoires de rétablissement à la terre atteintes (enveloppe) soient acceptables.