

TECHNICAL REPORT

INTERNATIONAL SPECIAL COMMITTEE ON RADIO INTERFERENCE

**Radio interference characteristics of overhead power lines and high-voltage equipment –
Part 2: Methods of measurement and procedure for determining limits**



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2010 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland
Email: inmail@iec.ch
Web: www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: www.iec.ch/searchpub

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: www.iec.ch/online_news/justpub

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

- Electropedia: www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

- Customer Service Centre: www.iec.ch/webstore/custserv

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: csc@iec.ch
Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00

TECHNICAL REPORT

INTERNATIONAL SPECIAL COMMITTEE ON RADIO INTERFERENCE

**Radio interference characteristics of overhead power lines and high-voltage equipment –
Part 2: Methods of measurement and procedure for determining limits**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

PRICE CODE **XB**

ICS 33.100.01

ISBN 978-2-88912-017-8

CONTENTS

FOREWORD.....	6
INTRODUCTION.....	8
1 Scope.....	10
2 Normative references.....	10
3 Terms and definitions.....	11
4 Measurements.....	11
4.1 Measuring instruments.....	11
4.1.1 Response of a standard quasi-peak CISPR measuring receiver to a.c. generated corona noise.....	11
4.1.2 Other measuring instruments.....	12
4.2 On-site measurements on HV overhead power lines.....	12
4.2.1 General.....	12
4.2.2 Measurements in the frequency range from 0,15 MHz to 30 MHz.....	12
4.2.3 Measurements in the frequency range from 30 MHz to 300 MHz.....	14
4.3 Statistical evaluation of the radio noise level of a line.....	15
4.4 Additional information to be given in the report.....	16
4.5 Measurements on HV equipment in the laboratory.....	16
4.5.1 Overview.....	16
4.5.2 State of the test object.....	17
4.5.3 Test area.....	17
4.5.4 Atmospheric conditions.....	18
4.5.5 Test circuit – Basic diagram.....	18
4.5.6 Practical arrangement of the test circuit.....	18
4.5.7 Test circuit components.....	19
4.5.8 Measuring receiver connections.....	19
4.5.9 Mounting and arrangement of test object.....	21
4.5.10 Measurement frequency.....	21
4.5.11 Checking of the test circuit.....	21
4.5.12 Calibration of the test circuit.....	21
4.5.13 Test procedure.....	22
4.5.14 Related observations during the test.....	23
4.5.15 Data to be given in test report.....	23
5 Methods for derivation of limits for HV power systems.....	24
5.1 Overview.....	24
5.2 Significance of CISPR limits for power lines.....	24
5.3 Technical considerations for derivation of limits for lines.....	25
5.3.1 Basic approach.....	25
5.3.2 Scope.....	25
5.3.3 Minimum broadcast signal levels to be protected.....	26
5.3.4 Required signal-to-noise ratio.....	27
5.3.5 Use of data on radio noise compiled during measurements in the field.....	28
5.3.6 Use of data obtained by prediction of the radio noise from high-voltage overhead power lines.....	29
5.4 Methods of determining compliance of measured data with limits.....	30
5.4.1 Long-term recording.....	30
5.4.2 Sampling method.....	31

5.4.3	Survey methods.....	31
5.4.4	Alternative criteria for an acceptable noise level.....	31
5.5	Examples for derivation of limits in the frequency range below 30 MHz.....	32
5.5.1	Radio reception.....	32
5.5.2	Television reception, 47 MHz to 230 MHz.....	33
5.6	Additional remarks.....	34
5.7	Technical considerations for derivation of limits for line equipment and HVAC substations.....	34
5.7.1	General.....	34
5.7.2	Current injected by line components and hardware.....	35
5.7.3	Current injected by substation equipment.....	35
5.7.4	Practical derivation of limits in the l.f. and m.f. band.....	35
6	Methods for derivation of limits for the radio noise produced by insulator sets.....	37
6.1	General considerations.....	37
6.2	Insulator types.....	37
6.3	Influence of insulator surface conditions.....	38
6.3.1	General.....	38
6.3.2	Clean insulators.....	38
6.3.3	Slightly polluted insulators.....	38
6.3.4	Polluted insulators.....	39
6.4	Criteria for setting up radio noise limits for insulators.....	39
6.4.1	General.....	39
6.4.2	Criterion for insulators to be installed in type A areas.....	40
6.4.3	Criterion for insulators to be installed in type B areas.....	40
6.4.4	Criterion for insulators to be installed in type C areas.....	40
6.5	Recommendations.....	40
7	Methods for derivation of limits for the radio noise due to HVDC converter stations and similar installations.....	42
7.1	General considerations.....	42
7.2	Sources of interference.....	43
7.2.1	Mechanism of radio noise generation.....	43
7.2.2	Influence of station design on radio interference.....	43
7.3	Radiated fields from valve halls.....	44
7.3.1	Frequency spectra.....	44
7.3.2	Lateral attenuation.....	44
7.3.3	Reduction of the radio interference due to direct radiation from the valve hall.....	44
7.4	Conducted interference along the transmission lines.....	45
7.4.1	Description of the mechanism and typical longitudinal profiles.....	45
7.4.2	Reduction of the interference conducted along the transmission lines.....	45
7.5	General criteria for stating limits.....	46
7.5.1	Overview.....	46
7.5.2	Direct radiation.....	46
7.5.3	Propagation along the lines.....	46
8	Figures.....	48
	Annex A (informative) Radio interference measuring apparatus differing from the CISPR basic standard instruments.....	62
	Annex B (normative) List of additional information to be included in the report on the results of measurements on operational lines.....	63

Annex C (informative) Minimum broadcast signal levels to be protected – ITU recommendations	64
Annex D (informative) Minimum broadcast signals to be protected – North American standards.....	65
Annex E (informative) Required signal-to-noise ratios for satisfactory reception.....	66
Annex F (informative) Derivation of the formula for the protected distance.....	69
Bibliography.....	70
Figure 1 – Transformation of pulses through a CISPR measuring receiver	48
Figure 2 – Bursts of corona pulses generated by alternating voltage.....	49
Figure 3 – Example of extrapolation to determine the radio noise field strength reference level of a power line, here at the direct reference distance of 20 m.....	49
Figure 4 – Basic test circuit.....	50
Figure 5 – Standard test circuit.....	50
Figure 6 – Connection to the measuring receiver by a coaxial cable	51
Figure 7 – Connection to the measuring receiver by a balanced cable	51
Figure 8 – Special test circuit.....	51
Figure 9 – Arrangement for calibration of the standard test circuit.....	52
Figure 10 – Map showing boundaries of zones A, B, and C in regions 1 and 3	53
Figure 11 – Illustration of the four basic parameters for a power transmission line	54
Figure 12 – Example of typical statistical yearly "all-weather" distributions of the radio-noise levels of a bipolar direct current line (-----) and for an alternating current line in a moderate climate (- - -)	55
Figure 13 – Example of radio noise voltage level V_f as a function of the relative air humidity R.H., in clean conditions and slightly polluted conditions, of a standard insulator (—) and a particular type of "low noise" insulator (- - -)	56
Figure 14 – Example of frequency spectra of pulses with different rise times, simulating commutation phenomena in mercury valves and in thyristor valves	56
Figure 15 – Example of frequency spectra of the radio interference recorded outside the hall of a mercury arc valve converter station with and without toroidal filters	57
Figure 16 – Example of frequency spectra of the radio interference recorded outside the hall of a thyristor valve converter station for different operating conditions.....	57
Figure 17 – Attenuation of the field strength as a function of the distance on a horizontal plane, for different frequencies	58
Figure 18 – Example of frequency spectrum of the radio interference in the vicinity of a d.c. line (30 m) at a short distance from the converter station	59
Figure 19 – Example of frequency spectrum of the radio interference in the vicinity of an a.c. line (20 m) at a short distance from the converter station	60
Figure 20 – Frequency spectra of radio interference at 20 m from the electrode line at 1,5 km from the Gotland HVDC link in Sweden with mercury arc groups or thyristor groups in operation.....	60
Figure 21 – Frequency spectra of radio interference at 20 m from the electrode line at 1,5 km and 4,5 km from the Gotland HVDC link in Sweden with mercury arc groups in operation	61
Figure 22 – Frequency spectra of the radio interference recorded along a 200 kV d.c. line, at 20 m from the conductor, at different distances from the converter station	61
Table 1 – Number of n sets of measurement of the radio noise level and corresponding values for factor k	16

Table 2 – Minimum usable broadcast signal field strengths in the v.h.f bands according to CCIR	27
Table 3 – Recommendations for the radio noise voltage limits and for the test methods for insulator sets installed in different areas	42
Table C.1 – Minimum field strength	64
Table C.2 – Nominal usable field strength	64
Table D.1 – Signal levels at the edge of the service area in North America	65
Table E.1 – Summary of signal-to-noise ratios for corona from a.c. lines (Signal measured with average detector, noise measured with quasi-peak detector)	66
Table E.2 – Quality of radio reception or degree of annoyance due to RFI	67

Withdrawn

INTERNATIONAL ELECTROTECHNICAL COMMISSION
INTERNATIONAL SPECIAL COMMITTEE ON RADIO INTERFERENCE

**RADIO INTERFERENCE CHARACTERISTICS
OF OVERHEAD POWER LINES
AND HIGH-VOLTAGE EQUIPMENT –**

**Part 2: Methods of measurement
and procedure for determining limits**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. However, a technical committee may propose the publication of a technical report when it has collected data of a different kind from that which is normally published as an International Standard, for example "state of the art".

CISPR 18-2, which is a technical report, has been prepared by CISPR subcommittee B: Interference relating to industrial, scientific and medical radio-frequency apparatus, to other (heavy) industrial equipment, to overhead power lines, to high voltage equipment and to electric traction.

This second edition cancels and replaces the first edition published in 1986. It is a technical revision.

This edition includes the following significant technical changes with respect to the previous edition: while the first edition of CISPR 18-2 only considered the direct distance D_0 for the establishment of standard profiles for the lateral radio noise field emanating from HV overhead power lines, this second edition now also allows for use of the lateral distance y_0 for these purposes. This way it allows for conduction of on-site measurements and simplified recording and use of measurement data obtained at lateral distances y slant to the pathway of modern HV and UHV overhead power line constructions with tall suspension towers.

The text of this technical report is based on the following documents:

DTR	Report on voting
CISPR/B/494/DTR	CISPR/B/502/RVC

Full information on the voting for the approval of this technical report can be found in the report on voting indicated in the above table.

This technical report has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of the CISPR 18 series can be found, under the general title *Radio interference characteristics of overhead power lines and high-voltage equipment*, on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

INTRODUCTION

This technical report forms the second of a three-part publication dealing with radio noise generated by electrical power transmission and distribution facilities (overhead lines and substations). It contains recommendations for conduction of on-site measurements of electromagnetic noise fields in the vicinity of high-voltage (HV) overhead power lines and substations and for determination of limits for protection of radio reception.

The recommendations given in this part 2 of the CISPR 18 series are intended to be a useful aid to engineers involved in maintenance of overhead lines and substations and also to anyone concerned with checking the radio noise performance of a line to ensure satisfactory protection of radio reception. Information on the physical phenomena involved in the generation of electromagnetic noise fields is found in CISPR/TR 18-1. It also includes the main properties of such fields and their numerical values. CISPR/TR 18-3 eventually contains a Code of Practice for minimizing the generation of radio noise.

This second edition of CISPR/TR 18-2 was adapted to the modern structure and content of technical reports issued by IEC. The first edition of CISPR 18-2 underwent thorough edition and adaptation to modern terminology. Furthermore its content was adjusted such as to allow for use of the lateral distance y for the conduction of measurements in the field.

The CISPR 18 series does not deal with biological effects on living matter or any issues related to exposure in electromagnetic fields.

The main content of this technical report is based on historical CISPR Rec. No. 56 given below:

RECOMMENDATION No. 56

METHODS OF MEASUREMENT OF RADIO INTERFERENCE CAUSED BY OVERHEAD POWER LINES AND HIGH-VOLTAGE EQUIPMENT AND THE PROCEDURE FOR DETERMINING LIMITS

The CISPR

CONSIDERING

- a) that a general description of the radio interference characteristics of overhead power lines and high-voltage equipment has been published in CISPR 18-1,
- b) that the methods of measurement of these characteristics need to be established,
- c) that national authorities require guidance on the procedure for determining limits of such radio interference.

RECOMMENDS

That the latest edition of CISPR/TR 18-2, including amendments, be used for methods of measurement of radio interference characteristics of overhead power lines and high-voltage equipment and for procedures for determining limits.

CISPR/TR 18-1 describes the main properties of the physical phenomena involved in the production of disturbing electromagnetic fields by overhead lines and provides numerical values of such fields.

In CISPR/TR 18-2 methods of measurement and procedures for determining limits of such radio interference are recommended.

The methods of measurement in CISPR/TR 18-2 detail the techniques and procedures for use when measuring fields on site near to an overhead line and also the techniques and procedures for making laboratory measurements of interference voltages and currents generated by line equipment and accessories.

The procedures for determining limits define the expected values of radio noise field and the width of the "disturbed" corridor following the route of the line.

This corridor takes into account the effective field strength of the wanted signal, the signal-to-noise ratio selected and the expected strength of the noise field for a given line.

The procedures are only valid for long and medium waves as the procedures applicable to VHF frequency-modulation broadcasting have not yet been decided, due to insufficient knowledge.

It is emphasized that this part of CISPR 18 does not specify a single set of limits to be applied internationally. Rather it details the procedures to enable national authorities to specify limits where it is decided there is a need for regulations.

Withdrawn