

INTERNATIONAL STANDARD



Effects of current on human beings and livestock – Part 1: General aspects



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2018 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

IEC Catalogue - webstore.iec.ch/catalogue

The stand-alone application for consulting the entire bibliographical information on IEC International Standards, Technical Specifications, Technical Reports and other documents. Available for PC, Mac OS, Android Tablets and iPad.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and also once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing 21 000 terms and definitions in English and French, with equivalent terms in 16 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

67 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.



IEC 60479-1

Edition 1.0 2018-12

INTERNATIONAL STANDARD



Effects of current on human beings and livestock – Part 1: General aspects

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 13.200; 29.020

ISBN 978-2-8322-6295-5

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	6
INTRODUCTION.....	8
1 Scope.....	9
2 Normative references	10
3 Terms and definitions	10
3.1 General definitions.....	10
3.2 Effects of sinusoidal alternating current in the range 15 Hz to 100 Hz.....	11
3.3 Effects of direct current.....	12
4 Electrical impedance of the human body and livestock	13
4.1 General.....	13
4.2 Internal impedance of the human body (Z_i)	13
4.3 Impedance of the skin (Z_S).....	13
4.4 Total impedance of the human body (Z_T)	13
4.5 Factors affecting initial resistance of the human body (R_0).....	14
4.6 Values of the total impedance of the human body (Z_T).....	14
4.6.1 Total body impedance dependence for large, medium and small surface areas of contact.....	14
4.6.2 Sinusoidal alternating current 50/60 Hz for large surface areas of contact	14
4.6.3 Sinusoidal alternating current 50/60 Hz for medium and small surface areas of contact.....	17
4.6.4 Sinusoidal alternating current with frequencies up to 20 kHz and above	20
4.6.5 Direct current.....	21
4.7 Value of the initial resistance of the human body (R_0)	22
4.8 Characteristics of the impedance of the body of livestock	22
5 Effects of sinusoidal alternating current in the range of 15 Hz to 150 Hz.....	22
5.1 General.....	22
5.2 Threshold of perception	22
5.3 Threshold of reaction	22
5.4 Immobilization.....	22
5.5 Threshold of let-go.....	23
5.6 Threshold of ventricular fibrillation	23
5.7 Other effects related to electric shocks	23
5.8 Effects of current on the skin	24
5.9 Description of time/current zones (see Figure 20)	24
5.10 Application of heart-current factor (F).....	25
6 Effects of direct current	26
6.1 General.....	26
6.2 Threshold of perception and threshold of reaction.....	26
6.3 Threshold of immobilization and threshold of let-go.....	26
6.4 Threshold of ventricular fibrillation	26
6.5 Other effects of current	27
6.6 Description of time/current zones (see Figure 22)	27
6.7 Heart factor.....	28
6.8 Effects of anodic versus cathodic DC currents	45
Annex A (normative) Measurements of the total body impedances Z_T made on living human beings and on corpses and statistical analysis of the results	48
Annex B (normative) Influence of frequency on the total body impedance (Z_T).....	51

Annex C (normative) Total body resistance (R_T) for direct current.....	52
Annex D (informative) Examples of calculations of Z_T	53
Annex E (informative) Theories of ventricular fibrillation.....	56
Annex F (informative) Quantities of upper limit of vulnerability (ULV) and lower limit of vulnerability (LLV)	57
Annex G (informative) Circuit simulation methods in electric shock evaluation	58
Annex H (normative) Effects of currents passing through the body of livestock	61
H.1 General.....	61
H.2 Principal consideration of the risk of ventricular fibrillation for livestock	61
H.3 Characteristics of the impedance of the body of livestock	62
H.4 Internal impedance of animals (Z_i)	62
H.5 Impedance of the hide and skin (Z_P).....	63
H.6 Impedance (resistance) of the hoof (Z_h, R_h).....	63
H.7 Total body impedance (Z_T)	63
H.8 Initial body resistance (R_0).....	64
H.9 Values of the total body impedance (Z_T)	64
H.10 Values of the initial resistance of the body (R_0).....	65
H.11 Effects on livestock of sinusoidal alternating current in the range from 15 Hz to 100 Hz	65
H.11.1 General	65
H.11.2 Threshold of reaction	66
H.11.3 Threshold of ventricular fibrillation	66
Bibliography.....	69
Figure 1 – Impedances of the human body.....	28
Figure 2 – Internal partial impedances Z_{ip} of the human body.....	29
Figure 3 – Simplified schematic diagram for the internal impedances of the human body	30
Figure 4 – Total body impedance Z_T (50 %) for a current path hand to hand, for large surface areas of contact in dry, water-wet and saltwater-wet conditions for a percentile rank of 50 % of the population for touch voltages $U_T = 25$ V to 700 V, AC 50/60 Hz	31
Figure 5 – Dependence of the total impedance Z_T of one living person on the surface area of contact in dry conditions and at touch voltage (50 Hz)	32
Figure 6 – Dependence of the total body impedance Z_T on the touch voltage U_T for a current path from the tips of the right to the left forefinger compared with large surface areas of contact from the right to the left hand in dry conditions measured on one living person, touch voltage range $U_T = 25$ V to 200 V, AC 50 Hz, duration of current flow max. 25 ms.....	33
Figure 7 – Dependence of the total body impedance Z_T for the 50 th percentile rank of a population of living human beings for large, medium and small surface areas of contact (order of magnitude 10 000 mm ² , 1 000 mm ² and 100 mm ² respectively) in dry conditions at touch voltages $U_T = 25$ V to 200 V AC 50/60 Hz.....	34
Figure 8 – Dependence of the total body impedance Z_T for the 50 th percentile rank of a population of living human beings for large, medium and small surface areas of contact (order of magnitude 10 000 mm ² , 1 000 mm ² and 100 mm ² respectively) in water-wet conditions at touch voltages $U_T = 25$ V to 200 V, AC 50/60 Hz	35
Figure 9 – Dependence of the total body impedance Z_T for the 50 th percentile rank of a population of living human beings for large, medium and small surface areas of contact (order of magnitude 10 000 mm ² , 1 000 mm ² and 100 mm ² respectively) in saltwater-wet conditions at touch voltages $U_T = 25$ V to 200 V, AC 50/60 Hz.....	36

Figure 10 – Values for the total body impedance Z_T measured on 10 living human beings with a current path hand to hand and large surface areas of contact in dry conditions at a touch voltage of 10 V and frequencies from 25 Hz to 20 kHz 37

Figure 11 – Values for the total body impedance Z_T measured on one living human being with a current path hand to hand and large surface areas of contact in dry conditions at a touch voltage of 25 V and frequencies from 25 Hz to 2 kHz 37

Figure 12 – Frequency dependence of the total body impedance Z_T of a population for a percentile rank of 50 % for touch voltages from 10 V to 1 000 V and a frequency range from 50 Hz to 150 kHz for a current path hand to hand or hand to foot, large surface areas of contact in dry conditions 38

Figure 13 – Statistical value of total body impedances Z_T and body resistances R_T for a percentile rank of 50 % of a population of living human beings for the current path hand to hand, large surface areas of contact, dry conditions, for touch voltages up to 700 V, for AC 50/60 Hz and DC 38

Figure 14 – Dependence of the alteration of human skin condition on current density i_T and duration of current flow 39

Figure 15 – Electrodes used for the measurement of the dependence of the impedance of the human body Z_T on the surface area of contact 40

Figure 16 – Oscillograms of touch voltages U_T and touch currents I_T for AC, current path hand to hand, large surface areas of contact in dry conditions taken from measurements 41

Figure 17 – Occurrence of the vulnerable period of ventricles during the cardiac cycle 42

Figure 18 – Triggering of ventricular fibrillation in the vulnerable period – Effects on electro-cardiogram (ECG) and blood pressure 42

Figure 19 – Fibrillation data for dogs, pigs and sheep from experiments and for persons calculated from statistics of electrical accidents with transversal direction of current flow hand to hand and touch voltages $U_T = 220$ V and 380 V AC with body impedances Z_T (5 %) 43

Figure 20 – Conventional time/current zones of effects of AC currents (15 Hz to 100 Hz) on persons for a current path corresponding to left hand to feet (see Table 11) 44

Figure 21 – Oscillogram of touch voltages U_T and touch current I_T for DC, current path hand to hand, large surface areas of contact in dry conditions 44

Figure 22 – Conventional time/current zones of effects of DC currents on persons for a longitudinal upward current path (see Table 13) 45

Figure 23 – Let-go currents for 60 Hz sinusoidal current 45

Figure 24 – Effects of anodic versus cathodic DC currents 46

Figure 25 – Pulsed DC stimulation of single heart cells 47

Figure G.1 – Electric shock in electrical model by Hart [33] including startle reaction effect 59

Figure H.1 – Current flow and impedances of the relevant parts of the body of a cow for current path from the nose to the legs 62

Figure H.2 – Diagrams for an animal, for a current path from the nose to the four legs (path A) and from the forelegs to the hindlegs (path B) 62

Figure H.3 – Diagram for the total body impedance for cattle for a percentage of 5 % of the population 65

Figure H.4 – Ventricular fibrillation for sheep 66

Figure H.5 – Minimum fibrillating currents of sheep as a function of weight for a shock duration of 3 s [55] 67

Figure H.6 – Minimum fibrillating currents (averages) of various species of livestock as a function of weight for a shock duration of 3 s [53] 68

Table 1 – Total body impedances Z_T for a current path hand to hand AC 50/60 Hz, for large surface areas of contact in dry conditions 15

Table 2 – Total body impedances Z_T for a current path hand to hand AC 50/60 Hz, for large surface areas of contact in water-wet conditions	16
Table 3 – Total body impedances Z_T for a current path hand to hand AC 50/60 Hz, for large surface areas of contact in saltwater-wet conditions.....	17
Table 4 – Total body impedances Z_T for a current path hand to hand for medium surface areas of contact in dry conditions at touch voltages $U_T = 25$ V to 200 V AC 50/60 Hz (values rounded to 25 Ω)	18
Table 5 – Total body impedances Z_T for a current path hand to hand for medium surface areas of contact in water-wet conditions at touch voltages $U_T = 25$ V to 200 V AC 50/60 Hz (values rounded to 25 Ω).....	19
Table 6 – Total body impedances Z_T for a current path hand to hand for medium surface areas of contact in saltwater-wet conditions at touch voltages $U_T = 25$ V to 200 V AC 50/60 Hz (values rounded to 5 Ω).....	19
Table 7 – Total body impedances Z_T for a current path hand to hand for small surface areas of contact in dry conditions at touch voltages $U_T = 25$ V to 200 V AC 50/60 Hz (values rounded to 25 Ω)	19
Table 8 – Total body impedances Z_T for a current path hand to hand for small surface areas of contact in water-wet conditions at touch voltages $U_T = 25$ V to 200 V AC 50/60 Hz (values rounded to 25 Ω)	20
Table 9 – Total body impedances Z_T for a current path hand to hand for small surface areas of contact in saltwater-wet conditions at touch voltages $U_T = 25$ V to 200 V AC 50/60 Hz (values rounded to 5 Ω)	20
Table 10 – Total body resistances R_T for a current path hand to hand, direct current, for large surface areas of contact in dry conditions	21
Table 11 – Time/current zones for AC 15 Hz to 100 Hz for hand to feet pathway – Summary of zones of Figure 20	25
Table 12 – Heart-current factor F for different current paths.....	26
Table 13 – Time/current zones for direct current for hand to feet pathway – Summary of zones of Figure 22	28
Table A.1 – Total body impedances Z_T , electrodes type A for dry conditions and deviation factors F_D (5 % and 95 %).....	48
Table A.2 – Total body impedances Z_T , electrodes type B for dry, water-wet and saltwater-wet conditions and deviation factors F_D (5 % and 95 %).....	48
Table A.3 – Total body impedances Z_T for dry, water-wet and saltwater-wet conditions and deviation factors F_D (5 % and 95 %).....	48
Table A.4 – Deviation factors F_D (5 %) and F_D (95 %) for dry and water-wet conditions in the touch voltage range $U_T = 25$ V up to 400 V for large, medium and small surface areas of contact.....	50
Table D.1 – 50 th percentile values for the total body impedance for a current path hands-feet, medium surface area of contact for hands, large for feet, reduction factor 0,8, dry conditions, touch currents I_T and electrophysiological effects	54
Table G.1 – Body impedance examples (uncompensated).....	59
Table H.1 – Impedance (resistance) of the hooves of cattle (Z_h , R_h) for AC voltages up to 230 V, 50/60 Hz.....	63
Table H.2 – Total body impedances Z_T for AC 50/60 Hz for cattle for touch voltages up to 230 V.....	64
Table H.3 – Initial body resistance R_0 for cattle	65
Table H.4 – Threshold of ventricular fibrillation for AC 50/60 Hz [53] [54] for different species of livestock, for a shock duration of 3 s	67

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**EFFECTS OF CURRENT ON HUMAN BEINGS
AND LIVESTOCK –****Part 1: General aspects****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60479-1 has been prepared by IEC technical committee 64: Electrical installations and protection against electric shock.

This first edition cancels and replaces IEC TS 60479-1:2005, Amendment 1:2016 and IEC TR 60479-3:1998. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to IEC TS 60479-1 and IEC TR 60479-3:

- The contents of IEC TR 60479-3 relating to aspects unique to the effects of current passing through the bodies of livestock have been incorporated into a new Annex H (normative).

It has the status of a basic safety publication in accordance with IEC Guide 104.

The text of this International Standard is based on the following documents:

CDV	Report on voting
64/2275/CDV	64/2343/RVC

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 60479 series, published under the general title *Effects of current on human beings and livestock*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

In order to avoid errors in the interpretation of this document, it should be emphasized that the data given herein is mainly based on experiments with animals as well as on information available from clinical observations. Only a few experiments with shock currents of short duration have been carried out on living human beings.

On the evidence available, mostly from animal research, the values are so conservative that this document applies to persons of normal physiological conditions including children, irrespective of age and weight.

There are, however, other aspects which should be taken into account, such as probability of faults, probability of contact with live or faulty parts, ratio between touch voltage and fault voltage, experience gained, technical feasibilities, and economics. These parameters should be considered carefully when establishing safety requirements, for example, operating characteristics of protective devices for electrical installations.

The form of the document, as has been adopted, summarizes results so far achieved which are being used by technical committee 64 as a basis for establishing requirements for protection against shock. These results are considered important enough to justify an IEC publication which may serve as a guide to other IEC committees and countries having need of such information.

This document applies to the threshold of ventricular fibrillation which is the main cause of deaths by electric current. The analysis of results of recent research work on cardiac physiology and on the fibrillation threshold, taken together, has made it possible to better appreciate the influence of the main physical parameters and, especially, of the duration of the current flow.

This document contains information about body impedance and body current thresholds for various physiological effects. This information can be combined to derive estimates of AC and DC touch voltage thresholds for certain body current pathways, contact moisture conditions, and skin contact areas.

This document refers specifically to the effects of electric current. When an assessment of the harmful effects of any event on human beings and livestock is being made, other non-electric phenomena, including falls, heat, fire, or others should be taken into account. These matters are beyond the scope of this document, but may be extremely serious in their own right.

Further experimental data are under consideration, such as recent ongoing experimental work on "current induced heart fibrillation by excitation with discrete Fourier spectra" which is intended to contribute to frequency factor data.

The characteristics of the impedance of the body of livestock and the effects of sinusoidal alternating currents are described in Annex H.

EFFECTS OF CURRENT ON HUMAN BEINGS AND LIVESTOCK –

Part 1: General aspects

1 Scope

This part of IEC 60479 provides basic guidance on the effects of shock current on human beings and livestock.

For a given current path through the human body, the danger to persons depends mainly on the magnitude and duration of the current flow. However, the time/current zones specified in the following clauses are, in many cases, not directly applicable in practice for designing measures of protection against electrical shock. The necessary criterion is the admissible limit of touch voltage (i.e. the product of the current through the body called touch current and the body impedance) as a function of time. The relationship between current and voltage is not linear because the impedance of the human body varies with the touch voltage, and data on this relationship is therefore required. The different parts of the human body (such as the skin, blood, muscles, other tissues and joints) present to the electric current a certain impedance composed of resistive and capacitive components.

The values of body impedance depend on a number of factors and, in particular, on current path, on touch voltage, duration of current flow, frequency, degree of moisture of the skin, surface area of contact, pressure exerted and temperature.

The impedance values indicated in this document result from a close examination of the experimental results available from measurements carried out principally on corpses and on some living persons.

Knowledge of the effects of alternating current is primarily based on the findings related to the effects of current at frequencies of 50 Hz or 60 Hz which are the most common in electrical installations. The values given are, however, deemed applicable over the frequency range from 15 Hz to 100 Hz, threshold values at the limits of this range being higher than those at 50 Hz or 60 Hz. Principally the risk of ventricular fibrillation is considered to be the main mechanism of death of fatal electrical accidents.

Accidents with direct current are much less frequent than would be expected from the number of DC applications, and fatal electrical accidents occur only under very unfavourable conditions, for example, in mines. This is partly due to the fact that with direct current, the let-go of parts gripped is less difficult and that for shock durations longer than the period of the cardiac cycle, the threshold of ventricular fibrillation is considerably higher than for alternating current.

This basic safety publication is primarily intended for use by technical committees in the preparation of standards in accordance with the principles laid down in IEC Guide 104 and ISO/IEC Guide 51. It is not intended for use by manufacturers or certification bodies.

One of the responsibilities of a technical committee is, wherever applicable, to make use of basic safety publications in the preparation of its publications. The requirements, test methods or test conditions of this basic safety publication will not apply unless specifically referred to or included in the relevant publications.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC Guide 104:2010, *The preparation of safety publications and the use of basic safety publications and group safety publications*

ISO/IEC Guide 51:2014, *Safety aspects – Guidelines for their inclusion in standards*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

3.1 General definitions

3.1.1

longitudinal current

current flowing lengthwise through the trunk of the human body such as from hand to feet

3.1.2

transverse current

current flowing across the trunk of the human body such as from hand to hand

3.1.3

internal impedance of the human body

Z_i

impedance between two electrodes in contact with two parts of the human body, neglecting skin impedances

Note 1 to entry: For the body of livestock, the impedance of the hooves, if any, are also neglected.

3.1.4

impedance of the skin

Z_s

impedance between an electrode on the skin and the conductive tissues underneath

3.1.5

total impedance of the human body

Z_T

vectorial sum of the internal impedance and the impedances of the skin

Note 1 to entry: For the body of livestock, Z_T is the vectorial sum of the internal impedance and the impedances of the hide, skin and hooves, if any (see Figure H.1).

SEE: Figure 1.

3.1.6**impedance of the hide and skin** Z_p

impedance between an electrode on the hide and/or skin and the conductive tissues underneath

3.1.7**impedance of the hoof** Z_h

impedance between an electrode under the hoof and the conductive tissues above it

3.1.8**initial resistance of the human body** R_0

resistance limiting the peak value of the current at the moment when the touch voltage occurs

Note 1 to entry: For the body of livestock the resistance of the hide, if any, is neglected, but the resistance of the hooves, if any, are included.

3.1.9**dry condition**

condition of the skin of a surface area of contact with regard to humidity of a living person being at rest under normal indoor environmental conditions

3.1.10**water-wet condition**

condition of the skin of a surface area of contact being exposed for 1 min to water of public water supplies (average resistivity $\rho = 3\,500\ \Omega\text{cm}$, pH = 7 to 9)

3.1.11**saltwater-wet condition**

condition of the skin of a surface area of contact being exposed for 1 min to a 3 % solution of NaCl in water (average resistivity $\rho = 30\ \Omega\text{cm}$, pH = 7 to 9)

Note 1 to entry: It is assumed that saltwater-wet condition simulates the condition of the skin of a sweating person or a person after immersion in seawater. Further investigations are necessary.

3.1.12**deviation factor** F_D

total body impedance Z_T for a given percentile rank of a population divided by the total body impedance Z_T for a percentile rank of 50 % of a population at a given touch voltage

$$F_D (X\%, U_T) = \frac{Z_T (X\%, U_T)}{Z_T (50\%, U_T)}$$

3.2 Effects of sinusoidal alternating current in the range 15 Hz to 100 Hz**3.2.1****threshold of perception**

minimum value of touch current which causes any sensation for the person through which it is flowing

3.2.2**threshold of reaction**

minimum value of touch current which causes involuntary muscular contraction

3.2.3**threshold of let-go**

maximum value of touch current at which a person holding electrodes can let go of the electrodes

3.2.4**threshold of immobilization**

minimum value of current through the body of the influenced human being or livestock (or part of the human body or livestock) which causes such muscular reaction that the person or livestock cannot move voluntarily, as long as the current flows

3.2.5**threshold of ventricular fibrillation**

minimum value of touch current through the body of the human being or livestock which causes ventricular fibrillation

3.2.6**heart-current factor**

F

factor which relates the electric field strength (current density) in the heart for a given current path to the electric field strength (current density) in the heart for a touch current of equal magnitude flowing from left hand to feet

Note 1 to entry: In the heart, the current density is proportional to the electric field strength.

3.2.7**vulnerable period**

comparatively small part of the cardiac cycle during which the heart fibres are in an inhomogeneous state of excitability and ventricular fibrillation occurs if they are excited by an electric current of sufficient magnitude

Note 1 to entry: The vulnerable period corresponds to the first part of the T-wave in the electrocardiogram which is approximately 10 % of the cardiac cycle (see Figures 17 and 18).

3.3 Effects of direct current**3.3.1****total body resistance**

R_T

sum of the internal resistance of the human body and the resistances of the skin

3.3.2**DC/AC equivalence factor**

k

ratio of direct current to its equivalent RMS value of alternating current having the same probability of inducing ventricular fibrillation

Note 1 to entry: As an example for shock durations longer than the period of one cardiac cycle and 50 % probability for ventricular fibrillation, the equivalence factor for 10 s is approximately:

$$k = \frac{I_{\text{DC-fibrillation}}}{I_{\text{AC-fibrillation (RMS)}}} = \frac{300 \text{ mA}}{80 \text{ mA}} = 3,75 \text{ (see Figures 20 and 22).}$$

3.3.3**upward current**

direct touch current through the human body for which the feet represent the positive polarity

3.3.4

downward current

direct touch current through the human body for which the feet represent the negative polarity

4 Electrical impedance of the human body and livestock

4.1 General

The values of body impedance depend on a number of factors and, in particular, on current path, on touch voltage, duration of current flow, frequency, degree of moisture of the skin, surface area of contact, pressure exerted and temperature.

A schematic diagram for the impedance of the human body is shown in Figure 1.

NOTE A modelling circuit for the human body is given in Annex G.

4.2 Internal impedance of the human body (Z_i)

The internal impedance of the human body can be considered as mostly resistive. Its value depends primarily on the current path and, to a lesser extent, on the surface area of contact.

NOTE 1 Measurements indicate that a small capacitive component exists (dashed lines in Figure 1).

Figure 2 shows the internal impedance of the human body for its different parts expressed as percentages of that related to the path hand to foot.

For current paths hand to hand or hand to feet, the impedances are mainly located in the limbs (arms and legs). If the impedance of the trunk of the body is neglected, a simplified circuit diagram can be established which is shown in Figure 3.

NOTE 2 In order to simplify the circuit diagram, it is assumed that the impedance of arms and legs have the same values.

4.3 Impedance of the skin (Z_s)

The impedance of the skin can be considered as a network of resistances and capacitances. Its structure is made up of a semi-insulating layer and small conductive elements (pores). The skin impedance falls when the current is increased. Sometimes current marks are observed (see 4.7).

The value of the impedance of the skin depends on voltage, frequency, duration of the current flow, surface area of contact, pressure of contact, the degree of moisture of the skin, temperature and type of skin.

For lower touch voltages the value of the impedance of the skin varies widely, even for one person, with surface area of contact and condition (dry, wet, perspiration), temperature, rapid respiration, etc. For higher touch voltages the skin impedance decreases considerably and becomes negligible when the skin breaks down.

As regards the influence of frequency, the impedance of the skin decreases when the frequency increases.

4.4 Total impedance of the human body (Z_T)

The total impedance of the human body consists of resistive and capacitive components.

For lower touch voltages, there are considerable variations in the impedance of the skin Z_s and the total impedance of the human body Z_T similarly varies widely. For higher touch voltages, the total impedance depends less and less on the impedance of the skin and its value approaches that of the internal impedance Z_i . See Figures 4 to 9.