

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Mobile and fixed offshore units – Electrical installations –
Part 1: General requirements and conditions**

**Unités mobiles et fixes en mer – Installations électriques –
Partie 1: Exigences générales et conditions**



THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2015 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

IEC Catalogue - webstore.iec.ch/catalogue

The stand-alone application for consulting the entire bibliographical information on IEC International Standards, Technical Specifications, Technical Reports and other documents. Available for PC, Mac OS, Android Tablets and iPad.

IEC publications search - www.iec.ch/searchpub

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and also once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 30 000 terms and definitions in English and French, with equivalent terms in 15 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

More than 60 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: csc@iec.ch.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Catalogue IEC - webstore.iec.ch/catalogue

Application autonome pour consulter tous les renseignements bibliographiques sur les Normes internationales, Spécifications techniques, Rapports techniques et autres documents de l'IEC. Disponible pour PC, Mac OS, tablettes Android et iPad.

Recherche de publications IEC - www.iec.ch/searchpub

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études,...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et aussi une fois par mois par email.

Electropedia - www.electropedia.org

Le premier dictionnaire en ligne de termes électroniques et électriques. Il contient plus de 30 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans 15 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

Glossaire IEC - std.iec.ch/glossary

Plus de 60 000 entrées terminologiques électrotechniques, en anglais et en français, extraites des articles Termes et Définitions des publications IEC parues depuis 2002. Plus certaines entrées antérieures extraites des publications des CE 37, 77, 86 et CISPR de l'IEC.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: csc@iec.ch.

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Mobile and fixed offshore units – Electrical installations –
Part 1: General requirements and conditions**

**Unités mobiles et fixes en mer – Installations électriques –
Partie 1: Exigences générales et conditions**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 47.020.60

ISBN 978-2-8322-2784-8

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

| | |
|--|----|
| FOREWORD..... | 4 |
| INTRODUCTION..... | 6 |
| 1 Scope..... | 7 |
| 2 Normative references..... | 7 |
| 3 Terms and definitions..... | 8 |
| 4 General requirements and conditions | 11 |
| 4.1 General..... | 11 |
| 4.2 Acceptance of substitutes or alternatives | 12 |
| 4.3 Additions and alterations | 12 |
| 4.4 Environmental conditions..... | 12 |
| 4.4.1 General | 12 |
| 4.4.2 Design parameters..... | 12 |
| 4.5 Materials | 13 |
| 4.6 Power supply system characteristics..... | 14 |
| 4.6.1 General | 14 |
| 4.6.2 AC distribution systems..... | 14 |
| 4.6.3 DC distribution systems..... | 16 |
| 4.7 Manual disconnection..... | 17 |
| 4.8 Electrical apparatus for explosive gas atmospheres..... | 17 |
| 4.9 Clearance and creepage distances..... | 17 |
| 4.10 Insulation | 17 |
| 4.11 Maintenance and inspection | 17 |
| 4.12 Cable entries..... | 18 |
| 4.13 Precautions against vibration and mechanical shock..... | 18 |
| 4.14 Location of electrical equipment in units | 18 |
| 4.15 Mechanical protection | 18 |
| 4.16 Protection from heat, water, steam and oil..... | 18 |
| 4.17 Protection against electrical shock..... | 19 |
| 4.18 Enclosures..... | 19 |
| 4.19 Environmental impact..... | 19 |
| Annex A (informative) Degree of protection | 20 |
| A.1 Definitions of numerals in the IP code..... | 20 |
| Annex B (informative) Cold climate precautions | 22 |
| Annex C (informative) Specification of surface treatment and protective painting system..... | 23 |
| C.1 Objectives | 23 |
| C.2 General and specification | 23 |
| C.2.1 General | 23 |
| C.2.2 Atmospheric corrosivity categories for protective painting systems | 23 |
| C.2.3 Durability performance of a protective painting system | 24 |
| Annex D (informative) DC distribution systems | 26 |
| D.1 DC distribution systems..... | 26 |
| Bibliography..... | 27 |
| Figure D.1 – Typical configuration of DC distribution system..... | 26 |

| | |
|--|----|
| Table 1 – Operational design parameters – Ambient temperature | 13 |
| Table 2 – Design parameters – Relative humidity | 13 |
| Table 3 – Voltage characteristics | 15 |
| Table 4 – Frequency characteristics | 16 |
| Table 5 – Tolerances for DC system | 16 |
| Table 6 – Fast transients | 17 |
| Table A.1 – Degrees of protection against foreign objects indicated by the first characteristic numeral | 20 |
| Table A.2 – Degrees of protection against water indicated by the second characteristic numeral | 21 |
| Table C.1 – Description of typical atmospheric environments related to the estimation of corrosivity categories | 24 |

Withdrawal

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**MOBILE AND FIXED OFFSHORE UNITS –
ELECTRICAL INSTALLATIONS –****Part 1: General requirements and conditions**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61892-1 has been prepared by IEC technical committee 18: Electrical installations of ships and of mobile and fixed offshore units.

This third edition cancels and replaces the second edition published in 2010. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition.

- a) The general requirement to harmonic distortion has been changed from IEC 61000-2-4 Class 2 to Class 1.
- b) The voltage tolerance for a DC system has been changed from $\pm 10\%$ to $+10\%$, -15% .
- c) Annex C (informative) regarding specification of surface treatment and protective painting system has been added.

The text of this standard based on the following documents:

| CDV | Report on voting |
|-------------|------------------|
| 18/1385/CDV | 18/1449/RVC |

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of the IEC 61892 series can be found, under the general title *Mobile and fixed offshore units – Electrical installations*, on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

The IEC 61892 series of International Standards is intended to enable safety in the design, selection, installation, maintenance and use of electrical equipment for the generation, storage, distribution and utilization of electrical energy for all purposes in offshore units which are used for the purpose of exploration or exploitation of petroleum resources.

This part of the IEC 61892 incorporates and co-ordinates, as far as possible, existing rules and forms a code of interpretation, where applicable, of the requirements of the International Maritime Organization, a guide for future regulations which may be prepared and a statement of practice for offshore unit owners, constructors and appropriate organizations.

This standard is based on equipment and practices which are in current use, but it is not intended in any way to impede development of new or improved techniques.

The ultimate aim has been to produce a set of International Standards exclusively for the offshore petroleum industry.

Withdrawn

MOBILE AND FIXED OFFSHORE UNITS – ELECTRICAL INSTALLATIONS –

Part 1: General requirements and conditions

1 Scope

This part of IEC 61892 contains provisions for electrical installations in mobile and fixed offshore units including pipeline, pumping or 'pigging' stations, compressor stations and exposed location single buoy moorings, used in the offshore petroleum industry for drilling, processing and storage purposes.

This International Standard applies to all installations, whether permanent, temporary, transportable or hand-held, to AC installations up to and including 35 000 V and DC installations up to and including 1 500 V (AC and DC voltages are nominal values).

This standard does not apply either to fixed equipment for medical purposes or to the electrical installations of tankers.

NOTE For medical rooms, IEC 60364-7-710 provides more information.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60034 (all parts), *Rotating electrical machines*

IEC 60034-1:2010, *Rotating electrical machines – Part 1: Rating and performance*

IEC 60079 (all parts), *Explosive atmospheres*

IEC 60529, *Degrees of protection provided by enclosures (IP Code)*

IEC 61000-2-4:2002, *Electromagnetic compatibility (EMC) – Part 2-4: Environment – Compatibility levels in industrial plants for low-frequency conducted disturbances*

IEC 61140, *Protection against electric shock – Common aspects for installation and equipment*

IEC 61892-2:2012, *Mobile and fixed offshore units – Electrical installations – Part 2: System design*

IEC 61892-5, *Mobile and fixed offshore units – Electrical installations – Part 5: Mobile units*

IEC 61892-6, *Mobile and fixed offshore units – Electrical installations – Part 6: Installation*

IEC 61892-7, *Mobile and fixed offshore units – Electrical installations – Part 7: Hazardous areas*

International Convention for the Safety of Life at Sea (SOLAS):1974, Consolidated edition 2009

IMO MODU Code, *Code for the construction and equipment of mobile offshore drilling units*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

NOTE The terms and definitions included in this part are those having general application in the IEC 61892 series. Terms and definitions applying to particular apparatus or equipment are included in the other parts of IEC 61892.

3.1

appropriate authority

governmental body and/or classification society with whose rules a unit is required to comply

3.2

equipment

single apparatus or set of devices or apparatuses, or the set of main devices of an installation, or all devices necessary to perform a specific task

EXAMPLE Power transformer, measuring equipment.

[SOURCE IEC 60050-151:2001, 151-11-25, modified — The words “the equipment of a substation” has been removed from the example.]

3.3

apparatus

device or assembly of devices which can be used as an independent unit for specific functions

[SOURCE IEC 60050-151:2001, 151-11-22, modified — The note has been deleted.]

3.4

rooms with a controlled atmosphere

rooms where the temperature and humidity can be controlled within specified limits

3.5

degree of protection of enclosure

IP

numerical classification according to IEC 60529 preceded by the symbol IP applied to the enclosure of electrical apparatus to provide:

- protection of persons against contact with, or approach to, live parts and against contact with moving parts (other than smooth rotating shafts and the like) inside the enclosure,
- protection of the electrical apparatus against ingress of solid foreign objects, and
- where indicated by the classification, protection of the electrical apparatus against harmful ingress of water

Note 1 to entry: Explanation of the numerals used for classification of degree of protection is given in Tables A.1 and A.2.

[SOURCE IEC 60050-426:2008, 426-04-02, modified — Note 1 to entry has been added.]

3.6

distribution board

assembly containing different types of switchgear and controlgear associated with one or more outgoing electric circuits fed from one or more incoming electric circuits, together with terminals for the neutral and protective conductors, if required

[SOURCE IEC 60050-826:2004, 826-16-08, modified — The words “if required” have been added.]

3.7

earth

ground, US, CA

general mass of the metal structure or hull of the unit

3.8

earthed

connected to the general mass of the metal structure or hull of the unit in such a manner as will ensure at all times an immediate discharge of electrical energy without danger

3.9

essential services

services essential for the navigation, steering or manoeuvring of the mobile unit, or for the safety of human life, or for special characteristics of the unit (for example special services)

3.10

frequency

3.10.1

cyclic frequency variation

periodic deviation in frequency during normal operation such as might be caused by regularly repeated loading

$$\frac{\pm(f_{\max} - f_{\min}) \times 100}{2 f_{\text{nominal}}} \%$$

3.10.2

frequency tolerance

maximum departure from nominal frequency during normal operation conditions excluding transient and cyclic frequency variations

Note 1 to entry: Frequency tolerance is a steady state tolerance and includes variations caused by loads and governor characteristics. It also includes variations due to environmental conditions.

3.10.3

frequency transient

sudden change in frequency which goes outside the frequency tolerance limits and returns to and remains inside these limits within a specified recovery time after initiation of the disturbance (time range: seconds)

3.11

live part

conductor or conductive part intended to be energized in normal operation, including a neutral conductor, but by convention not a PEN conductor or PEM conductor or PEL conductor

Note 1 to entry: This concept does not necessarily imply a risk of electric shock.

[SOURCE IEC 60050-195:1998, 195-02-19]

3.12

PEN conductor

conductor combining the functions of both a protective earthing conductor and a neutral conductor

[SOURCE IEC 60050-195:1998, 195-02-12]

3.13**PEM conductor**

conductor combining the functions of both a protective earthing conductor and a mid-point conductor

[SOURCE IEC 60050-195:1998, 195-02-13]

3.14**PEL conductor**

conductor combining the functions of both a protective earthing conductor and a line conductor

[SOURCE IEC 60050-195:1998, 195-02-14]

3.15**petroleum**

complex mixture of hydrocarbons that occurs in the earth in liquid or gaseous forms

3.16**point <wiring>**

any termination of the fixed wiring intended for the attachment of a luminaire or for connecting to the supply of a current-using appliance

3.17**voltages****3.17.1****voltage tolerance**

maximum departure from nominal user voltage during normal operating conditions, excluding transient and cyclic voltage variations

Note 1 to entry: Voltage tolerance is a steady state tolerance and includes voltage drop in cables and voltage regulator characteristics. It also includes variations due to environmental conditions.

3.17.2**voltage unbalance tolerance**

difference between the highest and lowest phase to phase voltage

3.17.3**cyclic voltage variation**

periodic voltage deviation (max. to min. r.m.s. values) of the nominal voltage, such as might be caused by regularly repeated loading

$$\frac{\pm(U_{\max} - U_{\min}) \times 100}{2U_{\text{nominal}}} \%$$

3.17.4**voltage transient**

sudden change in voltage (excluding spikes) which goes outside the nominal voltage tolerance limits and returns to and remains inside these limits within a specified recovery time after the initiation of the disturbance (time range: seconds)

3.18**recovery time****3.18.1****voltage transient recovery time**

time elapsed from exceeding the normal voltage tolerance until the voltage recovers and remains within the normal tolerance limits

3.18.2 frequency transient recovery time

time elapsed from exceeding the normal frequency tolerance until the frequency recovers and remains within the frequency tolerance limits

3.19 waveform

3.19.1 total harmonic distortion

THD

ratio of the r.m.s. value of the sum of all the harmonic components up to a specified order (recommended notation “*H*”) to the r.m.s. value of the fundamental component

$$\text{THD} = \sqrt{\sum_{h=2}^{h=H} \frac{(Q_h)^2}{(Q_1)^2}}$$

where

Q represents either current or voltage;

*Q*₁ is the r.m.s. value of the fundamental component;

h is the harmonic order;

*Q*_{*h*} is the r.m.s. value of the harmonic component of order *h*;

H is 50 for the purpose of the compatibility levels in this standard

Note 1 to entry: THD takes account of harmonics only. For the case where interharmonics are to be included, reference is made to A.3.1 of IEC 61000-2-4:2002.

Note 2 to entry: This note applies to the French language only.

[SOURCE IEC 61000-2-4:2002, 3.2.7, modified — Note 1 to entry is modified.]

3.19.2 single harmonic content

ratio of the effective r.m.s. value of the harmonic to the r.m.s. value of the fundamental expressed in per cent

4 General requirements and conditions

4.1 General

This clause contains conditions and requirements which are common to all equipment and installations in the IEC 61892 series.

Electrical installations in units shall be such that:

- essential services will be maintained under various emergency conditions;
- the safety of crew, contractors, visitors and unit will be ensured;
- the requirements with respect to safety in this standard are considered;
- the requirements of the International Convention for the Safety of Life at Sea (SOLAS) are met as far as applicable;
- the requirements of the IMO MODU Code are met as far as applicable.

For floating and mobile units, all machinery and equipment shall operate satisfactorily under the static and dynamic inclination limits according to IEC 61892-5.