

# INTERNATIONAL STANDARD

# NORME INTERNATIONALE



**Industrial communication networks – Fieldbus specifications –  
Part 4-2: Data-link layer protocol specification – Type 2 elements**

**Réseaux de communication industriels – Spécifications des bus de terrain –  
Partie 4-2: Spécification du protocole de la couche liaison de données –  
Éléments de type 2**



**THIS PUBLICATION IS COPYRIGHT PROTECTED**  
**Copyright © 2019 IEC, Geneva, Switzerland**

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office  
3, rue de Varembe  
CH-1211 Geneva 20  
Switzerland

Tel.: +41 22 919 02 11  
[info@iec.ch](mailto:info@iec.ch)  
[www.iec.ch](http://www.iec.ch)

#### About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

#### About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

#### IEC publications search - [webstore.iec.ch/advsearchform](http://webstore.iec.ch/advsearchform)

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

#### IEC Just Published - [webstore.iec.ch/justpublished](http://webstore.iec.ch/justpublished)

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

#### IEC Customer Service Centre - [webstore.iec.ch/csc](http://webstore.iec.ch/csc)

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: [sales@iec.ch](mailto:sales@iec.ch).

#### Electropedia - [www.electropedia.org](http://www.electropedia.org)

The world's leading online dictionary on electrotechnology, containing more than 22 000 terminological entries in English and French, with equivalent terms in 16 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

#### IEC Glossary - [std.iec.ch/glossary](http://std.iec.ch/glossary)

67 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

#### A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

#### A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

#### Recherche de publications IEC - [webstore.iec.ch/advsearchform](http://webstore.iec.ch/advsearchform)

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études,...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

#### IEC Just Published - [webstore.iec.ch/justpublished](http://webstore.iec.ch/justpublished)

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et une fois par mois par email.

#### Service Clients - [webstore.iec.ch/csc](http://webstore.iec.ch/csc)

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: [sales@iec.ch](mailto:sales@iec.ch).

#### Electropedia - [www.electropedia.org](http://www.electropedia.org)

Le premier dictionnaire d'électrotechnologie en ligne au monde, avec plus de 22 000 articles terminologiques en anglais et en français, ainsi que les termes équivalents dans 16 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

#### Glossaire IEC - [std.iec.ch/glossary](http://std.iec.ch/glossary)

67 000 entrées terminologiques électrotechniques, en anglais et en français, extraites des articles Termes et Définitions des publications IEC parues depuis 2002. Plus certaines entrées antérieures extraites des publications des CE 37, 77, 86 et CISPR de l'IEC.

# INTERNATIONAL STANDARD

# NORME INTERNATIONALE



**Industrial communication networks – Fieldbus specifications –  
Part 4-2: Data-link layer protocol specification – Type 2 elements**

**Réseaux de communication industriels – Spécifications des bus de terrain –  
Partie 4-2: Spécification du protocole de la couche liaison de données –  
Éléments de type 2**

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

COMMISSION  
ELECTROTECHNIQUE  
INTERNATIONALE

ICS 25.040.40; 35.100.20; 35.110

ISBN 978-2-8322-9134-4

**Warning! Make sure that you obtained this publication from an authorized distributor.  
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

## CONTENTS

FOREWORD.....	15
INTRODUCTION.....	17
1 Scope.....	19
1.1 General.....	19
1.2 Specifications .....	19
1.3 Procedures .....	19
1.4 Applicability .....	20
1.5 Conformance .....	20
2 Normative references .....	20
3 Terms, definitions, symbols, abbreviated terms and conventions .....	22
3.1 Reference model terms and definitions .....	22
3.2 Service convention terms and definitions .....	24
3.3 Common terms and definitions.....	24
3.4 Additional Type 2 definitions .....	25
3.5 Type 2 symbols and abbreviated terms .....	33
3.6 Conventions for station management objects.....	34
4 Overview of the data-link protocol.....	35
4.1 General.....	35
4.1.1 DLL architecture .....	35
4.1.2 Access control machine (ACM) and scheduling support functions .....	36
4.1.3 Connection-mode, connectionless-mode data transfer and DL service.....	37
4.2 Services provided by the DL.....	37
4.2.1 Overview.....	37
4.2.2 QoS.....	37
4.3 Structure and definition of DL-addresses .....	38
4.3.1 General .....	38
4.3.2 MAC ID address .....	38
4.3.3 Generic tag address .....	39
4.3.4 Fixed tag address .....	39
4.4 Services assumed from the PhL.....	40
4.4.1 General requirements .....	40
4.4.2 Data encoding rules.....	41
4.4.3 DLL to PhL interface .....	41
4.5 Functional classes .....	43
5 General structure and encoding of PhIDUs and DLPDUs and related elements of procedure.....	43
5.1 Overview .....	43
5.2 Media access procedure .....	43
5.3 DLPDU structure and encoding .....	47
5.3.1 General .....	47
5.3.2 DLPDU components .....	47
5.3.3 Preamble .....	47
5.3.4 Start and end delimiters.....	47
5.3.5 DLPDU octets and ordering .....	47
5.3.6 Source MAC ID.....	48
5.3.7 Lpackets field .....	48
5.3.8 Frame check sequence (FCS).....	48

5.3.9	Null DLPDU .....	51
5.3.10	Abort DLPDU .....	51
5.4	Lpacket components .....	51
5.4.1	General Lpacket structure .....	51
5.4.2	Size .....	51
5.4.3	Control .....	52
5.4.4	Generic tag Lpackets .....	52
5.4.5	Fixed tag Lpackets .....	53
5.5	DLPDU procedures .....	53
5.5.1	General .....	53
5.5.2	Sending scheduled DLPDUs .....	54
5.5.3	Sending unscheduled DLPDUs .....	54
5.5.4	Receiving DLPDUs .....	54
5.6	Summary of DLL support services and objects .....	54
6	Specific DLPDU structure, encoding and procedures .....	56
6.1	Modeling language .....	56
6.1.1	State machine description .....	56
6.1.2	Use of DLL- prefix .....	57
6.1.3	Data types .....	57
6.2	DLS user services .....	58
6.2.1	General .....	58
6.2.2	Connected mode and connectionless mode transfer service .....	58
6.2.3	Queue maintenance service .....	60
6.2.4	Tag filter service .....	60
6.2.5	Link synchronization service .....	61
6.2.6	Synchronized parameter change service .....	61
6.2.7	Event reports service .....	62
6.2.8	Bad FCS service .....	63
6.2.9	Current moderator service .....	63
6.2.10	Power up and online services .....	64
6.2.11	Enable moderator service .....	64
6.2.12	Listen only service .....	64
6.3	Generic tag Lpacket .....	64
6.3.1	General .....	64
6.3.2	Structure of the generic-tag Lpacket .....	65
6.3.3	Sending and receiving the generic-tag Lpacket .....	65
6.4	Moderator Lpacket .....	65
6.4.1	General .....	65
6.4.2	Structure of the moderator Lpacket .....	65
6.4.3	Sending and receiving the moderator Lpacket .....	66
6.5	Time distribution Lpacket .....	67
6.5.1	General .....	67
6.5.2	Structure of the time distribution Lpacket .....	67
6.5.3	Sending and receiving the time distribution Lpacket .....	69
6.6	UCMM Lpacket .....	69
6.6.1	General .....	69
6.6.2	Structure of the UCMM Lpacket .....	69
6.6.3	Sending and receiving the UCMM Lpacket .....	69

6.7	Keeper UCMM Lpacket .....	69
6.7.1	General .....	69
6.7.2	Structure of the Keeper UCMM Lpacket .....	70
6.7.3	Sending and receiving the Keeper UCMM Lpacket .....	70
6.8	TUI Lpacket .....	70
6.8.1	General .....	70
6.8.2	Structure of the TUI Lpacket .....	70
6.8.3	Sending and receiving the TUI Lpacket .....	71
6.9	Link parameters Lpacket and tMinus Lpacket .....	71
6.9.1	General .....	71
6.9.2	Structure of link parameters and tMinus Lpackets .....	72
6.9.3	Sending and receiving the tMinus and Link parameters Lpackets .....	72
6.10	I'm-alive Lpacket .....	73
6.10.1	General .....	73
6.10.2	Structure or the I'm-alive Lpacket .....	73
6.10.3	Sending and receiving I'm Alive .....	73
6.10.4	I'm alive state processing .....	73
6.11	Ping Lpackets .....	74
6.11.1	General .....	74
6.11.2	Structure of the ping Lpackets .....	75
6.11.3	Sending and receiving the ping Lpackets .....	75
6.12	WAMI Lpacket .....	76
6.12.1	General .....	76
6.12.2	Structure of the WAMI Lpacket .....	76
6.12.3	Sending and receiving the WAMI Lpacket .....	76
6.13	Debug Lpacket .....	76
6.14	IP Lpacket .....	77
6.15	Ethernet Lpacket .....	77
7	Objects for station management .....	77
7.1	General .....	77
7.2	ControlNet™ object .....	79
7.2.1	Overview .....	79
7.2.2	Class attributes .....	79
7.2.3	Instance attributes .....	79
7.2.4	Common services .....	87
7.2.5	Class specific services .....	88
7.2.6	Behavior .....	89
7.2.7	Module status indicator .....	89
7.3	Keeper object .....	90
7.3.1	Overview .....	90
7.3.2	Revision history .....	90
7.3.3	Class attributes .....	90
7.3.4	Instance attributes .....	90
7.3.5	Common services .....	98
7.3.6	Class specific services .....	99
7.3.7	Service error codes .....	105
7.3.8	Behavior .....	106
7.3.9	Miscellaneous notes .....	107
7.3.10	Keeper power up sequence .....	108

7.4	Scheduling object .....	113
7.4.1	Overview .....	113
7.4.2	Class attributes .....	114
7.4.3	Instance attributes .....	114
7.4.4	Common services .....	115
7.4.5	Class specific services .....	117
7.4.6	Typical scheduling session .....	123
7.5	TCP/IP Interface object .....	124
7.5.1	Overview .....	124
7.5.2	Revision history .....	124
7.5.3	Class attributes .....	125
7.5.4	Instance attributes .....	125
7.5.5	Common services .....	139
7.5.6	Class specific services .....	141
7.5.7	Behavior .....	142
7.5.8	Address Conflict Detection (ACD) .....	144
7.6	Ethernet link object .....	150
7.6.1	Overview .....	150
7.6.2	Revision history .....	150
7.6.3	Class attributes .....	150
7.6.4	Instance attributes .....	151
7.6.5	Common services .....	161
7.6.6	Class specific services .....	163
7.6.7	Behavior .....	163
7.7	DeviceNet™ object .....	164
7.7.1	Overview .....	164
7.7.2	Revision history .....	164
7.7.3	Class attributes .....	165
7.7.4	Instance attributes .....	165
7.7.5	Common services .....	172
7.7.6	Class specific services .....	173
7.8	Connection configuration object (CCO) .....	173
7.8.1	Overview .....	173
7.8.2	Revision history .....	174
7.8.3	Class attributes .....	174
7.8.4	Instance attributes .....	176
7.8.5	Connection Configuration Object change control .....	185
7.8.6	Common services .....	185
7.8.7	Class specific services .....	192
7.8.8	Behavior .....	195
7.9	DLR object .....	196
7.9.1	Overview .....	196
7.9.2	Revision history .....	196
7.9.3	Class attributes .....	197
7.9.4	Instance attributes .....	197
7.9.5	Common services .....	208
7.9.6	Class specific services .....	212
7.10	QoS object .....	213
7.10.1	Overview .....	213

7.10.2	Revision History .....	213
7.10.3	Class attributes .....	213
7.10.4	Instance Attributes.....	214
7.10.5	Common services .....	215
7.10.6	Get_Attributes_All response (class level).....	216
7.11	Port object .....	216
7.11.1	Overview .....	216
7.11.2	Revision History .....	216
7.11.3	Class attributes .....	217
7.11.4	Instance attributes .....	217
7.11.5	Common services .....	223
7.12	PRP/HSR Protocol object.....	224
7.12.1	Overview .....	224
7.12.2	Revision history .....	224
7.12.3	Class attributes .....	225
7.12.4	Instance attributes .....	225
7.12.5	Common Services .....	232
7.13	PRP/HSR Nodes Table object.....	234
7.13.1	Overview .....	234
7.13.2	Revision history .....	234
7.13.3	Class attributes .....	234
7.13.4	Instance attributes .....	234
7.13.5	Common services .....	237
8	Other DLE elements of procedure .....	237
8.1	Network attachment monitor (NAM).....	237
8.1.1	General .....	237
8.1.2	Default parameters .....	238
8.1.3	Auto-addressing .....	239
8.1.4	Valid MAC IDs.....	239
8.1.5	State machine description .....	239
8.2	Calculating link parameters.....	245
8.2.1	Link parameters.....	245
8.2.2	Conditions affecting link parameters .....	246
8.2.3	Moderator change.....	246
8.2.4	NUT timing .....	246
8.2.5	Slot timing .....	248
8.2.6	Blanking .....	248
8.2.7	Example implementation.....	249
9	Detailed specification of DL components .....	253
9.1	General.....	253
9.2	Access control machine (ACM) .....	253
9.3	TxLLC.....	273
9.4	RxLLC .....	277
9.5	Transmit machine (TxM) .....	281
9.6	Receive machine (RxM) .....	285
9.7	Serializer .....	291
9.8	Deserializer .....	293
9.8.1	Octet construction .....	293
9.8.2	FCS checking .....	293

9.8.3	End of DLPDU processing .....	294
9.9	DLL management.....	294
10	Device Level Ring (DLR) protocol.....	296
10.1	General.....	296
10.2	Support for Multiple DLR Ring Pairs.....	296
10.3	Supported topologies .....	297
10.4	Overview of DLR operation .....	298
10.4.1	Normal operation .....	298
10.4.2	Link failures.....	300
10.5	Classes of DLR implementation .....	301
10.6	DLR behavior.....	302
10.6.1	DLR variables.....	302
10.6.2	Ring supervisor .....	302
10.6.3	Ring node.....	305
10.6.4	Sign on process.....	306
10.6.5	Neighbor check process .....	307
10.7	Implementation requirements.....	307
10.7.1	Embedded switch requirements and recommendations.....	307
10.7.2	DLR implementation requirements.....	308
10.7.3	IEC 61588 and CP 2/2.1 considerations.....	309
10.7.4	IEEE 802.1D/IEEE 802.1Q STP/RSTP/MSTP considerations.....	309
10.8	Using non-DLR nodes in the ring network .....	309
10.8.1	General considerations.....	309
10.8.2	Non-DLR end devices.....	310
10.8.3	Non-DLR switches.....	310
10.9	Redundant gateway devices on DLR network.....	313
10.9.1	General .....	313
10.9.2	Supported topologies.....	313
10.9.3	Redundant gateway capable device.....	314
10.9.4	Redundant gateway device behavior .....	314
10.10	DLR messages .....	317
10.10.1	General .....	317
10.10.2	Common frame header .....	318
10.10.3	Beacon frame .....	319
10.10.4	Neighbor_Check request .....	319
10.10.5	Neighbor_Check_response.....	320
10.10.6	Link_Status/Neighbor_Status.....	320
10.10.7	Locate_Fault.....	321
10.10.8	Announce .....	321
10.10.9	Sign_On .....	321
10.10.10	Advertise .....	322
10.10.11	Flush_Tables.....	322
10.10.12	Learning_Update .....	323
10.11	State diagrams and state-event-action matrices.....	323
10.11.1	Beacon-based ring node.....	323
10.11.2	Announce-based ring node .....	330
10.11.3	Ring supervisor .....	334
10.11.4	Redundant gateway.....	349

10.12	Performance analysis .....	354
10.12.1	General .....	354
10.12.2	Redundant gateway switchover performance .....	358
11	PRP and HSR redundancy protocols .....	359
11.1	General.....	359
11.2	PRP overview .....	360
11.2.1	General .....	360
11.2.2	Address Conflict Detection (ACD).....	361
11.3	HSR overview .....	362
Annex A (normative)	Indicators and switches .....	364
A.1	Purpose .....	364
A.2	Indicators.....	364
A.2.1	General indicator requirements.....	364
A.2.2	Common indicator requirements .....	364
A.2.3	Fieldbus specific indicator requirements – option 1.....	366
A.2.4	Fieldbus specific indicator requirements – option 2.....	370
A.2.5	Fieldbus specific indicator requirements – option 3.....	374
A.3	Switches .....	378
A.3.1	Common switch requirements.....	378
A.3.2	Fieldbus specific switch requirements – option 1 .....	378
A.3.3	Fieldbus specific switch requirements – option 2 .....	378
A.3.4	Fieldbus specific switch requirements – option 3 .....	379
Bibliography	.....	380
Figure 1	– Data-link layer internal architecture .....	36
Figure 2	– Relationships of DLSAPs, DLSAP-addresses, and group DL-addresses.....	38
Figure 3	– Basic structure of a MAC ID address.....	39
Figure 4	– Basic structure of a generic tag address .....	39
Figure 5	– Basic structure of a fixed tag address .....	39
Figure 6	– M <sub>s</sub> symbols and Manchester encoding at 5 MHz .....	41
Figure 7	– NUT structure .....	44
Figure 8	– Media access during scheduled time .....	45
Figure 9	– Media access during unscheduled time .....	46
Figure 10	– DLPDU format.....	47
Figure 11	– Aborting a DLPDU during transmission .....	51
Figure 12	– Lpacket format .....	51
Figure 13	– Generic tag Lpacket format .....	52
Figure 14	– Fixed tag Lpacket format.....	53
Figure 15	– Goodness parameter of TimeDist_Lpacket.....	68
Figure 16	– Example I'm alive processing algorithm.....	74
Figure 17	– Keeper CRC algorithm .....	96
Figure 18	– Keeper object power-up state diagram .....	109
Figure 19	– Keeper object operating state diagram .....	110
Figure 20	– Synchronized network change processing .....	113
Figure 21	– State transition diagram for TCP/IP Interface object.....	143
Figure 22	– State transition diagram for TCP/IP Interface object.....	144

Figure 23 – ACD Behavior .....	146
Figure 24 – State transition diagram for Ethernet Link object .....	164
Figure 25 – Connection configuration object edit flowchart.....	196
Figure 26 – NAM state machine .....	238
Figure 27 – Devices with Multiple DLR Ring Pairs.....	297
Figure 28 – DLR rings connected to switches.....	298
Figure 29 – Normal operation of a DLR network.....	299
Figure 30 – Beacon and Announce frames.....	299
Figure 31 – Link failure .....	300
Figure 32 – Network reconfiguration after link failure .....	301
Figure 33 – Neighbor Check process .....	307
Figure 34 – Unsupported topology – example 1 .....	311
Figure 35 – Unsupported topology – example 2 .....	311
Figure 36 – DLR ring connected to switches through redundant gateways.....	313
Figure 37 – DLR redundant gateway capable device.....	314
Figure 38 – Advertise frame.....	316
Figure 39 – State transition diagram for Beacon frame based non-supervisor ring node.....	324
Figure 40 – State transition diagram for Announce frame based non-supervisor ring node .....	330
Figure 41 – State transition diagram for ring supervisor .....	335
Figure 42 – State transition diagram for redundant gateway.....	350
Figure 43 – PRP network.....	360
Figure 44 – Directly Attached SANs.....	361
Figure 45 – Virtual DANs .....	362
Figure 46 – HSR network.....	362
Figure A.1 – Non redundant network status indicator labeling .....	370
Figure A.2 – Redundant network status indicator labeling .....	370
Figure A.3 – Network status indicator state diagram .....	373
Figure A.4 – Examples of multiple network status indicators .....	373
Table 1 – Format of attribute tables .....	34
Table 2 – Data-link layer components .....	35
Table 3 – MAC ID addresses allocation .....	39
Table 4 – Fixed tag service definitions .....	40
Table 5 – Data encoding rules .....	41
Table 6 – M Data symbols .....	42
Table 7 – Truth table for ph_status_indication.....	42
Table 8 – FCS length, polynomials and constants .....	49
Table 9 – DLL support services and objects.....	55
Table 10 – Elementary data types.....	58
Table 11 – DLL events.....	63
Table 12 – Time distribution priority .....	68
Table 13 – Format of the TUI Lpacket.....	71

Table 14 – ControlNet object class attributes ..... 79

Table 15 – ControlNet object instance attributes ..... 80

Table 16 – TUI status flag bits ..... 84

Table 17 – Mac\_ver bits ..... 85

Table 18 – Channel state bits ..... 85

Table 19 – ControlNet object common services ..... 87

Table 20 – ControlNet object class specific services ..... 88

Table 21 – Keeper object revision history ..... 90

Table 22 – Keeper object class attributes ..... 90

Table 23 – Keeper object instance attributes ..... 91

Table 24 – Keeper operating state definitions ..... 94

Table 25 – Port status flag bit definitions ..... 94

Table 26 – TUI status flag bits ..... 95

Table 27 – Keeper attributes ..... 97

Table 28 – Memory requirements (in octets) for the Keeper attributes ..... 98

Table 29 – Keeper object common services ..... 98

Table 30 – Keeper object class specific services ..... 100

Table 31 – Service error codes ..... 101

Table 32 – Wire order format of the TUI Lpacket ..... 105

Table 33 – Service error codes ..... 106

Table 34 – Keeper object operating states ..... 107

Table 35 – Keeper object state event matrix ..... 111

Table 36 – Scheduling object class attributes ..... 114

Table 37 – Scheduling object instance attributes ..... 115

Table 38 – Scheduling object common services ..... 115

Table 39 – Status error descriptions for Create ..... 116

Table 40 – Status error descriptions for Delete and Kick\_Timer ..... 117

Table 41 – Scheduling object class specific services ..... 117

Table 42 – Status error descriptions for Read ..... 119

Table 43 – Status error descriptions for Conditional\_Write ..... 120

Table 44 – Status error descriptions for Forced\_Write ..... 120

Table 45 – Status error descriptions for Change\_Start ..... 121

Table 46 – Status error descriptions for Break\_Connections ..... 122

Table 47 – Status error descriptions for Change\_Complete ..... 122

Table 48 – Status error descriptions for Restart\_Connections ..... 123

Table 49 – Revision history ..... 124

Table 50 – TCP/IP Interface object class attributes ..... 125

Table 51 – TCP/IP Interface object instance attributes ..... 126

Table 52 – Status bits ..... 129

Table 53 – Configuration capability bits ..... 130

Table 54 – Configuration control bits ..... 131

Table 55 – Example path ..... 132

Table 56 – Interface configuration components ..... 133

Table 57 – Alloc control values .....	135
Table 58 – AcdActivity values .....	136
Table 59 – ArpPdu – ARP Response PDU in binary format .....	136
Table 60 – Admin Capability member bit definitions .....	137
Table 61 – Admin Capability member bit definitions .....	138
Table 62 – TCP/IP Interface object common services .....	139
Table 63 – Get_Attributes_All reply format.....	140
Table 64 – TCP/IP Interface object class specific services.....	141
Table 65 – Set_Port_Admin_State service request parameters .....	141
Table 66 – Set_Protocol_Admin_State service request parameters.....	142
Table 67 – Class specific error codes .....	142
Table 68 – Ethernet link object revision history .....	150
Table 69 – Ethernet link object class attributes .....	151
Table 70 – Ethernet link object instance attributes .....	151
Table 71 – Interface flags bits.....	157
Table 72 – Control bits.....	158
Table 73 – Interface type .....	159
Table 74 – Interface state .....	159
Table 75 – Admin state .....	159
Table 76 – Capability Bits .....	160
Table 77 – Ethernet Link object common services.....	161
Table 78 – Get_Attributes_All reply format.....	162
Table 79 – Ethernet Link object class specific services .....	163
Table 80 – DeviceNet object revision history.....	165
Table 81 – DeviceNet object class attributes.....	165
Table 82 – DeviceNet object instance attributes.....	166
Table 83 – Bit rate attribute values .....	168
Table 84 – BOI attribute values.....	169
Table 85 – Diagnostic counters bit description .....	171
Table 86 – DeviceNet object common services .....	172
Table 87 – Reset service parameter .....	172
Table 88 – Reset service parameter values .....	172
Table 89 – DeviceNet object class specific services.....	173
Table 90 – Connection configuration object revision history .....	174
Table 91 – Connection configuration object class attributes .....	174
Table 92 – Format number values.....	176
Table 93 – Connection configuration object instance attributes .....	176
Table 94 – Originator connection status values .....	180
Table 95 – Target connection status values .....	181
Table 96 – Connection flags .....	181
Table 97 – I/O mapping formats.....	183
Table 98 – Services valid during a change operation .....	185
Table 99 – Connection configuration object common services.....	186

Table 100 – Get_Attributes_All Response – class level.....	186
Table 101 – Get_Attributes_All response – instance level.....	187
Table 102 – Set_Attributes_All error codes.....	188
Table 103 – Set_Attributes_All request.....	189
Table 104 – Create request parameters.....	190
Table 105 – Create error codes.....	191
Table 106 – Delete error codes.....	191
Table 107 – Restore error codes.....	192
Table 108 – Connection configuration object class specific services.....	192
Table 109 – Change_Start error codes.....	193
Table 110 – Get_Status service parameter.....	193
Table 111 – Get_Status service response.....	194
Table 112 – Get_Status service error codes.....	194
Table 113 – Change_Complete service parameter.....	194
Table 114 – Change_Complete service error codes.....	195
Table 115 – Audit_Changes service parameter.....	195
Table 116 – Audit_Changes service error codes.....	195
Table 117 – Revision history.....	197
Table 118 – DLR object class attributes.....	197
Table 119 – DLR object instance attributes.....	198
Table 120 – Network Status values.....	201
Table 121 – Ring Supervisor Status values.....	201
Table 122 – Capability flags.....	205
Table 123 – Redundant Gateway Status values.....	207
Table 124 – DLR object common services.....	208
Table 125 – Get_Attributes_All Response – Object Revision 1, non supervisor device.....	209
Table 126 – Get_Attributes_All Response – Object Revision 1, supervisor-capable device.....	210
Table 127 – Get_Attributes_All Response – Object Revision 2, non supervisor device.....	210
Table 128 – Get_Attributes_All Response – All other cases.....	211
Table 129 – DLR object class specific services.....	212
Table 130 – QoS object revision history.....	213
Table 131 – QoS object class attributes.....	214
Table 132 – QoS object instance attributes.....	214
Table 133 – Default DCSP values and usages.....	215
Table 134 – QoS object common services.....	216
Table 135 – Port object revision history.....	217
Table 136 – Port object class attributes.....	217
Table 137 – Port object instance attributes.....	218
Table 138 – Port Type and associated Link Object classes and Port Type Name values.....	220
Table 139 – Port Routing Capabilities attribute bit definitions.....	222
Table 140 – Port object common services.....	223
Table 141 – Get_Attributes_All response– class level.....	224

Table 142 – Get_Attributes_All response– instance level .....	224
Table 143 – Revision history .....	225
Table 144 – Class attributes .....	225
Table 145 – Instance attributes .....	226
Table 146 – Node Type .....	229
Table 147 – Switching Node .....	230
Table 148 – HSR Mode .....	230
Table 149 – RedBox ID .....	231
Table 150 – PRP/HSR Protocol object common services .....	232
Table 151 – Get_Attributes_All response .....	233
Table 152 – Revision history .....	234
Table 153 – Class attributes .....	234
Table 154 – Instance attributes .....	235
Table 155 – Remote Node Type .....	236
Table 156 – PRP/HSR Nodes Tables object common services .....	237
Table 157 – Get_Attributes_All response .....	237
Table 158 – NAM states .....	238
Table 159 – Default link parameters .....	239
Table 160 – PhL timing characteristics .....	246
Table 161 – DLR variables .....	302
Table 162 – DLR Link speed and duplex requirements .....	308
Table 163 – Redundant gateway variables .....	315
Table 164 – MAC addresses for DLR messages .....	318
Table 165 – IEEE 802.1Q common frame header format .....	318
Table 166 – DLR message payload fields .....	318
Table 167 – DLR frame types .....	319
Table 168 – Format of the Beacon frame .....	319
Table 169 – Ring State values .....	319
Table 170 – Format of the Neighbor_Check request .....	320
Table 171 – Format of the Neighbor_Check response .....	320
Table 172 – Format of the Link_Status/Neighbor_Status frame .....	320
Table 173 – Link/Neighbor status values .....	321
Table 174 – Format of the Locate_Fault frame .....	321
Table 175 – Format of the Announce frame .....	321
Table 176 – Format of the Sign_On frame .....	322
Table 177 – Format of the Advertise frame .....	322
Table 178 – Gateway state values .....	322
Table 179 – Format of the Flush_Tables frame .....	323
Table 180 – Format of the Learning_Update frame .....	323
Table 181 – Parameter values for Beacon frame based non-supervisor ring node .....	324
Table 182 – LastBcnRcvPort bit definitions .....	325
Table 183 – State-event-action matrix for Beacon frame based non-supervisor ring node .....	325

Table 184 – Parameter values for Announce frame based non-supervisor ring node .....	331
Table 185 – State-event-action matrix for Announce frame based non-supervisor ring node .....	332
Table 186 – Parameter values for ring supervisor node .....	336
Table 187 – LastBcnRcvPort bit definitions .....	337
Table 188 – State-event-action matrix for ring supervisor node .....	337
Table 189 – Parameter values for redundant gateway node .....	350
Table 190 – State-event-action matrix for redundant gateway node .....	352
Table 191 – Parameters/assumptions for example performance calculations .....	354
Table 192 – Example ring configuration parameters and performance .....	358
Table 193 – Variables for performance analysis .....	358
Table A.1 – Module status indicator .....	365
Table A.2 – Time Sync status indication .....	366
Table A.3 – Network status indicators .....	368
Table A.4 – Network status indicator .....	372
Table A.5 – Network status indicator .....	375
Table A.6 – Combined module/network status indicator .....	376
Table A.7 – I/O status indicator .....	377
Table A.8 – Bit rate switch encoding .....	379

Withholding

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

**INDUSTRIAL COMMUNICATION NETWORKS –  
FIELDBUS SPECIFICATIONS –****Part 4-2: Data-link layer protocol specification –  
Type 2 elements**

## FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

Attention is drawn to the fact that the use of the associated protocol type is restricted by its intellectual-property-right holders. In all cases, the commitment to limited release of intellectual-property-rights made by the holders of those rights permits a layer protocol type to be used with other layer protocols of the same type, or in other type combinations explicitly authorized by its intellectual-property-right holders.

NOTE Combinations of protocol types are specified in IEC 61784-1 and IEC 61784-2.

International Standard IEC 61158-4-2 has been prepared by subcommittee 65C: Industrial networks, of IEC technical committee 65: Industrial-process measurement, control and automation.

This fourth edition cancels and replaces the third edition published in 2014. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- clarifications of ControlNet object in 7.2;
- extensions and clarifications of TCP/IP interface object in 7.5;
- extensions and clarifications of Ethernet Link object in 7.6;
- clarifications of DeviceNet object in 7.7;
- extensions and clarifications of CCO object in 7.8;
- extensions and clarifications of DLR object in 7.9;
- extensions and clarifications of Port object in 7.11;
- addition of PRP/HSR Protocol and PRP/HSR Nodes Table objects in 7.12 and 7.13;
- extensions and clarifications of DLR protocol in Clause 10;
- addition of PRP/HSR protocol mapping in Clause 11;
- update of indicator behaviour in A.2.2 and A.2.4;
- miscellaneous editorial corrections.

The text of this International Standard is based on the following documents:

FDIS	Report on Voting
65C/946/FDIS	65C/955/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with ISO/IEC Directives, Part 2.

A list of all parts of the IEC 61158 series, published under the general title *Industrial communication networks – Fieldbus specifications*, can be found on the IEC web site.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed;
- withdrawn;
- replaced by a revised edition, or
- amended.

**IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.**

## INTRODUCTION

This part of IEC 61158 is one of a series produced to facilitate the interconnection of automation system components. It is related to other standards in the set as defined by the “three-layer” fieldbus reference model described in IEC 61158-1.

The data-link protocol provides the data-link service by making use of the services available from the physical layer. The primary aim of this document is to provide a set of rules for communication expressed in terms of the procedures to be carried out by peer data-link entities (DLEs) at the time of communication. These rules for communication are intended to provide a sound basis for development in order to serve a variety of purposes:

- a) as a guide for implementers and designers;
- b) for use in the testing and procurement of equipment;
- c) as part of an agreement for the admittance of systems into the open systems environment;
- d) as a refinement to the understanding of time-critical communications within OSI.

This document is concerned, in particular, with the communication and interworking of sensors, effectors and other automation devices. By using this document together with other standards positioned within the OSI or fieldbus reference models, otherwise incompatible systems may work together in any combination.

The International Electrotechnical Commission (IEC) draws attention to the fact that it is claimed that compliance with this document may involve the use of patents given in several subclauses as indicated in the table below. These patents are held by their respective inventors under license to ODVA, Inc:

US 5,400,331	[ODVA]	Communication network interface with screeners for incoming messages	Subclause 3.4, Clauses 4 to 9
US 5,471,461	[ODVA]	Digital communication network with a moderator station election process	
US 5,491,531	[ODVA]	Media access controller with a shared class message delivery capability	
US 5,493,571	[ODVA]	Apparatus and method for digital communications with improved delimiter detection	
US 5,537,549	[ODVA]	Communication network with time coordinated station activity by time slot and periodic interval number	
US 5,553,095	[ODVA]	Method and apparatus for exchanging different classes of data during different time intervals	
US 8,244,838	[ODVA]	Industrial controller employing the network ring topology	Clause 10

IEC takes no position concerning the evidence, validity and scope of these patent rights.

ODVA and the holders of these patent rights have assured the IEC that ODVA is willing to negotiate licences either free of charge or under reasonable and non-discriminatory terms and conditions with applicants throughout the world. In this respect, the statement of ODVA and the holders of these patent rights is registered with IEC. Information may be obtained from:

[ODVA] ODVA, Inc.  
2370 East Stadium Boulevard #1000  
Ann Arbor, Michigan 48104  
USA  
Attention: Office of the Executive Director  
e-mail: [odva@odva.org](mailto:odva@odva.org)

ISO ([www.iso.org/patents](http://www.iso.org/patents)) and IEC (<http://patents.iec.ch>) maintain on-line databases of patents relevant to their standards. Users are encouraged to consult the databases for the most up to date information concerning patents.

Withdrawn