

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Enterprise business function interfaces for utility operations –
Part 9: Interfaces for meter reading and control**

**Interfaces de fonctions métier d'entreprise pour l'exploitation des services –
Partie 9: Interfaces pour le relevé et la commande des compteurs**



THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2024 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Secretariat
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Discover our powerful search engine and read freely all the publications previews, graphical symbols and the glossary. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 500 terminological entries in English and French, with equivalent terms in 25 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Recherche de publications IEC -

webstore.iec.ch/advsearchform

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études, ...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et une fois par mois par email.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Découvrez notre puissant moteur de recherche et consultez gratuitement tous les aperçus des publications, symboles graphiques et le glossaire. Avec un abonnement, vous aurez toujours accès à un contenu à jour adapté à vos besoins.

Electropedia - www.electropedia.org

Le premier dictionnaire d'électrotechnologie en ligne au monde, avec plus de 22 500 articles terminologiques en anglais et en français, ainsi que les termes équivalents dans 25 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.



IEC 61968-9

Edition 3.0 2024-07

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Enterprise business function interfaces for utility operations –
Part 9: Interfaces for meter reading and control**

**Interfaces de fonctions métier d'entreprise pour l'exploitation des services –
Partie 9: Interfaces pour le relevé et la commande des compteurs**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 33.200

ISBN 978-2-8322-9296-9

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

| | |
|---|----|
| FOREWORD..... | 13 |
| INTRODUCTION..... | 16 |
| 1 Scope..... | 17 |
| 2 Normative references | 18 |
| 3 Terms, definitions and abbreviated terms | 19 |
| 3.1 Terms and definitions..... | 19 |
| 3.2 Abbreviated terms..... | 21 |
| 4 Reference and information models | 21 |
| 4.1 General approach to messaging..... | 21 |
| 4.2 General approach to metering systems | 22 |
| 4.3 Meter reading and control functions and components..... | 22 |
| 4.4 Static information model | 23 |
| 4.4.1 General | 23 |
| 4.4.2 Classes for meter reading and control | 24 |
| 4.4.3 Classes related to meter reading and control..... | 26 |
| 5 Meter reading and control message types..... | 27 |
| 5.1 General..... | 27 |
| 5.2 End device event messages..... | 28 |
| 5.2.1 General | 28 |
| 5.2.2 Applications..... | 28 |
| 5.2.3 Message format..... | 33 |
| 5.3 Meter reading messages..... | 35 |
| 5.3.1 General | 35 |
| 5.3.2 Applications..... | 36 |
| 5.3.3 Message formats | 41 |
| 5.4 End device control messages..... | 54 |
| 5.4.1 General | 54 |
| 5.4.2 Applications..... | 54 |
| 5.4.3 Message format..... | 61 |
| 5.5 Meter service requests..... | 65 |
| 5.5.1 General | 65 |
| 5.6 Metering system events | 66 |
| 5.6.1 General | 66 |
| 5.6.2 Applications – Firmware upgrade..... | 67 |
| 5.6.3 Message formats | 67 |
| 5.7 Premises area networks..... | 67 |
| 5.7.1 General | 67 |
| 5.7.2 Applications..... | 68 |
| 5.7.3 Message formats | 70 |
| 5.8 Master data management messages | 70 |
| 5.8.1 General | 70 |
| 5.8.2 Applications..... | 71 |
| 5.8.3 Message formats | 74 |
| Annex A (informative) Recommended use of message type verbs..... | 84 |
| Annex B (informative) Reply error codes..... | 88 |
| Annex C (normative) Procedure for the generation of a ReadingType name..... | 89 |

| | | |
|---------|---|-----|
| C.1 | General..... | 89 |
| C.2 | Understanding the important attributes of a data element name | 89 |
| C.2.1 | General | 89 |
| C.2.2 | Attribute #1, macroPeriod | 89 |
| C.2.3 | Attribute #2, aggregate | 90 |
| C.2.4 | Attribute #3, measuringPeriod | 91 |
| C.2.5 | Attribute #4, accumulation | 94 |
| C.2.6 | Attribute #5, flowDirection..... | 97 |
| C.2.7 | Attribute #6, commodity | 104 |
| C.2.8 | Attribute #7, measurementKind..... | 106 |
| C.2.9 | Attribute #8, interharmonicNumerator | 113 |
| C.2.10 | Attribute #9, interharmonicDenominator | 113 |
| C.2.11 | Attribute #10, argumentNumerator | 114 |
| C.2.12 | Attribute #11, argumentDenominator | 114 |
| C.2.13 | Attribute #12, tou..... | 116 |
| C.2.14 | Attribute #13, cpp | 116 |
| C.2.15 | Attribute #14, consumptionTier | 117 |
| C.2.16 | Attribute #15, phases..... | 118 |
| C.2.17 | Attribute #16, multiplier..... | 122 |
| C.2.18 | Attribute #17, unit | 123 |
| C.2.19 | Attribute #18, currency | 140 |
| C.3 | Using data element attributes to define the ReadingType name – Construction formula with example ReadingType codes | 140 |
| Annex D | (normative) Quality code enumerations..... | 146 |
| D.1 | General..... | 146 |
| D.2 | Identification of the system offering commentary on the data | 146 |
| D.3 | Construction | 146 |
| D.4 | Quality code system identifier | 146 |
| D.5 | Quality code categorization..... | 147 |
| D.6 | Quality code index | 148 |
| D.7 | Example quality codes | 158 |
| Annex E | (normative) EndDeviceEventType enumerations | 160 |
| E.1 | General..... | 160 |
| E.2 | Alarm conditions | 160 |
| E.2.1 | General | 160 |
| E.2.2 | Clearing alarm conditions and communicating state/condition changes..... | 160 |
| E.3 | Event data | 161 |
| E.4 | The 4-Part ID: EndDeviceEventType..... | 163 |
| E.5 | EndDeviceType..... | 163 |
| E.6 | EndDeviceDomain | 165 |
| E.7 | EndDeviceSubDomain | 166 |
| E.8 | EndDeviceEventOrAction..... | 172 |
| E.9 | Normative EndDeviceEventTypes | 180 |
| Annex F | (normative) EndDeviceControlType enumerations..... | 201 |
| F.1 | General..... | 201 |
| F.2 | Normative EndDeviceControlType Enumerations | 201 |
| Annex G | (normative) XML schemas for message payloads | 204 |
| G.1 | General..... | 204 |
| G.2 | ComModuleConfig | 204 |

| | | |
|---------|---|-----|
| G.3 | EndDeviceConfig | 204 |
| G.4 | EndDeviceControls | 204 |
| G.5 | EndDeviceEvents..... | 204 |
| G.6 | GetComModuleConfig..... | 205 |
| G.7 | GetEndDeviceConfig..... | 205 |
| G.8 | GetEndDeviceControls..... | 205 |
| G.9 | GetEndDeviceEvents | 205 |
| G.10 | GetEndDeviceGroups | 205 |
| G.11 | GetMeterConfig | 205 |
| G.12 | GetMeterReadings | 205 |
| G.13 | GetMeterReadSchedules | 205 |
| G.14 | GetUsagePointConfig | 206 |
| G.15 | GetUsagePointGroups | 206 |
| G.16 | GetUsagePointLocationConfig | 206 |
| G.17 | MasterDataLinkageConfig..... | 206 |
| G.18 | MeterConfig | 206 |
| G.19 | MeterReadings | 206 |
| G.20 | MeterReadSchedules..... | 206 |
| G.21 | UsagePointConfig..... | 206 |
| G.22 | UsagePointGroups..... | 207 |
| G.23 | UsagePointLocationConfig..... | 207 |
| Annex H | (normative) Querying data using Get profiles..... | 208 |
| H.1 | General..... | 208 |
| H.2 | GetMeterReadings..... | 208 |
| H.3 | GetEndDeviceConfig..... | 209 |
| Annex I | (informative) Master data management transaction processing | 211 |
| Annex J | (informative) Master data management use cases | 212 |
| J.1 | General..... | 212 |
| J.2 | Sample XML for Exemplary Master Data Management use cases | 228 |
| J.2.1 | General | 228 |
| J.2.2 | Create MeterConfig – Two Meters – Step 1 | 229 |
| J.2.3 | Create MeterConfig – Two Meters – Step 2 | 231 |
| J.2.4 | Create MeterConfig – Two Meters – Step 3 | 231 |
| J.2.5 | Create MeterConfig – Two Meters – Step 4 | 232 |
| J.2.6 | Update MeterConfig (add MeterMultipliers, modify formNumber and ConfigurationEvent) – Step 1..... | 233 |
| J.2.7 | Update MeterConfig (add MeterMultipliers, modify formNumber and ConfigurationEvent) – Step 2..... | 235 |
| J.2.8 | Update MeterConfig (add MeterMultipliers, modify formNumber and ConfigurationEvent) – Step 3..... | 236 |
| J.2.9 | UpdateMeterConfig (add MeterMultipliers, modify formNumber and ConfigurationEvent) – Step 4..... | 237 |
| J.2.10 | Update MeterConfig (delete details) – Step 1..... | 238 |
| J.2.11 | Update MeterConfig (delete details) – Step 2..... | 239 |
| J.2.12 | Update MeterConfig (delete details) – Step 3..... | 240 |
| J.2.13 | Update MeterConfig (delete details) – Step 4..... | 241 |
| J.2.14 | Delete MeterConfig – Step 1..... | 242 |
| J.2.15 | Delete MeterConfig – Step 2..... | 243 |
| J.2.16 | Delete MeterConfig – Step 3..... | 244 |

| | | |
|---|--|-----|
| J.2.17 | Delete MeterConfig – Step 4..... | 245 |
| J.2.18 | Create UsagePointConfig – Step 1 | 246 |
| J.2.19 | Create UsagePointConfig – Step 2 | 247 |
| J.2.20 | Create UsagePointConfig – Step 3 | 247 |
| J.2.21 | Create UsagePointConfig – Step 4 | 248 |
| J.2.22 | Create MasterDataLinkageConfig – Step 1 | 249 |
| J.2.23 | Create MasterDataLinkageConfig – Step 1 | 250 |
| J.2.24 | Create MasterDataLinkageConfig – Step 3 | 251 |
| J.2.25 | Create MasterDataLinkageConfig – Step 4 | 252 |
| J.2.26 | Delete MasterDataLinkageConfig – Step 1..... | 253 |
| J.2.27 | Delete MasterDataLinkageConfig – Step 2..... | 254 |
| J.2.28 | Delete MasterDataLinkageConfig – Step 3..... | 255 |
| J.2.29 | Delete MasterDataLinkageConfig – Step 4..... | 256 |
| J.2.30 | Execute OperationSet – Step 1..... | 256 |
| J.2.31 | Execute OperationSet – Step 2..... | 258 |
| J.2.32 | Execute OperationSet – Step 3..... | 259 |
| J.2.33 | Execute OperationSet – Step 4..... | 259 |
| J.2.34 | Change ObjectNamesConfig..... | 260 |
| Annex K (normative) EUMED Metering UML Model..... | | 261 |
| K.1 | EUMED Metering profile and associated European regulation..... | 261 |
| K.1.1 | The EUMED Metering profile | 261 |
| K.1.2 | The Associated European regulation | 261 |
| K.2 | EUMED Metering global view..... | 262 |
| K.3 | EUMED Metering Entities..... | 265 |
| K.3.1 | General | 265 |
| K.3.2 | MeterReadingSet Entity | 265 |
| K.3.3 | MeterReading Entity | 265 |
| K.3.4 | Meter Entity | 266 |
| K.3.5 | Customer Entity | 266 |
| K.3.6 | IntervalBlock Entity | 267 |
| K.3.7 | IntervalReading Entity | 267 |
| K.3.8 | ReadingQuality Entity | 268 |
| K.3.9 | UsagePoint Entity | 269 |
| K.3.10 | UsagePointLocation Entity..... | 269 |
| K.3.11 | ReadingType Entity | 270 |
| K.3.12 | Name Entity..... | 273 |
| K.3.13 | NameType Entity | 273 |
| K.3.14 | NameTypeAuthority Entity | 274 |
| K.4 | EUMED Metering Datatypes..... | 275 |
| K.4.1 | General | 275 |
| K.4.2 | AccumulationKind enumeration Datatype..... | 276 |
| K.4.3 | AggregateKind enumeration Datatype..... | 277 |
| K.4.4 | CommodityKind enumeration Datatype | 278 |
| K.4.5 | Currency enumeration Datatype | 279 |
| K.4.6 | CustomerKind enumeration Datatype..... | 282 |
| K.4.7 | DateTimeInterval compound Datatype | 283 |
| K.4.8 | FlowDirectionKind enumeration Datatype | 283 |
| K.4.9 | MacroPeriodKind enumeration Datatype | 285 |
| K.4.10 | MeasurementKind enumeration Datatype..... | 285 |

| | | |
|-----------------------|--|-----|
| K.4.11 | MeasuringPeriodKind enumeration Datatype | 288 |
| K.4.12 | PhaseCode enumeration Datatype..... | 290 |
| K.4.13 | RationalNumber compound Datatype..... | 291 |
| K.4.14 | ReadingInterharmonic compound Datatype..... | 291 |
| K.4.15 | UnitMultiplier enumeration Datatype | 291 |
| K.4.16 | UnitSymbol enumeration Datatype..... | 292 |
| Annex L (normative) | EUMED Metering XSD schema..... | 298 |
| L.1 | EUMED Metering Entities global view | 298 |
| L.1.1 | General | 298 |
| L.1.2 | MeterReadingSet Entity | 298 |
| L.1.3 | MeterReading Entity | 298 |
| L.1.4 | Meter Entity | 299 |
| L.1.5 | Customer Entity | 299 |
| L.1.6 | IntervalBlock Entity | 300 |
| L.1.7 | IntervalReading Entity | 300 |
| L.1.8 | ReadingQuality Entity | 301 |
| L.1.9 | UsagePoint Entity | 302 |
| L.1.10 | UsagePointLocation Entity..... | 302 |
| L.1.11 | ReadingType Entity | 302 |
| L.1.12 | Name Entity..... | 303 |
| L.1.13 | NameType Entity | 304 |
| L.1.14 | NameTypeAuthority Entity | 304 |
| L.2 | EUMED Metering Entities description..... | 305 |
| L.3 | EUMED Metering Datatypes Description | 311 |
| Annex M (informative) | Contextualization and examples of EUMED metering messages | 351 |
| M.1 | Overview | 351 |
| M.2 | EUMED Metering Load Curve message payload | 351 |
| M.3 | EUMED Metering Max Power message payload..... | 352 |
| M.4 | EUMED Metering Index message payload..... | 352 |
| Bibliography | | 355 |
| Figure 1 | – IEC 61968-9 scope | 18 |
| Figure 2 | – Outage Detection, request/reply message exchange, Example 1..... | 29 |
| Figure 3 | – Outage Detection, request / reply message exchange, Example 2..... | 29 |
| Figure 4 | – Outage Detection, publish/subscribe exchange, Example 1..... | 30 |
| Figure 5 | – Outage Detection, publish/subscribe exchange, Example 2..... | 31 |
| Figure 6 | – Meter Health Event exchange, Example 1 | 32 |
| Figure 7 | – Meter Health Event exchange, Example 2 | 32 |
| Figure 8 | – Power quality event exchange, Example 1 | 33 |
| Figure 9 | – Power quality event exchange, Example 2 | 33 |
| Figure 10 | – End device event message format..... | 34 |
| Figure 11 | – EndDeviceEvents example..... | 35 |
| Figure 12 | – Example use of meter read schedule to create subscription | 36 |
| Figure 13 | – Example manual meter reading exchange | 37 |
| Figure 14 | – Example On-Request meter read | 39 |
| Figure 15 | – Historical MeterData exchange..... | 40 |

| | |
|--|----|
| Figure 16 – Example billing inquiry message exchange | 40 |
| Figure 17 – Meter readings message format | 41 |
| Figure 18 – Reading structure | 44 |
| Figure 19 – Timestamps assigned between systems | 45 |
| Figure 20 – Conventions for timeStamp and timePeriod | 45 |
| Figure 21 – IntervalBlock structure | 46 |
| Figure 22 – Interval data timestamp generation | 47 |
| Figure 23 – Time interval conventions | 47 |
| Figure 24 – ReadingType structure | 48 |
| Figure 25 – MeterReadings Example 1 | 49 |
| Figure 26 – MeterReadings Example 2 | 50 |
| Figure 27 – Coincident readings example | 51 |
| Figure 28 – Final meter reading coincident with disconnect example | 51 |
| Figure 29 – GetMeterReadings example | 52 |
| Figure 30 – Meter read schedules message format | 53 |
| Figure 31 – Example load control message exchange | 55 |
| Figure 32 – Example message exchange for LC unit installation | 56 |
| Figure 33 – Example message exchange for change of customer program | 57 |
| Figure 34 – Example message exchange for change of customer program w/o MDM | 57 |
| Figure 35 – Example for change of customer program with meter change out | 58 |
| Figure 36 – Example message exchange for meter connect/disconnect | 59 |
| Figure 37 – Example of remote connect/disconnect directly between CIS and MS | 60 |
| Figure 38 – Example message exchange for real-time price signal | 61 |
| Figure 39 – End device controls message format | 62 |
| Figure 40 – EndDevice example | 63 |
| Figure 41 – EndDeviceControl example | 64 |
| Figure 42 – EndDeviceControls disconnect by group example | 64 |
| Figure 43 – EndDeviceControls meter connection example | 65 |
| Figure 44 – Example end device event message exchange due to meter changeout | 66 |
| Figure 45 – Example firmware upgrade message exchange | 67 |
| Figure 46 – Pairing of a PAN device | 68 |
| Figure 47 – PAN device events | 69 |
| Figure 48 – PAN device controls | 70 |
| Figure 49 – Master data linkages | 72 |
| Figure 50 – Message exchange for transferring usage point information | 73 |
| Figure 51 – Message exchange for transferring meter information | 74 |
| Figure 52 – Message exchange for transferring end device information | 74 |
| Figure 53 – MasterDataLinkageConfig message format | 75 |
| Figure 54 – MaterDataLinkageConfig example | 76 |
| Figure 55 – UsagePointConfig message format | 77 |
| Figure 56 – UsagePointConfig example | 78 |
| Figure 57 – UsagePointLocationConfig message format | 79 |
| Figure 58 – UsagePointLocationConfig example | 80 |

Figure 59 – End device config message format 81

Figure 60 – Meter configuration message 82

Figure 61 – MeterConfig example 83

Figure 62 – ComModuleConfig message format 83

Figure C.1 – Typical enumerations for accumulation behaviour 97

Figure C.2 – Typical enumerations for direction of flow 104

Figure C.3 – Voltage measurements 113

Figure E.1 – Event data 162

Figure E.2 – Multiple EndDeviceEventDetails Example 1 162

Figure E.3 – EndDeviceEventDetails example 2 163

Figure E.4 – EndDeviceEvent Example 3 163

Figure H.1 – GetMeterReadings 209

Figure H.2 – GetMeterConfig 210

Figure J.1 – Create MeterConfig – Two Meters – Step 1 230

Figure J.2 – Create MeterConfig – Two Meters – Step 2 231

Figure J.3 – Create MeterConfig – Two Meters – Step 3 232

Figure J.4 – Create MeterConfig – Two Meters – Step 4 233

Figure J.5 – Create MeterConfig – Update MeterConfig (add MeterMultiplies, modify formNumber and ConfigurationEvent) Step 1 234

Figure J.6 – Update MeterConfig (add MeterMultiplies, modify formNumber and ConfigurationEvent) Step 2 235

Figure J.7 – Update MeterConfig (add MeterMultiplies, modify formNumber and ConfigurationEvent) Step 3 236

Figure J.8 – Update MeterConfig (add MeterMultiplies, modify formNumber and ConfigurationEvent) Step 4 237

Figure J.9 – Update MeterConfig (delete details) – Step 1 238

Figure J.10 – Update MeterConfig (delete details) – Step 2 239

Figure J.11 – Update MeterConfig (delete details) – Step 3 240

Figure J.12 – Update MeterConfig (delete details) – Step 4 241

Figure J.13 – Delete MeterConfig – Step 1 242

Figure J.14 – Delete MeterConfig – Step 2 243

Figure J.15 – Delete MeterConfig – Step 3 244

Figure J.16 – Delete MeterConfig – Step 4 245

Figure J.17 – Create UsagePointConfig – Step 1 246

Figure J.18 – Create UsagePointConfig – Step 2 247

Figure J.19 – Create UsagePointConfig – Step 3 247

Figure J.20 – Create UsagePointConfig – Step 4 248

Figure J.21 – Create MasterDataLinkageConfig – Step 1 249

Figure J.22 – Create MasterDataLinkageConfig – Step 2 250

Figure J.23 – Create MasterDataLinkageConfig – Step 3 251

Figure J.24 – Create MasterDataLinkageConfig – Step 4 252

Figure J.25 – Delete MasterDataLinkageConfig – Step 1 253

Figure J.26 – Delete MasterDataLinkageConfig – Step 2 254

Figure J.27 – Delete MasterDataLinkageConfig – Step 3 255

| | |
|--|-----|
| Figure J.28 – Delete MasterDataLinkageConfig – Step 4 | 256 |
| Figure J.29 – Execute OperationSet – Step 1 | 258 |
| Figure J.30 – Execute OperationSet – Step 2 | 258 |
| Figure J.31 – Execute OperationSet – Step 3 | 259 |
| Figure J.32 – Execute OperationSet – Step 4 | 260 |
| Figure K.1 – EUMED Metering Class diagram | 264 |
| Figure L.1 – MeterReadingSet schema for EUMED Metering | 298 |
| Figure L.2 – The MeterReading schema used for EUMED Metering | 299 |
| Figure L.3 – Meter Entity | 299 |
| Figure L.4 – Customer Schema used for EUMED Metering | 300 |
| Figure L.5 – IntervalBlock Schema used for EUMED Metering | 300 |
| Figure L.6 – IntervalReading schema used for EUMED metering | 301 |
| Figure L.7 – ReadingQuality element for EUMED Metering | 301 |
| Figure L.8 – UsagePoint element used in EUMED Metering | 302 |
| Figure L.9 – UsagePointLocation element used in EUMED Metering | 302 |
| Figure L.10 – ReadingType element used in EUMED Metering | 303 |
| Figure L.11 – Name element used in EUMED Metering | 304 |
| Figure L.12 – NameType element used in EUMED Metering | 304 |
| Figure L.13 – NameTypeAuthority element used in EUMED Metering | 304 |
| Figure M.1 – Load curve XML message payload | 351 |
| Figure M.2 – Max power XML message payload | 352 |
| Figure M.3 – Index XML message payload (extract 1) | 353 |
| Figure M.4 – Index XML message payload (extract 2) | 354 |
| | |
| Table 1 – Business functions and abstract components | 23 |
| Table 2 – Classes for meter reading and control | 24 |
| Table 3 – Classes related to meter reading and control | 27 |
| Table 4 – IEC 61968-9 configuration profiles | 71 |
| Table A.1 – Recommended verb usage with related profiles | 85 |
| Table C.1 – Time-period of interest enumerations | 90 |
| Table C.2 – Data qualifier enumerations | 91 |
| Table C.3 – measuringPeriod enumerations | 92 |
| Table C.4 – Demand normalization scalars | 93 |
| Table C.5 – Accumulation behaviour enumerations | 95 |
| Table C.6 – Customary accumulation behaviour enumerations | 97 |
| Table C.7 – Direction of flow enumeration | 98 |
| Table C.8 – DirectionOfFlow enumeration equivalencies | 103 |
| Table C.9 – Commodity | 104 |
| Table C.10 – measurementKind Index | 106 |
| Table C.11 – Harmonic and Interharmonic enumerations | 114 |
| Table C.12 – Argument enumerations | 115 |
| Table C.13 – Time Of Use Enumerations | 116 |
| Table C.14 – Critical Peak Period Enumerations | 116 |

| | |
|--|-----|
| Table C.15 – Consumption Tier Enumerations | 117 |
| Table C.16 – Example Combinations of TOU and Consumption Tier Enumerations | 117 |
| Table C.17 – Phase enumerations | 119 |
| Table C.18 – Power of ten enumerations | 122 |
| Table C.19 – Historical concentration multiplier enumerations | 123 |
| Table C.20 – Base SI units of measure | 125 |
| Table C.21 – Derived SI units of measure with special names | 125 |
| Table C.22 – Derived SI Units of Measure without Special Names | 127 |
| Table C.23 – Non-SI Units of Measure accepted for use with the International System of Units | 131 |
| Table C.24 – Dimensionless and Concentration Units of Measure | 132 |
| Table C.25 – Non-SI units whose values in SI units shall be obtained experimentally | 134 |
| Table C.26 – Other Non-SI Units of Measure | 135 |
| Table C.27 – Non-SI Units Associated with the CGS and the CGS-Gaussian System of Units | 139 |
| Table C.28 – Currency units of measure (from ISO 4217) | 140 |
| Table C.29 – ReadingType Examples | 142 |
| Table D.1 – System identifier | 147 |
| Table D.2 – Example quality code categories | 147 |
| Table D.3 – Validity related codes | 148 |
| Table D.4 – Diagnostics related codes | 149 |
| Table D.5 – Power quality related codes | 150 |
| Table D.6 – Tamper / revenue protection related codes | 150 |
| Table D.7 – Data collection related codes | 151 |
| Table D.8 – Failed reasonability testing related codes | 152 |
| Table D.9 – Failed validation testing related codes | 152 |
| Table D.10 – Edit related codes | 154 |
| Table D.11 – Estimation related codes | 155 |
| Table D.12 – Questionable related codes | 156 |
| Table D.13 – Derived related codes | 157 |
| Table D.14 – Projected related codes | 158 |
| Table D.15 – Example Quality Codes | 159 |
| Table E.1 – Example pairings between meter events and EndDeviceEvent enumerated mnemonics | 161 |
| Table E.2 – EndDeviceType codes | 164 |
| Table E.3 – EndDeviceDomain Codes | 165 |
| Table E.4 – EndDeviceSubdomain codes | 167 |
| Table E.5 – EndDeviceEventOrAction codes | 173 |
| Table E.6 – Battery events | 180 |
| Table E.7 – Billing events | 181 |
| Table E.8 – Cartridge events | 181 |
| Table E.9 – Clock events | 182 |
| Table E.10 – Communication events | 183 |
| Table E.11 – Configuration events | 184 |

| | |
|---|-----|
| Table E.12 – Demand events | 185 |
| Table E.13 – Firmware events | 185 |
| Table E.14 – GasSupply events | 187 |
| Table E.15 – Installation events | 187 |
| Table E.16 – LoadControl events | 187 |
| Table E.17 – LoadProfile events | 188 |
| Table E.18 – Logs events | 188 |
| Table E.19 – Memory events | 189 |
| Table E.20 – Metrology events..... | 189 |
| Table E.21 – MobileSecurity events | 191 |
| Table E.22 – Modem events..... | 192 |
| Table E.23 – ModuleFirmware events | 192 |
| Table E.24 – Network events | 192 |
| Table E.25 – PAN / HAN events..... | 193 |
| Table E.26 – Power events | 194 |
| Table E.27 – Pressure events | 197 |
| Table E.28 – RCDSwitch events | 197 |
| Table E.29 – Security events | 198 |
| Table E.30 – Temperature events | 200 |
| Table E.31 – VideoDisplay events..... | 200 |
| Table E.32 – WaterSupply events | 200 |
| Table F.1 – Demand Controls | 201 |
| Table F.2 – LoadControl Controls | 202 |
| Table F.3 – PAN / HAN Controls | 202 |
| Table F.4 – RCDSwitch Controls..... | 202 |
| Table J.1 – Exemplary master data management / data synchronization use cases | 213 |
| Table K.1 – Entities of the EUMED Metering Model | 263 |
| Table K.2 – Association ends of EUMED Metering ENTITIES:: MeterReadingSet with other classes | 265 |
| Table K.3 – Attributes of EUMED Metering ENTITIES::MeterReading | 265 |
| Table K.4 – Association ends of EUMED Metering ENTITIES:: MeterReading with other classes | 266 |
| Table K.5 – Attributes of EUMED Metering ENTITIES::Meter | 266 |
| Table K.6 – Association ends of EUMED Metering ENTITIES::Meter with other classes | 266 |
| Table K.7 – Attributes of EUMED Metering ENTITIES::Customer | 267 |
| Table K.8 – Association ends of EUMED Metering ENTITIES:: Customer with other classes | 267 |
| Table K.9 – Association ends of Metering::IntervalBlock with other classes | 267 |
| Table K.10 – Attributes of EUMED Metering ENTITIES::IntervalReading..... | 268 |
| Table K.11 – Association ends of EUMED Metering ENTITIES:: IntervalReading with other classes | 268 |
| Table K.12 – Attributes of EUMED Metering ENTITIES::ReadingQuality | 268 |
| Table K.13 – Association ends of EUMED Metering ENTITIES:: ReadingQuality with other classes | 269 |
| Table K.14 – Attributes of EUMED Metering ENTITIES::UsagePoint | 269 |

| | |
|--|-----|
| Table K.15 – Association ends of EUMED Metering ENTITIES:: UsagePoint with other classes | 269 |
| Table K.16 – Attributes of EUMED Metering ENTITIES::UsagePointLocation | 270 |
| Table K.17 – Association ends of EUMED Metering ENTITIES:: UsagePointLocation with other classes | 270 |
| Table K.18 – Attributes of EUMED Metering ENTITIES::ReadingType..... | 270 |
| Table K.19 – Association ends of EUMED Metering ENTITIES:: ReadingType with other classes | 273 |
| Table K.20 – Attributes of EUMED Metering ENTITIES::Name | 273 |
| Table K.21 – Association ends of EUMED Metering ENTITIES::Name with other classes | 273 |
| Table K.22 – Attributes of EUMED Metering ENTITIES::NameType | 274 |
| Table K.23 – Association ends of EUMED Metering ENTITIES:: NameType with other classes | 274 |
| Table K.24 – Attributes of EUMED Metering ENTITIES::NameTypeAuthority | 274 |
| Table K.25 – Association ends of EUMED Metering ENTITIES:: NameTypeAuthority with other classes | 274 |
| Table K.26 – Association ends of EUMED Metering ENTITIES:: MeterReadingSet with other classes | 275 |
| Table K.27 – Datatypes of EUMED Metering Model | 275 |
| Table K.28 – Literals of EUMED Metering DATA TYPES::AccumulationKind | 276 |
| Table K.29 – Literals of EUMED Metering DATA TYPES::AggregateKind | 277 |
| Table K.30 – Literals of EUMED Metering DATA TYPES::CommodityKind | 278 |
| Table K.31 – Literals of EUMED Metering DATA TYPES::Currency..... | 279 |
| Table K.32 – Literals of EUMED Metering DATA TYPES::CustomerKind..... | 283 |
| Table K.33 – Attributes of EUMED Metering DATA TYPES::DateTimeInterval..... | 283 |
| Table K.34 – Literals of EUMED Metering DATA TYPES::FlowDirectionKind..... | 284 |
| Table K.35 – Literals of EUMED Metering DATA TYPES::MacroPeriodKind | 285 |
| Table K.36 – Literals of EUMED Metering DATA TYPES::MeasurementKind..... | 286 |
| Table K.37 – Literals of EUMED Metering DATA TYPES::MeasuringPeriodKind..... | 289 |
| Table K.38 – Literals of EUMED Metering DATA TYPES::PhaseCode | 290 |
| Table K.39 – Attributes of EUMED Metering DATA TYPES::RationalNumber | 291 |
| Table K.40 – Attributes of EUMED Metering DATA TYPES::ReadingInterharmonic | 291 |
| Table K.41 – Literals of EUMED Metering DATA TYPES::UnitMultiplier | 292 |
| Table K.42 – Literals of EUMED Metering DATA TYPES::UnitSymbol | 293 |
| Table L.1 – Association ends of EUMED Metering ENTITIES:: IntervalBlock with other classes | 300 |

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**ENTERPRISE BUSINESS FUNCTION INTERFACES
FOR UTILITY OPERATIONS –****Part 9: Interfaces for meter reading and control**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 61968-9 has been prepared by IEC technical committee 57: Power systems management and associated information exchange. It is an International Standard.

This third edition cancels and replaces the second edition published in 2013. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) IEC 61968-100:2022 has superseded IEC 61968-100:2013 that was used in many of the examples in IEC 61968-9:2013. Applicable portions of the current version of IEC 61968-9 have been updated to reflect message envelope and message exchange patterns specified in IEC 61968-100:2022. Although the use of IEC 61968-100 is highly recommended, it is possible to utilize IEC 61968-9 without using IEC 61968-100 message envelopes or exchange patterns. This was true for IEC 61968-9:2013 and remains true for this IEC 61968-9:2024.
- b) Unless noted otherwise, the IEC 61968-9:2013 XSDs that remain in IEC 61968-9:2024 are unchanged except for changes that have been made for compatibility with IEC 61968-100:2022 as described in 61968-100:2022. This supports the abstract payload construct in the Message.xsd defined in IEC 61968-100:2022. As a result, these modified profiles have a new namespace. One notable exception is that the MeterReadSchedule.xsd has been replaced with a new MeterReadSchedules.xsd. It has structural changes to support improved functionality as described in 5.3.3. Another exception is that the GetMeterReadSchedule.xsd has been replaced with GetMeterReadSchedules.xsd. Also note that IEC 61968-8:2015 profiles listed in the table in Annex A will require edits in order to be compatible with IEC 61968-100:2022.
- c) The "Verbs" listed in IEC 61968-9:2013, Annex A have been moved to IEC 61968-100:2022. Annex A now (in this third edition) instead provides a table which recommends the use of certain verbs to accompany profiles related to 61968-9;
- d) The "Reply Error Codes" listed in IEC 61968:2013, Annex B have been moved to IEC 61968-100:2022. Annex B now (in this third edition) instead provides a few recommendations on how to handle certain error situations which might originate in 61968-9;
- e) Customer profiles CustomerAccountConfig, CustomerAgreementConfig, CustomerConfig, GetAuxiliaryAgreementConfig, GetCustomerAccountConfig, GetCustomerAgreementConfig, GetServiceCategoryConfig, GetCustomerConfig, GetMeterServiceRequests, GetPricingStructureConfig, GetServiceLocationConfig, GetServiceSupplierConfig, MeterServiceRequests, PricingStructureConfig, ServiceCategoryConfig, ServiceLocationConfig, and ServiceSupplierConfig have been deleted from this document and moved to IEC 61968-8. However, certain references to these profiles have been retained for the sake of usability. A "MeterServiceRequest" which might be issued by a function within IEC 61968-9:2013, is now shared with 61968-8 which also could just as well have a need to issue such a request. Users of one part may have to refer to another part within the 61968 series in order to obtain a shared schema. Furthermore, certain names may change when they are moved from one part to another. For example, a "MeterServiceRequest" is now referred to as a (more generic) "ServiceRequest".;
- f) Additional enumerations have been provided in the annexes for ReadingTypes (Annex C), EndDeviceEventTypes (Annex E) and EndDeviceControlTypes (Annex F);
- g) Statements have been added to certain figures, tables, schemas, and enumerations throughout the document that indicate that they are reproduced with the permission of the UCA International User Group (UCAIug). These items are derived from the Common Information Model (CIM);
- h) The "Conventions for naming and identifying objects" provided in IEC 61968:2013, Annex G has been deleted. The user should instead consider IEC 61968-11, *Common information model (CIM) extensions for Operation Support* or IEC 61970-301, *Energy management system application program interface (EMS-API) – Part 301: Common information model (CIM) base*. This deletion causes subsequent Annexes in IEC 61968:2013, to be renumbered in this third edition; The "Notes on extended use of IEC 61968-100" provided in Annex M of IEC 61968:2013, have been deleted. It is recommended that the reader instead obtain a copy of the most recent version of 61968-100.
- i) The profiles in IEC 61968-9:2013, Annex H "(Normative) XML Schemas for Message Payloads" and IEC 61968-9:2013, Annex I "(Informative) XML Schemas for Message Payloads" have been removed from the document. Instead, there is now (in this third edition) an Annex G which provides links to the profiles at the UCAIug website,

- j) Small changes have been made to the document for better comprehension and usability;
- k) Added normative and informative annexes (K,L, and M) to describe how IEC 61968-9 can be used to support European regulation regarding access to data and interoperability. In particular, these annexes describe the EUMED Metering profile, and serve to draft requirements to address provisions laid down in Articles 20, 23, and 24 of the Electricity Directive (EU) 2019/944. For more information refer to IEC 62325-451-10.

The text of this International Standard is based on the following documents:

| | |
|--------------|------------------|
| Draft | Report on voting |
| 57/2670/FDIS | 57/2679/RVD |

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts in the IEC 61968 series, published under the general title *Enterprise business function interfaces for utility operations*, can be found on the IEC website.

Future standards in this series will carry the new general title as cited above. Titles of existing standards in this series will be updated at the time of the next edition.

This IEC standard includes Code Components i.e. components that are intended to be directly processed by a computer. Such content is any text found between the markers <CODE BEGINS> and <CODE ENDS>, or otherwise is clearly labelled in this standard as a Code Component.

The purchase of this IEC standard carries a copyright license for the purchaser to sell software containing Code Components from this standard to end users either directly or via distributors, subject to IEC software licensing conditions, which can be found at: <https://www.iec.ch/webstore/custserv/pdf/CC-EULA.pdf>.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

The purpose of this part of IEC 61968 is to define a standard for the integration of Metering Systems (MS), which would include traditional (one or two-way) Automated Meter Reading (AMR) Systems, with other systems and business functions within the scope of IEC 61968. The scope of this document is the exchange of meter reading, transactions, event and control information between systems within the utility enterprise and between enterprises. The specific details of communication protocols those systems employ are outside the scope of this document. Instead, this document will recognize and model the general capabilities that can be potentially provided by advanced and/or legacy meter infrastructures, including two-way communication capabilities such as load control, dynamic pricing, outage detection, distributed energy resource (DER) control signals and on-request read.