

IEC 60092-504
(Third edition – 2001)

**Electrical installations in ships –
Part 504: Special features – Control and instrumentation**

CORRIGENDUM 1

5 Environmental type testing parameters

Replace, in Table 1, item 2, column Other information:

“- Air pressure: 90 kPa ± 10 kPa”

by:

“- Air pressure: 96 kPa ± 10 kPa”

Withdrawn